


MASTER

GEND-INF-017
Volume VI
January 1982



This is an informal report intended for use as a preliminary or working document

GEND

General Public Utilities • Electric Power Research Institute • U.S. Nuclear Regulatory Commission • U.S. Department of Energy

FIELD MEASUREMENTS AND INTERPRETATION OF TMI-2 INSTRUMENTATION: IC-10-dPT

**J. E. Jones
J. T. Smith
M. V. Mathis**

**U.S. Department of Energy
Three Mile Island Operations Office
Under DOE Contract No. DE-AC07-76ID01570**

DISCLAIMER

This document contains information that is the property of the U.S. Department of Energy. It is loaned to you for your information and use only. It is not to be distributed outside your organization. It is not to be used for any purpose other than that for which it was loaned to you. It is not to be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of the U.S. Department of Energy.

**GEND-INF-017
Volume VI**

FIELD MEASUREMENTS AND INTERPRETATION OF TMI-2 INSTRUMENTATION: IC-10-dPT

GEND-INF--017 Vol. 6

**J. E. Jones
J. T. Smith
M. V. Mathis**

DE82 010037

Technology for Energy Corporation

January 1982

**Published on Behalf of the GEND Group
by
EG&G Idaho, Inc.
Idaho Falls, Idaho 83415**

**Prepared for the
U.S. Department of Energy
Three Mile Island Operations Office
Under DOE Contract No. DE-AC07-76ID01570**

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1. INTRODUCTION	1-1
2. INSTRUMENT LOCATION, CABLING, AND TERMINATIONS	2-1
3. MEASUREMENT PROCEDURES	3-1
4. MEASUREMENTS	4-1
5. INTERPRETATION OF MEASUREMENTS	5-1
6. CONCLUSIONS	6-1
APPENDIX	

LIST OF TABLES

<u>Table</u>	<u>Page</u>
2-1 Termination Points for JC-10-dPT Measurements	2-3
4-1 Capacitance, Impedance, and Resistance Measurements	4-6
5-1 Major AC Components on the Flow Signal	5-2
5-2 Summary of TDR Measurements	5-5

LIST OF FIGURES

<u>Figure</u>	<u>Page</u>
2-1 Composite Electrical Diagram for Control Rod Drive Bypass Flow IC-10-dPT	2-2
2-2 Functional Diagram of Bailey Type BY Differential Pressure Transmitter	2-4
4-1 Oscilloscope Traces of Flow Signal	4-2
4-2 Oscilloscope Trace of 118 VAC Supply	4-3
4-3 High Frequency Spectra of Flow Signal	4-4
4-4 Low Frequency Spectra of Flow Signal	4-5
4-5 TDR Trace of Flow Signal Lines	4-8
4-6 TDR Trace of (+) Signal to Shield	4-9
4-7 TDR Trace of 118 VAC Lines	4-10
4-8 TDR Trace of 118 VAC (H) to Shield	4-11

Section 1

INTRODUCTION

During and following the TMI-2 accident, a number of instruments failed or were suspected of providing erroneous readings. Because of this problem, industry concerns were focused upon the behavior of instrumentation under adverse conditions. To better understand failure mechanisms, the Technical Integration Office (TIO) contracted Technology for Energy Corporation (TEC) to perform field measurements on a set of selected TMI-2 instruments to determine in-situ operating characteristics. For some instruments, these measurements were to be performed prior to removal (and replacement with new instruments) in order to have a cross reference with post removal observations. For other instruments, an indication of the condition of the instrument (i. e., fully operational or failed) was desired.

This report describes the measurements and results of the Control Rod Drive Bypass Flow IC-10-dPT. This instrument consists of a Bailey Type BY Process Computer Transmitter connected to a readout module by approximately 500 feet of cable through a penetration junction and an instrument mounting junction. The status of this instrument is uncertain, but it was producing a reasonable output reading of zero flow which could indicate it had not failed. As a result, measurements on this instrument were designed to determine if it were properly functioning.

Section 2

INSTRUMENT LOCATION, CABLING, AND TERMINATIONS

A review of appropriate drawings from Bailey Meter Company and Burns & Roe (itemized in the Appendix in the measurement procedure, pages A-5 and A-6) resulted in the composite electrical diagram shown in Figure 2-1. From this information, Table 2-1 gives a list of the appropriate termination points for performing measurements in Control Cabinet 157. Also noted in Figure 2-1 are the cable lengths pulled during instrument installation and lengths after trimming between each termination and/or junction point.

The flow sensing assembly is a Bailey Type BY which consists of a differential pressure LVDT, temperature compensation, and calibration adjustment for conversion of pressure difference to flow. This instrument has a normal range of 0-200 GPM, producing an output of -10 to +10 volts. The functional diagram of the unit is shown in Figure 2-2.

Since measurements were being made in Control Cabinet 157, the effect of the readout meter (attached to the signal line) was present on the observed instrument response. However, since this readout was located outside containment, it did not experience severe operating environments, and thus was not considered to have failed.




Figure 2-1. Composite Electrical Diagram for Control Rod Drive Bypass Flow IC-10-dPT

Table 2-1

TERMINATION POINTS FOR IC-10-dPT MEASUREMENTS

Signal	Cabinet 156 Identification*
+Signal	TB9-2-5/9
-Signal	TB9-2-5/8
Shield	TB9-2-5/10
118 VAC (H)	TB9-2-5/6
118 VAC (L)	TB9-2-5/7

*From cables IT2823I (signal lines) and IT2754C (118 VAC).




Figure 2-2. Functional Diagram of Bailey Type BY Differential Pressure Transmitter.

Section 3

PREPARATION OF MEASUREMENT PROCEDURES

As a result of generating the composite electrical diagram and from a review of the Bailey Meter Product Instruction E21-17 Manual, the major types of measurements to be performed were identified as:

1. Determine as-found condition of flow indication and record signal output.
2. Perform passive measurements (i.e., passively monitor signals) on each electrical connection consisting of time domain waveforms, very-high frequency spectrum analysis (i.e., MHz region), and frequency spectra below 100 kHz.
3. Perform resistance, capacitance, impedance, and Time Domain Reflectometry (TDR) active measurements (i.e., actively introducing a test signal).

These measurements were designed to verify the operation of the Readout Module and the power supplies, but the focus of the measurement was on the flow measurement assembly, cabling, and terminations/connections to the assembly. The Appendix contains the detailed procedure which was followed during the measurement program, and a summary of measurements is presented in the next section.

Section 4

MEASUREMENTS

Since the output of IC-10-dPT was designed to cover the range of -10 to +10 volts, the signal could be directly measured without amplification. Before performing measurements, the readout of IC-10-dPT indicated no flow for the control rod drive. The flow indication signal was then recorded for approximately 10 minutes on an FM recorder and the voltage outputs measured (with a DVM). The output of the flow signal was -10.8 VDC, and the power supply was 117 VAC.

The next measurements consisted of photographing the output waveforms of the flow signal and line voltage from a storage oscilloscope. Figures 4-1 and 4-2 show the results of these time trace measurements. Along with the time traces, both high and low frequency spectra (frequency domain) were taken of the flow signal. Figure 4-3 shows the measured spectra over both a 6 MHz and 1 MHz bandwidth, while Figure 4-4 shows spectra over both a 100 kHz and 1 kHz range.

Following the frequency spectra measurements, electrical calibration data was requested from the TMI Instrumentation Shop; however, this data was not available. Power was then removed from IC-10-dPT. The test fixture was removed and all signal lines from cables IT2823I and IT2754C to cabinet 157 were disconnected.

A series of active measurements (i.e., actively introducing a test signal into the circuit) was then performed. Table 4-1 shows the




Photo 111-1

Time - 50 μ sec/div

Gain - 10 mV/div

Signal - SIGNAL




Photo 111-2

Time - 0.5msec/div

Gain - 10 mV/div

Signal - SIGNAL




Photo 111-3

Time - 5msec/div

Gain - 10 mV/div

Signal - SIGNAL

Figure 4-1. Oscilloscope Traces of Flow Signal




Photo 111-4

Time - 5msec/div

Gain - 5 V/div

X10 Probe

Signal - 118 VAC

Figure 4-2. Oscilloscope Trace of 118 VAC Supply




Photo 111-5

BW - 3 KHz

Scan width - 1 mHz/div

Scan time - 1 sec/div

Attn - 0

Log Ref - -20 db

SIGNAL




Photo 111-6

BW - 3 KHz

Scan width - 0.2 mHz/div

Scan time - 1 sec/div

Attn - 0

Log Ref - -20 db

SIGNAL

Figure 4-3. High Frequency Spectra of Flow Signal

0.00408 RMS




Photo 111-7

100 KHz Range

+20 db Reference

0.000543 RMS




Photo 111-8

1 KHz Range

+20 db Reference

Figure 4-4. Low Frequency Spectra of Flow Signal

Table 4-1

CAPACITANCE, IMPEDANCE, AND RESISTANCE MEASUREMENTS

Signal	Capacitance (nF)*			Impedance (ohms)			Resistance (ohms)**
	100Hz	1kHz	100kHz	100Hz	1kHz	100kHz	
+Signal -Signal	22	20	15	4.3K	3.3K	104	6.7K (8.1K)
+Signal Shield	59	47	41	27K	3.3K	40	0F [†]
-Signal Shield	59	48	43	27K	3.2K	38	0F
118 VAC (H) 118 VAC (L)	-120	17	25	12K	9K	65	99 (99)
118 VAC (H) -Signal	0.9	0.6	-2.5	0F	0F	333	0F
118 VAC (H) Shield	0.9	0.6	-29	0F	0F	171	0F

* nF = Nano~~farads~~ farads.

** Values in parentheses are reverse polarity values.

[†] 0F indicates overflow condition.

results of capacitance, impedance, and DC resistance measurements on some of the field cable lines (see Appendix page A-12 for a complete set). A set of TDR measurements were taken on the signal lines to determine possible cable defects. These TDR traces are shown in Figures 4-5 to 4-8.

STRIP CHART 111-i

IC-10-DPT





Figure 4-5. TDR Trace of Flow Signal Lines

STRIP CHART 111-2

IC-10-DPT

Setting - $500\mu\text{p}/\text{div}$

Range - 52.6 ft/div

Sensitivity - 0.25


Filter - 15 Hz

Cable dielectric - poly

Figure 4-6. TDR Trace of (+) Signal to Shield

STRIP CHART 111-3

IC-10-DPT



Setting - 500 μ p/div

Range - 52.6 ft/div

Sensitivity - 0.25

Filter - 15 Hz

Cable dielectric - other

Figure 4-7. TDR Trace of 118 VAC Lines

STRIP CHART 111-4

IC-10-DPT




Figure 4-8. TDR Trace of 118 VAC (H) to Shield

Section 5

INTERPRETATION OF MEASUREMENTS

This section presents a summary of the interpretation of the measurements taken on IC-10-dPT. This interpretation is intended to indicate the condition of the device based on observed data.

Since this device varies from -10 to +10 volts for a 0 to 200 GPM range, the observation of 0 flow readout indicates that the voltage should be -10 volts. The measured value of -10.8 volts is below this expected value, which could indicate a problem in the instrument or could be a slight offset problem at low flow rates (i.e., no flow). The 117 VAC value on the power supply line is also well within a normal operating range.

The time traces and frequency spectra do not indicate any serious contamination which would affect the DC readout. Table 5-1 lists the low level AC components present on the flow signal. Note that even though up to 50 mV P-P fluctuations are present, readout devices normally respond at low frequencies. As a result, the worst-case effect of these AC variations is likely to be less than the 0.5 mV RMS value given for the 60 Hz components.

One feature of the frequency spectrum of the flow signal gives an indication that the differential pressure LVDT (see Figure 2-2) is operating. Since the LVDT AC output is "demodulated" by a full-wave rectifier and Resistance-Capacitance (RC) smoothing, a low level ripple must be present at the frequency of the internal oscillator. The

Table 5-1

MAJOR AC COMPONENTS ON THE FLOW SIGNAL

Frequency	Amplitude
60 Hz and harmonics	0.5 mV RMS
1 kHz and harmonics	4 mV RMS
96 kHz	1 mV RMS
200 kHz (broadband)	<1 mV RMS
Total Spectrum	50 mV P-P

oscillator for this type device operates at approximately 1000 hertz and the component values of the RC smoothing circuit ($R = 100k$ ohms, $C = 0.68 \mu F$) would produce a ripple factor (fraction of AC RMS fluctuations) of 0.001. This would indicate that the expected ripple would be in the millivolt range. From Table 5-1, this AC ripple value was measured to be 4 mV, which is reasonable.. Also, the reduction in amplitude of the higher harmonics (see Figure 4-4) is consistent with the expected attenuation of a rectified signal.

The capacitance, impedance, and resistance data given in Table 4-1 is difficult to quantitatively interpret, but qualitative results are possible. Most of the data indicates very low effective capacitance values, which would be expected from the amplifier section of the transmitter. However, the 118 VAC (H) to 118 VAC (L) measurement passes through the primary of a transformer. This creates an inductance which appears as negative capacitance at the 100 hertz measurement.

The presence of a 10,000 ohm resistor in the transmitter amplifier and the absence of other direct electrical paths indicates that a resistance measurement near this value should be obtained. The measured values for the flow signal were 6700 and 8100 ohms for two polarities. The variation would be caused by active electrical components, and the values are of the magnitudes expected. Since the expected responses are present, there is no obvious indication of instrumentation degradation from these measurements.

The results of TDR measurements performed on the cable (shown in Figures 4-5 to 4-7) are summarized in Table 5-2. Note that the lengths identified in the table are only approximate, since no calibration of the cable resistance and material composition was performed on the TDR instrument. Some junction points were not identified by these measurements, but no indication of cabling problems is present in this data.

Table 5-2

SUMMARY OF TDR MEASUREMENTS

Signal Lines	Distance (ft)	Description**	Probable Cause
+Signal	232	Point R increase	Penetration R607
-Signal	489	Point R small decrease	Terminal block
	579	Large R increase	Electronics
+Signal	221	Point R increase	Penetration R607
Shield	479	Point R small increase	Terminal block
	574	Large R increase	Electronics
118 VAC (H)	274	Point R increase	Penetration R506
118 VAC (L)	579	Large R increase	Electronics

Note: Distances are not calibrated due to lack of prior information on the cable type which prevented calibration tests.

* TDR to terminal block test cable (15 ft) not included in distance.

** R is the abbreviation for resistance.

Section 6

CONCLUSIONS

Based on the measurements, data reduction, and circuit analysis of IC-10-dPT, there is no indication of degradation of the instrument. The only significant contamination present in the pressure signal that appeared to be abnormal was the 96 kHz component. However, the amplitude of this signal was relatively low and, from other measurements performed at TMI, this low-level 96 kHz component is probably due to a widespread 16 kHz (with harmonics) signal found in various circuits. In addition to the observation of no abnormal characteristics of the instrument, the low level oscillator ripple on the level signal indicates that the LVDT is working. Therefore, it appears that IC-10-dPT is operating correctly, but these measurements could not determine whether the instrument is calibrated.

APPENDIX

ORIGINAL FIELD PROCEDURES AND
DATA SHEETS FOR IC-10-dPT

UNIT 2

COMPONENT DESIGNATION										LOCATION/UNIT		JOB TYPE		RECEIVED DATE		RECOMMENDED PRIORITY	
SYS	COMP TYPE	COMP ID	GROUP									MO	DAY	HR			
IC	DPT	GOIC		0	3	6	0	0	2	C	M				0	9	2

DESCRIBE
MALFUNCTION
OR
MODIFICATION
DESIRED

CAUSE OF
MALFUNCTION
(IF KNOWN)

ORIGINATOR'S EMP NO.	<i>[Signature]</i>	<i>9/27/80</i>	SUPERVISOR'S EMP NO.	<i>[Signature]</i>	<i>9/27/80</i>
06175	ORIGINATOR'S SIGNATURE	DATE	06175	SUPERVISOR'S SIGNATURE	DATE

DOE/EGSG Project

WORK ORDER NUMBER						JC CODE		ACCOUNT NUMBER								PLANT CONDITION								WPRO FAILURE				START						
LOCATION				SERIAL				X-001								SU	OP	MD	CD	RF		WS	LR					YR	MO	CAY	HR	MIN		
0	3	6	0	0	0	1	8	7	G	A			7	E	7	4	a	i	s															
CHRG MOD NO.		#	A	NO	NO	REG AGENCY CODE		CHG/MOD NUMBER		ENV CODE		OUTAGE CAUSE CODE		STATUS HOLD CODE																				
											X																							
D	C	O	C																															

[illegible]

P R C 2	RESP LOCATION OR CONTRACTOR
	20364

Location Cable Room, elev 305', Control Building

Comply with the
set forth in 17.10

Limits and Precautions:

Met Ed Safety Manual

a) Personnel

b) Equipment

c) Environment

d) Nuclear

ASSURE WORK AREA CLEANED

Post Maintenance Testing required and Acceptance Criteria. UP AT COMPLETION OF JOE

ANNEX 1 - INTERVIEW - SUPERVISOR OF MAINTENANCE - MAINTENANCE FOREMAN

COPY 1

JOB TICKET (WORK REQUEST)
REVIEW — CLASSIFIED **IG CONTROL FORM**
Page A-2

JOB TICKET NUMBER 0572

1. Does work represent a change or modification to an existing system or component? If yes, an approved change modification is required per AP 1021.

C/M No. 112 Yes _____ No ✓

- 2a. Does work requires an RWP?

Yes _____ No ✓

- 2b. Is an approved procedure required to minimize personnel exposure?

Yes _____ No ✓

- 3a. Is work on a QC component as defined in GP 1008?

Yes _____ No ✓

- 3b. If 3a is yes does work have an effect on Nuclear Safety? If 3b is yes, PORC reviewed Superintendent approved procedure must be used.

Yes _____ No ✓

4. Agreement that a PORC reviewed, Superintendent approved procedure is not required for this work because it has no effect on nuclear safety. (Applies only if 3a is Yes and 3b is No).

NA _____
SUPERINTENDENT DATE

- 5a. Is the system on the Environmental Impact list in AP 1026?

Yes _____ No ✓

- 5b. If 5a is YES, is an approved procedure required to limit environmental impact?

Yes _____ No ✓

6. Agreement that 5b is No (Required only if 5a is Yes).

NA _____
UNIT SUPT. SUPV. OF OPERATIONS DATE

7. Plant status or preferred site conditions required for work. (Operating and/or shutdown)

8. QC Dept. review, if required in item No. 3

NA _____
QC SUPERVISOR DATE

9. Does work require code inspector to be notified?

Yes _____ No ✓

10. Supervisor of Maintenance approval to commence work:


[Signature] _____ Date 9/22/80

11. Maintenance Foreman Assigned: _____

12. Code Inspector Notified. Name: _____ Date _____

13. Shift Foreman's approval to commence work: [Signature] _____ Date 9/23/80

_____ Initial if Shift Foreman signature is not required.

 Technology for Energy Corporation	TITLE IN-SITU MEASUREMENTS OF CABLES AND SIGNALS FROM DIFFERENTIAL PRESSURE TRANSDUCER IC-10-DPT (CONTROL ROD DRIVE HDR BYPASS FLOW) TRANSMITTER	NO. TP-111
	Page A-3 APPROVED	REV. 0
PROCEDURE	M.V. Mathis, Director, Tech. Serv. Div.	DATE 9-15-80

PURPOSE: The purpose of these measurements is to gather baseline data and information in preparation for removal of the Differential Pressure Transducer IC-10-DPT from the Reactor Building TMI Unit 2. The tests specified in this procedure are designed to assess the condition of the in-containment instrumentation, associated cabling, and readout devices. This assessment will require the use of Time Domain Reflectometry (TDR), Impedance (Z), Spectral Analysis (frequency domain), and general oscilloscope observations (with recording) of waveforms from/to the unit under test (UUT).

PROCEDURE (ADMINISTRATIVE):

A. Limitations and Precautions

1. Nuclear Safety. The unit is not considered part of the engineered reactor safeguards system and thus is not nuclear safety-related.
2. Environmental Safety. ~~Source Range Detector Preamplifier HI AMP-2~~ ^{CONTROL ROD DRIVE HDR BYPASS FLOW TRANSMITTER IC-10-DPT} can be taken out-of and restored to services without producing a hazard to the environment.
3. Personnel Safety. The test described herein produces no additional personnel safety hazards other than normally associated with performing instrument testing.
4. Equipment Protection. In the performance of each test described herein, care will be taken to insure adequate equipment protection as follows:
 - a. In all cases actual test hookups to the Unit-2 instrumentation shall be made and verified by Instrumentation Personnel.
 - b. All passive measurements (Spectral Analysis and Oscilloscope observations) of waveforms and signals from powered instruments shall be performed using high input impedance probes or inputs ($Z \geq 1$ Meg ohm) to prevent loading of signals.
 - c. In all Time Domain Reflectometry and Impedance measurements, power will be removed from the unit under test and low level test signals prescribed in Table 4-1 shall be utilized to perform cable integrity measurements on the appropriate instrumentation cables by inserting test signals on appropriate conductors of Cables

WORK REQUEST PROCEDURE
Maintenance Page A-4 ion
t and Approval

Unit No. 2

This form outlines the format and acts as a cover sheet for a maintenance procedure. Due to the limited size of the form, additional pages may be attached as required. Work Request procedure AP 1016 Section 6 should be used as a guide in preparing the maintenance procedure.

1. Procedure Title & No.:

Sensor/Cable measurements for Control Rod Drive Bypass Flow

2. Purpose: *To determine signal characteristics of sensor/cable.*

3. Description of system or component to be worked on.

IC-10-DPT

4. References:

See attached

5. Special Tools, and Materials required.

See attached

6. Detailed Procedure (attach additional pages as required)

See attached

Supervisor of Maintenance recommends approval

[Signature] Date 9/22/90

• PORC RECOMMENDS APPROVAL

Engineering Review

[Signature] Date 9/22/90

Unit No. 1 Chairman _____ Date _____ Unit No. 2 Chairman _____ Date _____

• UNIT SUPERINTENDENT APPROVAL

Unit No. 1 _____ Date _____ Unit No. 2 _____ Date _____

• Standing Procedure _____
Supervisor of OC _____ Date _____

*Note These approvals required only on Nuclear Safety Related/Radiation work permit jobs.

TEC

TITLE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10.00T

INC.

TP-111

REV.

0

Page A-5

IT2754C and IT2825I (terminations shall be removed and replaced on TB 9-2-5 of Cabinet 157).

Table 4-1 Active Measurements

Active Signal Parameter	Time Domain Reflectometry	Impedance
Voltage	225 mV nominal (into 50 ohm base)	$\leq 5V$ rms
Frequency	---	100Hz, 1kHz, 10kHz, 100kHz
Current	$\leq 10mA$	$\leq 100mA$
Other	225mV, 110 picosecond pulses	---


B. Prerequisites

1. The Shift Supervisor/Shift Foreman shall be notified for concurrence prior to the performance of those measurements.
2. Instrumentation personnel shall be assigned to assist in the performance of these measurements.
3. All measurements and test instrumentation shall be in current calibration (traceable to NBS).
4. The Shift Supervisor/Shift Foreman shall be notified prior to starting and upon completion of the measurements.

C. Procedure for Performing Measurements

References:

1. Instruction Manual for Bailey Differential Pressure Transducer, BY&230X-A.
2. Burns & Roe Dwg. 3045, Sh. 346.

	TITLE IN-SITU MEASUREMENTS OF CABLES AND SIGNALS FROM DIFFERENTIAL PRESSURE TRANSDUCER IC-10-DPT	NC. TP-111
		REV. 0

Page A-6

3. Burns & Roe Dwg. 3305, Sh. 7.
4. Burns & Roe Dwg. 3024, Sh. 54.
5. Burns & Roe Dwg. 3045, Sh. 26F.
6. Burns & Roe Dwg. 3045, Sh. 36h.
7. Instruction Manual, Tektronix Model 1502 Time Domain Reflectometer.
8. Instruction Manual, Hewlett Packard Model 4274 Multifrequency LCR Meter.
9. Instruction Manual, Hewlett Packard Spectrum Analyzer (Model 141T, 8553B, 8552B Modules).
10. Instruction Manual, Nicolet Model 444A-26 Spectrum Analyzer.
11. Instruction Manual, Tektronix Model 335 Oscilloscope.
12. Instruction Manual, Lockheed Store-4 Recorder.
13. Instruction Manual, Tektronix SC502 Oscilloscope.
14. TEC Composite Electrical Connection Diagram, IC-10-DPT (see attachment).

SIGNAL	CABLE	CABINET 157
118 VAC (H)	IT2754C	TB 9-2-5/6
118 VAC (L)	IT2754C	TB 9-2-5/7
- Signal	³ IT282 5 I	TB 9-2-5/8
+ Signal	³ IT282 5 I	TB 9-2-5/9
Shield	³ IT282 5 I	TB 9-2-5/10

1. Notify Shift Supervisor/Shift Foreman of start of test on IC-10-DPT.
2. Verify power is applied to IC-10-DPT.
3. Record present reading from IC-10-DPT.

Signature/Date

TE

TE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NO. TP-111

REV. 0

Page A-7

SIGNAL	READING IN INCHES
IC-10-DPT Readout	\emptyset FLOW

SYSTEM SHUT DOWN

- Connect Isolation Amplifier (TEC Model 901) to TB 9-2-5/829 (Signal) in Cabinet 157 and record signal for 30 minutes. Remove recorder and amplifier when complete.
- Using a Keithley Model 177 DMM (or equivalent, Range 0-2000 V, Precision $\pm 1\%$) measure the Voltage or current at the following test points.

SIGNAL	CABINET 157	TEST LEAD	READING
a.	TB 9-2-5/9 TB 9-2-5/8	(+) (-)	Signal <u>-10.86</u> (VDC)
*b.	TB 9-2-5/6 TB 9-2-5/7	(+) (-)	118 VAC <u>116.6</u> VAC

*CAUTION: 118 VDC

Q. T. S. H.
Signature/Date

- Using a Tektronix Model SC502 (or equivalent) oscilloscope observe the waveform at the following test point:

TEC

TITLE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS FROM DIFFERENTIAL PRESSURE TRANSDUCER IC-10-DPT

NC. TP-111

REV. 0

Page A-8

SIGNAL	CABINET 157	PARAMETER			
a.	TB 9-2-5/9 TB 9-2-5/8	SIGNAL	Photo <u>111-1</u> Time Base <u>50ms</u> Vert Gain <u>10mV</u>	Photo <u>111-2</u> Time Base <u>5ms</u> Vert Gain <u>10mV</u>	Photo <u>111-3</u> Time Base <u>5ms</u> Vert Gain <u>10mV</u>
*b.	TB 9-2-5/6 TB 9-2-5/7	118 VAC	Photo <u>111-4</u> Time Base <u>5ms</u> Vert Gain <u>5V</u>	Photo _____ Time Base _____ Vert Gain _____	Photo _____ Time Base _____ Vert Gain _____

*CAUTION 118 VAC at TB 9-2-5/6 & 7; use X10 probe.

Sync the oscilloscope and photograph the waveform using up to three time base and vertical gain settings. Mark the back of the photographs with the instrument tag number and parameter measured.

J. T. Smith 9/23/80
Signature/Date

- Using a Hewlett-Packard Spectrum Analyzer (Models 141T, 85538 and 8552 or equivalent) perform an analysis of the following signal for spectral content:

SIGNAL	CABINET 157	PARAMETER	PHOTO #
*a.	TB 9-2-5/9 TB 9-2-5/8	SIGNAL	<u>111-5</u> <u>111-6</u>

*CAUTION 118 VAC at TB 9-2-5/6&7.

Before photographing each scope display, adjust analyzer for best spectral resolution. Record critical analyzer parameters e.g., RF bandwidth, RF bandwidth and sweep speed on rear of photograph as well as parameter analyzed.

TEC

TEC

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NO. TP-111

REV. 0

Page A-9

<u>SPECTRUM IDENT</u>	<u>FREQUENCY</u>	<u>AMPLITUDE</u>	<u>REMARKS</u>
<u>BANDWIDTH</u>	<u>SCAN WIDTH</u>	<u>INPUT ATTN</u>	<u>SCAN TIME</u>
3 KHz	1 MEG Hz / 1011	0	1 SEC
			LOG Ref 10 db LOG
			-20 db
			SENS
			0
			111-5
11	C-2 MEG Hz / 1011		11
			11
			11
			111-6

Q-TS 9/23/80
Signature/Date

8. Using the Nicolet Model 444 FFT Analyzer (or equivalent) perform FFT annalysis of signals for the following test point:

<u>SIGNAL</u>	<u>CABINET 157</u>	<u>PARAMETER</u>	<u>PHOTO #</u>
*a.	TB 9-2-5/9 TB 9-2-5/8	SIGNAL	111-7 111-8

100K RANGE

*CAUTION 118 VAC at TB 9-2-5/6&7.

Q-TS 9/23/80
Signature/Date

TEI

III-E

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NO. TP-111

REV. 0

Page A-10

9. Inside Cabinet 157 perform usual electronic calibrations using applicable instrument shop procedures. Attach instrument shop calibration data sheet and record any significant adjustments or problems in the space below.

Procedure Step	Remarks
See attached instrument shop procedure data sheet.	

Instrument Shop Procedure No. _____

Signature/Date

10. Remove all power from IC-10-DPT.

Q. TSK 9/23/80

Signature/Date

11. Open links for field wires from Cables IT2754C* and IT2825I at TB 9-2-5/6, 7, 8, 9, and 10 (Cabinet 157).

*CAUTION: 118 VAC Power Supply Cable (TB 9-2-5/6&7).

TEC

TITLE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NO. TP-111

REV. 0

Page A-11

<u>TERMINAL</u>	<u>SIGNAL IDENT.</u>
TB 9-2-5/6	118 VAC (H)
TB 9-2-5/7	118 VAC (L)
TB 9-2-5/8	- Signal
TB 9-2-5/9	+ Signal
TB 9-2-5/10	Shield

Signature/Date

12. Using the Hewlett-Packard Model 4274 (or equivalent) Impedance Bridge, measure the capacitance and impedance at the following test points:

TEST POINT	FROM	TO
a.	TB 9-2-5/9 (+ Signal)	TB 9-2-5/8 (- Signal)
b.	TB 9-2-5/9 (+ Signal)	TB 9-2-5/10 (Shield)
c.	TB 9-2-5/8 (- Signal)	TB 9-2-5/10 (Shield)
d.	TB 9-2-5/6 (118 VAC H)	TB 9-2-5/7 (118 VAC L)
e.	TB 9-2-5/6 (118 VAC H)	TB 9-2-5/9 (+ Signal)
f.	TB 9-2-5/6 (118 VAC H)	TB 9-2-5/8 (- Signal)
g.	TB 9-2-5/6 (118 VAC H)	TB 9-2-5/10 (Shield)

TEC

TITLE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-NPT

NO. TP-111

REV. 0

Page A-12

Record the data required below:

Test Point	Capacitance			Impedance		
Frequency	100 Hz	1 kHz	100 kHz	100 Hz	1 kHz	100 kHz
a. TB 9-2-5/9:8	22.3 nF	19.8 nF	14.9 nF	4.3 K \angle -34 $^{\circ}$	3.3 K \angle -21 $^{\circ}$	104 \angle -78 $^{\circ}$
b. TB 9-2-5/9:10	59 nF	47 nF	40.8 nF	27 K \angle -86 $^{\circ}$	3.3 K \angle -75 $^{\circ}$	40 \angle -76 $^{\circ}$
c. TB 9-2-5/8:10	59 nF	48 nF	43 nF	27 K \angle -86 $^{\circ}$	3.2 K \angle -76 $^{\circ}$	37.7 \angle -75 $^{\circ}$
d. TB 9-2-5/6:7	10 nF 130 nF	17 nF	25 nF	12 K \angle -55 $^{\circ}$	9.1 K \angle -80 $^{\circ}$	65 \angle -79 $^{\circ}$
e. TB 9-2-5/6:9	0.9 nF	0.59 nF	0.24 nF	OF	OF	359 \angle -147 $^{\circ}$
f. TB 9-2-5/6:8	0.9 nF	0.59 nF	0.25 nF	OF	OF	353 \angle -148 $^{\circ}$
g. TB 9-2-5/6:10	0.9 nF	0.63 nF	0.29 nF	OF	OF	171 \angle -161 $^{\circ}$

Put 15 ft of COAXIAL CABLE RG/58 IN SERIES FOR
ABOVE MEASUREMENT

J. T. S. A.
Signature/Date

13. Using the Tektronix Model 1502 (or equivalent) TDR unit perform TDR measurements on three test points.

TEL

TITLE

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NO. TP-111

REV. 0

Page A-13

Record data below:

Test Point	Instrument Settings	Strip Chart Number
	Ampl Range Mult	
a. TB 9-2-5/9:8 (+ Signal)		111-1
b. TB 9-2-5/9:10 (+ Signal: SHLD)		111-2
c. TB 9-2-5/6:7 (118 VAC)		111-3
d. TB 9-2-5/6:10 (118 VAC: SHLD)		111-4

J. T. Sullivan 9/23/80
Signature/Date

14. Using the Keithley Model 144 (or equivalent DMM) perform resistance measurements on the test points specified and record values in the space provided.

			POLARITY From = -; To = -	POLARITY From = -; To = +
TEST POINT	FROM LINK	TP LINK	RESISTANCE	RESISTANCE
a.	TB 9-2-5/9	TB 9-2-5/8	6.7KΩ	8.1KΩ
b.	TB 9-2-5/9	TB 9-2-5/10	OPEN	OPEN
c.	TB 9-2-5/8	TB 9-2-5/10	OPEN	OPEN
d.	TB 9-2-5/6	TB 9-2-5/7	98.9Ω	98.9Ω
e.	TB 9-2-5/6	TB 9-2-5/9	OPEN	OPEN
f.	TB 9-2-5/6	TB 9-2-5/8	OPEN	OPEN
g.	TB 9-2-5/6	TB 9-2-5/10	OPEN	OPEN

20K RANGE

J. T. Sullivan 9/23/80
Signature/Date

IN-SITU MEASUREMENTS OF CABLES AND SIGNALS
FROM DIFFERENTIAL PRESSURE TRANSDUCER
IC-10-DPT

NC.

TP-111

REV. 0

Page A-14

15. Connect field wires from Cables IT2754C* and IT2825I at TB 9-2-5/6, 7, 8, 9, and 10 (Cabinet 157) and restore power to IC-10-DPT.

16. Notify the Shift Supervisor/Shift Foreman of the conclusion of testing ^{IC-10-DPT.} ~~NI-AMP-2.~~

I hereby certify that this Test Procedure has been completed as written and that all data has been correctly entered and filed as requested.

TEC Representative

Q. T. S. A. 9/25/80
Signature/Date

Instrumentation

John P. Grooms 9/23/80
Signature/Date

CM STATUS ACTIVITY FORM

Page A-15

COMPONENT DESIGNATOR																LOCATION UNIT				JOB TYPE	WORK AUTHORIZATION NUMBER				REQUEST DATE			
SYS	COMP TYPE				COMP ID.	LOOP											MO	DAY	YR									
5	8	12				16	17	22				23	24	28				32	33	38								
7	0							0	3	6	0	0	2	C	M	/	/	C	5	7	1	2	0	9	2	0	8	0

TXN CD			AC T 4
8	0	4	A

TXN			A
CO			C
1			T
			J
8	0	5	A

TXN CD			ACT
1			4
8	0	7	A

TXN			ACT
1			4
8	1	0	A

ECM NUMBER				
47				51

P R T Y	RESP LOCATION OR CONTRACTOR	P R T Y	ASSISTING CONTRACTOR	P R T Y	ASSISTING CONTRACTOR
55	67	71			
6	0	3	6	7	1

PURCHASE REQUISITION NUMBER					PURCHASE ORDER NUMBER				
59					6667				

STATUS HOLD								% COMPL	S/M APPROVAL TO COMMENCE WORK			FIELD WORK COMPLETION DATE				
CODE		START DATE		RELEASE DATE					MO	DAY	YR	MO	DAY	YR		
39	40	41			45	47		52	53	55	56		61	62		67

OUTAGE HOLD

PART HOLD

QUALITY CONTROL PART HOLD

QUALITY CONTROL PROCEDURE HOLD

OPERATIONS HOLD

CHANGE MODIFICATION HOLD

ENGINEERING HOLD

PLANNING HOLD

MANPOWER NOT AVAILABLE

AT PORC

AT QUALITY CONTROL

AT UNIT SUPERINTENDENT

AT READING

POST MAINTENANCE TEST HOLD

AT ALAR