

# Nuclear Data Target Requirements for MA Burners

2011 ANS Annual Meeting

G. Palmiotti  
M. Salvatores

June 2011

The INL is a  
U.S. Department of Energy  
National Laboratory  
operated by  
Battelle Energy Alliance



This is a preprint of a paper intended for publication in a journal or proceedings. Since changes may be made before publication, this preprint should not be cited or reproduced without permission of the author. This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights. The views expressed in this paper are not necessarily those of the United States Government or the sponsoring agency.

## Nuclear Data Target Accuracy Requirements for MA Burners, invited

G. Palmiotti, M. Salvatores<sup>1,2</sup>

1-Idaho National Laboratory, 2525 Fremont Ave. P.O. Box 1625, Idaho Falls, ID 83415-3855  
(USA, [Giuseppe.Palmiotti@inl.gov](mailto:Giuseppe.Palmiotti@inl.gov))

2- CEA-Cadarache

### I. Nuclear Data Target Accuracy Assessment

Innovative fuel cycles, in particular those that require the introduction of TRU burners, present several potential feasibility issues, in particular in the field of the development of new fuels with a high MA content. Their definition, fabrication, performance under irradiation and reprocessing are crucial issues still under investigation. In this context, neutronics issues could seem to be of a lesser importance. However, key feasibility issues can arise in terms of nuclear data uncertainty impact, since safety and operation constraints can jeopardize specific fuel choices (e.g. maximum MA content) of potential interest.

Nuclear data requirements for innovative systems have been initially assessed, using sensitivity and uncertainty analysis and preliminary covariance data. Previous work was performed and preliminary indications were obtained [1]. The availability of more realistic uncertainty data allows a better target accuracy assessment. The present work improves previous evaluations in two respects: the method used is a more general one since it accounts for energy correlations in the definition of target accuracies [2] and it is based on a very recent release of new covariance data The AFCI 2.0 [3].

The present analysis is related to two typical TRU burner systems [1]. The first system, called SFR, is a Na-cooled, metal fuelled fast reactor loaded with TRU fuel of a composition as discharged by standard PWRs (i.e. Pu/MA ratio ~10). This is the typical composition of a TRU burner reactor when all TRUs are considered a potential waste.

The second system, called ADMAB, is a Pb-cooled nitride fuelled fast spectrum ADS; the fuel composition has a Pu/MA ratio close to one. This is a typical MA burner in a so-called double strata fuel cycle strategy where most of the Pu is considered a resource and recycled in LWRs (or FRs) and MA are loaded in the burner ADS together with some Pu that is needed to create a fuel such that the reactivity loss during the cycle stays approximately close to zero (and consequently, the accelerator proton current stays ~constant).

In Table I the uncertainty on  $k_{\text{eff}}$  of both SFR and ADMAB systems are shown together with the major

components (i.e. isotope, reaction) of the overall uncertainty. These uncertainties are much higher than the expected design requirement ( $\pm 0.3\% \Delta k/k$ ). For both systems the uncertainties have a significant impact. As an example to account for the present uncertainty on the  $k_{\text{eff}}$  for the sub-critical system ADMAB ( $\sim \pm 1.7\% \Delta k/k$ ), it would be needed to increase the nominal design value of the sub-criticality level, with a significant penalty on the proton beam power requirements.

In order to meet the design requirement, the required cross section target accuracies obtained with the method of Reference 2, are given in tables II and III. A 7 group energy structure has been used with the following upper energy in eV:  $1.96 \times 10^7$ ,  $2.23 \times 10^6$ ,  $4.98 \times 10^5$ ,  $6.74 \times 10^4$ ,  $2.03 \times 10^3$ ,  $1.49 \times 10^2$ , and  $5.40 \times 10^{-1}$ . The requirements are shown according (rank) to their overall original contribution to the total uncertainty on  $k_{\text{eff}}$ .

### II. Fuel Cycle Nuclear Data Uncertainty Impact

As for integral parameters more related to the fuel cycle (as decay heat, neutron sources at fuel fabrication or radiotoxicity in a geological disposal), their uncertainty is due to both the out-of-pile decay (and related decay constants uncertainties) and to the uncertainty of the isotope composition at the end of the in-pile irradiation. Since uncertainties on decay constants are relatively small, the major effect can be associated to the isotope composition uncertainty at the end of irradiation ( $N_F$ ):

$$\delta N_F / N_F = \delta (N_0 + \Delta N) / N_F = \delta (\Delta N) / N_F = (\delta (\Delta N) / \Delta N) \times \Delta N / N_F$$

where  $\Delta N = N_F - N_0$  is the difference between the final and initial densities of any isotope.

For example in the case of decay heat of fuels with a high content of MA, the major contribution to decay heat is due to Pu-238, Am-241 and Cm-244 (see e.g. References 1 and 4).

Preliminary calculations indicate that cross section uncertainties, both for the SFR and ADMAB systems, will increase the overall uncertainties on the  $N_F$  values of those isotopes of less than 5%. Consequently, rather acceptable (at least in initial design phases) uncertainties

are expected on integral parameters as decay heat, neutron sources at fuel fabrication or radiotoxicity in a geological disposal.

### III. Conclusions

Recent and improved evaluations of nuclear data uncertainties indicate a potential significant impact on the nominal performances of MA burner reactors. In particular, the uncertainty on the subcritical level can have an impact on the safety assessment of any type of subcritical source driven system, possibly resulting in the requirement to add control rods (up to now not foreseen in any conceptual designs) to the system. Fuel cycle related parameters are less affected by uncertainties. This preliminary indication should be carefully verified, in view of the very important feasibility issues related to advanced fuel cycles that make use of MA or TRU burner reactors as indicated in Reference 4. This is the case of decay heat of discharged fuel elements or targets, that can require long cooling times with potential impact on the reactor availability and, consequently, on the transmutation effectiveness. In that respect an uncertainty of 20% or more on that quantity, can induce significant penalties on the performance of the fuel handling design.

### ACKNOWLEDGMENTS

Work supported by the U.S. Department of Energy, Office of Nuclear Energy, under DOE Idaho Operations Office Contract DE-AC07-05ID14517.

### REFERENCES

1. M. Salvatores, "Nuclear Data for Advanced Fuel Cycles", *Proc. 10<sup>th</sup> IEMPT Meeting, Mito, Japan, September 2008*
2. G. Palmiotti, M. Salvatores, M. Assawaroongruengchot, M. Herman, P. Oblozinsky, C. Mattoon, "Nuclear Data Target Accuracies for Generation-IV Systems Based on the Use of New Covariance Data," *Proc. Int. Conf. ND2010, International Conference on Nuclear Data for Science and Technology 2010, Jeju Island, South Korea, April 2010.*
3. M. Herman, S. Hoblit, BNL, private communication
4. M. Salvatores et al. "Fuel cycle analysis of TRU or MA burner fast reactors with variable conversion ratio using a new algorithm at equilibrium", *Nucl. Eng. and Design*, 239 (2009) 2160–2168

TABLE I. Major components of  $K_{\text{eff}}$  uncertainty, expressed in pcm, for the two transmuter systems.

| <b>SFR</b>     |                       |                        |            |                      |                        |              |
|----------------|-----------------------|------------------------|------------|----------------------|------------------------|--------------|
| <b>Isotope</b> | $\sigma_{\text{cap}}$ | $\sigma_{\text{fiss}}$ | $\nu$      | $\sigma_{\text{el}}$ | $\sigma_{\text{inel}}$ | <b>Total</b> |
| <b>PU240</b>   | <b>192</b>            | <b>258</b>             | <b>447</b> | <b>12</b>            | <b>129</b>             | <b>565</b>   |
| <b>FE56</b>    | <b>162</b>            | <b>0</b>               | <b>0</b>   | <b>401</b>           | <b>289</b>             | <b>521</b>   |
| <b>CM245</b>   | <b>7</b>              | <b>434</b>             | <b>48</b>  | <b>0</b>             | <b>3</b>               | <b>437</b>   |
| <b>CM244</b>   | <b>166</b>            | <b>142</b>             | <b>110</b> | <b>1</b>             | <b>8</b>               | <b>245</b>   |
| <b>U238</b>    | <b>44</b>             | <b>8</b>               | <b>32</b>  | <b>10</b>            | <b>233</b>             | <b>240</b>   |
| <b>PU242</b>   | <b>182</b>            | <b>98</b>              | <b>85</b>  | <b>6</b>             | <b>16</b>              | <b>224</b>   |
| <b>PU238</b>   | <b>76</b>             | <b>131</b>             | <b>158</b> | <b>2</b>             | <b>28</b>              | <b>221</b>   |
| <b>NA23</b>    | <b>29</b>             | <b>0</b>               | <b>0</b>   | <b>34</b>            | <b>166</b>             | <b>172</b>   |
| <b>PU241</b>   | <b>119</b>            | <b>43</b>              | <b>33</b>  | <b>2</b>             | <b>9</b>               | <b>131</b>   |
| <b>CM242</b>   | <b>12</b>             | <b>113</b>             | <b>14</b>  | <b>0</b>             | <b>3</b>               | <b>115</b>   |
| <b>Total</b>   | <b>382</b>            | <b>563</b>             | <b>498</b> | <b>403</b>           | <b>428</b>             | <b>1029</b>  |
| <b>ADMAB</b>   |                       |                        |            |                      |                        |              |
| <b>Isotope</b> | $\sigma_{\text{cap}}$ | $\sigma_{\text{fiss}}$ | $\nu$      | $\sigma_{\text{el}}$ | $\sigma_{\text{inel}}$ | <b>Total</b> |
| <b>AM241</b>   | <b>207</b>            | <b>125</b>             | <b>173</b> | <b>3</b>             | <b>119</b>             | <b>321</b>   |
| <b>PU241</b>   | <b>92</b>             | <b>41</b>              | <b>32</b>  | <b>0</b>             | <b>14</b>              | <b>106</b>   |
| <b>CM245</b>   | <b>12</b>             | <b>1040</b>            | <b>111</b> | <b>0</b>             | <b>10</b>              | <b>1046</b>  |
| <b>CM244</b>   | <b>555</b>            | <b>642</b>             | <b>505</b> | <b>1</b>             | <b>60</b>              | <b>989</b>   |
| <b>AM243</b>   | <b>316</b>            | <b>430</b>             | <b>93</b>  | <b>3</b>             | <b>267</b>             | <b>604</b>   |
| <b>NP237</b>   | <b>166</b>            | <b>162</b>             | <b>63</b>  | <b>2</b>             | <b>102</b>             | <b>261</b>   |
| <b>BI209</b>   | <b>54</b>             | <b>0</b>               | <b>0</b>   | <b>64</b>            | <b>180</b>             | <b>198</b>   |
| <b>PU240</b>   | <b>52</b>             | <b>91</b>              | <b>149</b> | <b>1</b>             | <b>73</b>              | <b>197</b>   |
| <b>N15</b>     | <b>3</b>              | <b>0</b>               | <b>0</b>   | <b>214</b>           | <b>12</b>              | <b>214</b>   |
| <b>PU239</b>   | <b>89</b>             | <b>122</b>             | <b>34</b>  | <b>2</b>             | <b>86</b>              | <b>177</b>   |
| <b>AM242M</b>  | <b>11</b>             | <b>133</b>             | <b>10</b>  | <b>0</b>             | <b>5</b>               | <b>134</b>   |
| <b>Total</b>   | <b>707</b>            | <b>1328</b>            | <b>578</b> | <b>223</b>           | <b>380</b>             | <b>1671</b>  |

TABLE II. Nuclear data target accuracy requirements (first 20 major contributors) on a total uncertainty of 300 pcm on  $K_{\text{eff}}$  for the SFR system

| Rank | Cross Sect.                                   | Energy Range (eV)                        | Current (%) | Required (%) |
|------|---|--|-------------|--------------|
| 1    | $^{56}\text{Fe}$ $\sigma^{\text{el}}$ Gr. 3   | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 12.0        | 1.6          |
| 2    | $^{240}\text{Pu}$ $\nu$ Gr. 2                 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 3.2         | 0.8          |
| 3    | $^{245}\text{Cm}$ $\sigma^{\text{fis}}$ Gr. 3 | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 47.0        | 3.1          |
| 4    | $^{56}\text{Fe}$ $\sigma^{\text{inel}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 11.4        | 1.8          |
| 5    | $^{240}\text{Pu}$ $\nu$ Gr. 3                 | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 4.8         | 1.3          |
| 6    | $^{245}\text{Cm}$ $\sigma^{\text{fis}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 47.3        | 4.4          |
| 7    | $^{238}\text{U}$ $\sigma^{\text{inel}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 17.0        | 2.7          |
| 8    | $^{240}\text{Pu}$ $\sigma^{\text{fis}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 2.5         | 1.1          |
| 9    | $^{56}\text{Fe}$ $\sigma^{\text{el}}$ Gr. 2   | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 6.3         | 2.0          |
| 10   | $^{240}\text{Pu}$ $\sigma^{\text{fis}}$ Gr. 3 | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 6.4         | 1.7          |
| 11   | $^{56}\text{Na}$ $\sigma^{\text{inel}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 15.0        | 2.7          |
| 12   | $^{240}\text{Pu}$ $\nu$ Gr. 1                 | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 2.5         | 1.4          |
| 13   | $^{245}\text{Cm}$ $\sigma^{\text{fis}}$ Gr. 4 | $6.74 \times 10^4$ to $2.03 \times 10^3$ | 16.1        | 3.7          |
| 14   | $^{238}\text{U}$ $\sigma^{\text{inel}}$ Gr. 1 | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 19.4        | 3.5          |
| 15   | $^{56}\text{Fe}$ $\sigma^{\text{cap}}$ Gr. 3  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 12.3        | 2.7          |
| 16   | $^{244}\text{Cm}$ $\sigma^{\text{cap}}$ Gr. 4 | $6.74 \times 10^4$ to $2.03 \times 10^3$ | 68.7        | 6.6          |
| 17   | $^{242}\text{Pu}$ $\sigma^{\text{cap}}$ Gr. 4 | $6.74 \times 10^4$ to $2.03 \times 10^3$ | 20.2        | 3.8          |
| 18   | $^{240}\text{Pu}$ $\sigma^{\text{cap}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 28.2        | 3.7          |
| 19   | $^{244}\text{Cm}$ $\sigma^{\text{fis}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 14.5        | 3.1          |
| 20   | $^{242}\text{Pu}$ $\sigma^{\text{cap}}$ Gr. 3 | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 28.2        | 4.5          |

TABLE III. Nuclear data target accuracy requirements (first 20 major contributors) on a total uncertainty of 300 pcm on  $K_{\text{eff}}$  for the ADMAB system

| Rank | Cross Sect.                                   | Energy Range (eV)                        | Current (%) | Required (%) |
|------|---|--|-------------|--------------|
| 1    | $^{245}\text{Cm } \sigma^{\text{fis}}$ Gr. 3  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 47.0        | 1.4          |
| 2    | $^{244}\text{Cm } \sigma^{\text{fis}}$ Gr. 2  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 14.3        | 1.0          |
| 3    | $^{245}\text{Cm } \sigma^{\text{fis}}$ Gr. 2  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 47.5        | 2.0          |
| 4    | $^{244}\text{Cm } \nu$ Gr. 2                  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 8.7         | 0.9          |
| 5    | $^{244}\text{Cm } \sigma^{\text{cap}}$ Gr. 4  | $6.74 \times 10^4$ to $2.03 \times 10^3$ | 64.4        | 2.5          |
| 6    | $^{243}\text{Am } \sigma^{\text{fis}}$ Gr. 2  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 8.8         | 1.0          |
| 7    | $^{245}\text{Cm } \sigma^{\text{fis}}$ Gr. 4  | $6.74 \times 10^4$ to $2.03 \times 10^3$ | 14.7        | 1.5          |
| 8    | $^{244}\text{Cm } \sigma^{\text{cap}}$ Gr. 3  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 48.6        | 2.6          |
| 9    | $^{244}\text{Cm } \sigma^{\text{fis}}$ Gr. 1  | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 19.7        | 1.7          |
| 10   | $^{243}\text{Am } \sigma^{\text{inel}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 21.6        | 1.9          |
| 11   | $^{243}\text{Am } \sigma^{\text{cap}}$ Gr. 2  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 6.8         | 1.1          |
| 12   | $^{243}\text{Am } \sigma^{\text{fis}}$ Gr. 1  | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 12.1        | 1.6          |
| 13   | $^{243}\text{Am } \sigma^{\text{cap}}$ Gr. 3  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 8.2         | 1.3          |
| 14   | $^{244}\text{Cm } \sigma^{\text{cap}}$ Gr. 2  | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 77.9        | 4.2          |
| 15   | $^{244}\text{Cm } \nu$ Gr. 1                  | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 10.1        | 1.7          |
| 16   | $^{244}\text{Cm } \sigma^{\text{fis}}$ Gr. 3  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 10.0        | 1.9          |
| 17   | $^{209}\text{Bi } \sigma^{\text{inel}}$ Gr. 2 | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 14.0        | 1.9          |
| 18   | $^{15}\text{N } \sigma^{\text{elas}}$ Gr. 2   | $2.23 \times 10^6$ to $4.98 \times 10^5$ | 2.9         | 0.9          |
| 19   | $^{245}\text{Cm } \sigma^{\text{fis}}$ Gr. 1  | $1.96 \times 10^7$ to $2.23 \times 10^6$ | 38.0        | 4.0          |
| 20   | $^{244}\text{Cm } \nu$ Gr. 3                  | $4.98 \times 10^5$ to $6.74 \times 10^4$ | 10.0        | 1.9          |