DOE-NE Light Water Reactor Sustainability Program and EPRI Long-Term Operations Program – Joint Research and Development Plan

April 2014



DISCLAIMER

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, do not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

DOE-NE Light Water Reactor Sustainability Program and EPRI Long-Term Operations Program – Joint Research and Development Plan

April 2014

Idaho National Laboratory Idaho Falls, Idaho 83415

http://www.inl.gov

Prepared for the
U.S. Department of Energy
Office of Nuclear Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517

DOE-NE Light Water Reactor Sustainability Program and EPRI Long-Term Operations Program – Joint Research and Development Plan

Revision 3

April 2014

Approved by	
Kathryn McCarthy, FJ.D.	4-30-14
Kathryn McCarthy, PJ.D. Light Water Reactor Sustainability Technical Integration Office Director, INL	Date
Richla. Reit	4/30/14
Richard Reister Light Water Reactor Sustainability Federal Program Director, DOE-NE	Date
Sherry Bernhoft Sherry Bernhoft Manager FPRI	4/30/14
Sherry Bernhoft	Date
Mong-Term Operations Program Manager FPRI	

SUMMARY

Nuclear power has safely, reliably, and economically contributed almost 20% of the total amount of electricity generated in the United States over the past two decades. High capacity factors and low operating costs make nuclear power plants some of the most economical power generators available. Further, nuclear power remains the single largest contributor (more than 60%) of non-greenhouse-gas-emitting electric power generation in the United States. Even when major refurbishments are performed to extend operating life, these plants continue to represent cost-effective, low-carbon assets to the nation's electrical generation capability.

At present, nearly three-quarters of the nuclear power plants in the United States have received a renewed operating license from the U.S. Nuclear Regulatory Commission (NRC), permitting those plants to operate up to 60 years. By the end of 2014, about one-third of the existing domestic fleet will have passed their 40th anniversary of power operations, and about one-half of the fleet will reach the same 40-year mark within this decade. A regulatory process exists (10 CFR Part 54) for obtaining approval from NRC on extended nuclear power plant operations beyond 60 years. However, the NRC will require nuclear power plants that choose to apply for a second renewal (termed "Subsequent License Renewal") of their operating license to demonstrate that adequate design and operational safety margins will be maintained over the duration of the extended operations period.

While recent, overall performance has been excellent (capacity factors approaching or exceeding 90%), the fleet is facing a number of technical challenges related to long-term operations. If current nuclear power plants do not operate beyond 60 years, the total fraction of domestic electrical energy generated from nuclear power will begin to decline—even with the expected addition of new nuclear generating capacity. Replacing these units will require long-lead planning periods (i.e., 10 to 15 years prior to unit retirement). In addition, significant capital investments (hundreds of billions of dollars) will be needed to design, construct, and commission the replacement generation capacity. Further, if the new capacity has to meet any carbon-neutral criteria (i.e., the replacement units must not produce more greenhouse gas emissions than the units being retired), the costs for replacement generation capacity will be even higher.

Recognizing the challenges associated with pursuing extended service life of commercial nuclear power plants, the U.S. Department of Energy's (DOE) Office of Nuclear Energy (NE) and the Electric Power Research Institute (EPRI) have established separate but complementary research and development (R&D) programs (DOE-NE's Light Water Reactor Sustainability [LWRS] Program and EPRI's Long-Term Operations [LTO] Program) to address these challenges. Over the past three years, the LWRS and LTO programs have cooperatively pursued extensive, long-term R&D activities related to the ability (from a materiel and economic perspective) of operating the existing fleet for periods up to 80 years and beyond. Contributions to date have advanced the state of knowledge on the measured and predicted performance of materials (e.g., metals, concrete, and cabling) used in plant systems, structures, and components;

improved analysis methods and tools for understanding safety margins; and advanced instrumentation, information and control technologies with no generic technical barriers identified that would make long-term plant operations infeasible. The R&D activities of both programs, including progress achieved and plans for continued work, are described herein.

To ensure that a proper linkage is maintained between the programs, DOE-NE and EPRI executed a memorandum of understanding in late 2010 to "establish guiding principles under which research activities (between LWRS and LTO) could be coordinated to the benefit of both parties." The memorandum of understanding calls for DOE-NE and EPRI to "provide and annually update a coordinated plan for the LWRS and LTO programs. The plan should provide for the integration of the separate LWRS and LTO Program Plans at the project level, showing project scope, schedule, budgets, and key interrelationships between the LWRS and LTO programs, including possible cost sharing." This document represents the third annual revision to the initial version (March 2011) of the plan as called for in the memorandum of understanding.

CONTENTS

SUM	MARY		iii
ACR	ONYMS		vii
1.	BACKO	GROUND	. 1
	1.1	U.S. Department of Energy Office of Nuclear Energy	1
	1.2	Electric Power Research Institute	. 1
	1.3	Research and Development Cooperation	. 1
2.	DESCR	LIPTION OF RESEARCH AND DEVELOPMENT PROGRAMS	3
	2.1	Department of Energy Office of Nuclear Energy Light Water Reactor Sustainability Program	3
	2.2	Electric Power Research Institute Long-Term Operations Program	. 4
	2.3	Reporting of Research and Development Projects	. 7
3.		WATER REACTOR SUSTAINABILITY/ LONG-TERM OPERATIONS DINATED RESEARCH AND DEVELOPMENT ACTIVITIES	. 1
4.		WATER REACTOR SUSTAINABILITY/LONG-TERM OPERATIONS ABORATIVE RESEARCH AND DEVELOPMENT ACTIVITIES	15
5.		WATER REACTOR SUSTAINABILITY/ LONG-TERM OPERATIONS PROGRAM- E RESEARCH AND DEVELOPMENT ACTIVITIES	40
Attac	hment A	- Long-Term Operations Issues Tracking Table	47
Appe	ndix A –	Industry Cost Sharing	71

ACRONYMS

AMP aging management program

ASR alkali silica reaction

BWR boiling water reactor

CASS cast austenitic stainless steel

DOE U.S. Department of Energy

EAF environmentally assisted fatigue

EMDA Expanded Materials Degradation Assessment

EPRI Electric Power Research Institute

IASCC irradiation-assisted stress corrosion cracking

I&C instrumentation and control

II&C instrumentation, information, and control

ILCM integrated life-cycle management

IMT issues management table

ITT issues tracking table

INL Idaho National Laboratory

LTO long-term operations

LWR light water reactor

LWRS light water reactor sustainability

MAaD materials aging and degradation

MDM Materials Degradation Matrix

MOOSE Multi-physics Object Oriented Simulation Environment

NDE nondestructive examination

NE Office of Nuclear Energy

NRC U.S. Nuclear Regulatory Commission

PWR pressurized water reactor

R&D research and development

RAVEN Reactor Analysis and Virtual Control Environment

RELAP Reactor Excursion and Leak Analysis Program

RIMM risk-informed margin management

RISMC risk-informed safety margin characterization

RPV reactor pressure vessel

SCC stress corrosion cracking

SLR subsequent license renewal

SSC systems, structures, and components

DOE-NE Light Water Reactor Sustainability Program and EPRI Long-Term Operations Program – Joint Research and Development Plan

1. BACKGROUND

1.1 U.S. Department of Energy Office of Nuclear Energy

The U.S. Department of Energy Office of Nuclear Energy (DOE-NE) conducts research and development (R&D) on nuclear energy to advance nuclear power as a resource capable of meeting the United States' energy, environmental, and energy security needs by resolving technical, cost, safety, proliferation resistance, and security barriers through research, development, and demonstration activities, as appropriate. R&D efforts under the Light Water Reactor Sustainability (LWRS) Program are managed by DOE-NE's Office of Light Water Reactor Technologies, NE-72, and the program Technical Integration Office, located at the Idaho National Laboratory (INL).

1.2 Electric Power Research Institute

The Electric Power Research Institute (EPRI) conducts R&D in the public's interest, mostly with funding provided by its membership and the electric utility industry, with respect to the production, transmission, distribution, and utilization of electric power, including research designed to improve the safety, reliability, and economy of nuclear power plants. R&D efforts in the Long-Term Operations (LTO) Program are managed as a separate technical program operating in the External Affairs Department of the EPRI Nuclear Power Sector, with the guidance of an industry advisory Integration Committee.

1.3 Research and Development Cooperation

The DOE-NE and EPRI R&D activities directed at providing the technical foundations for licensing and managing the long-term safe and economical operation of commercial nuclear power plants are described in the following documents:

- 1. The DOE-NE Light Water Reactor Sustainability Integrated Program Plan (April 2014)
- 2. The EPRI Long-Term Operations Program Plan (July 2013).

In late 2010, DOE-NE and EPRI executed a memorandum of understanding^a to "establish guiding principles under which research activities (between LWRS and LTO) could be coordinated to the benefit of both parties." This cooperation includes the sharing of responsibilities (leadership and financial) for conducting portions of large, multi-year R&D projects; the exchange of information on R&D work in areas of mutual interest; and participation in periodic conference calls and meetings (technical and budget reviews) for the other program.

^a "Memorandum of Understanding Between United States Department of Energy (DOE) and The Electric Power Research Institute (EPRI) on Light Water Reactor Research Programs," dated November 1, 2010, and signed by John E. Kelly, Deputy Assistant Secretary for Nuclear Reactor Technologies, Office of Nuclear Energy, DOE and Neil Wilmshurst, Vice President Nuclear, EPRI.

The work funded and managed by DOE under the LWRS Program is laid out along the following R&D pathways^b:

- 1. Materials Aging and Degradation (MAaD)
- 2. Risk-Informed Safety Margin Characterization (RISMC)
- 3. Advanced Instrumentation, Control, and Information (II&C) Systems Technologies.

The work funded and managed by EPRI under their LTO Program is organized and managed in the following work areas:

- 1. Primary System Metals Aging
- 2. Concrete Structures, including Containment Degradation
- 3. Instrumentation and Control (I&C) and Information Technology (including online monitoring of critical equipment)
- 4. Advanced Safety and Risk Analysis Tools
- 5. Integrated Life-Cycle Management (data, methods, and tools)
- 6. Cable Aging
- 7. Aging Management Program Scope for Operation Beyond 60 Years
- 8. Integrated Strategy, Process Plan, and Demonstration Plants.

As acknowledged in the memorandum of understanding, "the technical areas above encompassing each participant's work scope are roughly the same;" that is, both organizations have the same objectives to deliver technology on critical issues in a timely manner to inform decisions on life extension and license renewal. LTO Technical Area 5, Integrated Life-Cycle Management, and LTO Technical Area 7, Aging Management Program Scope, currently are exceptions for which there are no corresponding LWRS Program pathways. In a few cases, activities are highly collaborative and co-funded — both organizations fund the same activity with the same deliverable. However, in most cases, as stated in the memorandum of understanding, "...the planned work in each program is distinctly different as the result of planning that reduces duplication of effort and takes into account each party's interests and strengths."

At the center of DOE's interest is work to develop new scientific knowledge, models, tools, and technology. DOE brings the strong expertise of national laboratory investigators, unique laboratory capabilities, and relationships with universities and other laboratories. At the center of EPRI's interest are adaptation, validation, and implementation of technology with deliverables such as databases, guidelines, and pilot applications. EPRI brings global leadership in conducting public interest R&D with collaboration from nuclear utilities. Through joint planning and defined cooperation, the intent is to leverage the diversity between the LWRS and LTO Programs to more efficiently and effectively meet the joint objectives.

^b A fourth pathway, Advanced Light Water Reactor Fuels, was transitioned to the DOE-NE Fuel Cycle R&D Program under the advanced fuels activity at the beginning of Fiscal Year 2014.

2. DESCRIPTION OF RESEARCH AND DEVELOPMENT PROGRAMS

2.1 Department of Energy Office of Nuclear Energy Light Water Reactor Sustainability Program

For the LWRS Program, "sustainability" is defined as the ability to maintain safe and economic operation of the existing fleet of nuclear power plants for a longer-than-initially-licensed lifetime. It has two facets with respect to long-term operations: (1) manage the aging of hardware so the nuclear power plant lifetime can be extended and the nuclear power plants can continue to operate safely, efficiently, and economically; and (2) provide science-based solutions to industry to implement technology to exceed the performance of the current labor-intensive business model.

In April 2010, DOE-NE's Roadmap was issued. The roadmap organized DOE-NE activities in accordance with four objectives that ensure nuclear energy remains a compelling and viable energy option for the United States. Objective 1 of the roadmap focuses on developing the technologies and other solutions that can improve reliability, sustain safety, and extend the life of the current fleet of commercial nuclear power plants. The LWRS Program is the primary programmatic activity that addresses Objective 1. The LWRS Program is focused on the following three goals:

- 1. Developing the fundamental scientific basis to understand, predict, and measure changes in materials and systems, structures, and components (SSCs) as they age in environments associated with continued long-term operations of existing reactors
- 2. Applying this fundamental knowledge to develop and demonstrate methods and technologies that support safe and economical long-term operation of existing reactors
- 3. Researching new technologies to address enhanced nuclear power plant performance, economics, and safety.

Through the LWRS Program, DOE collaborates with industry and the U.S. Nuclear Regulatory Commission (NRC) in appropriate ways to support and conduct the long-term research needed to inform major component refurbishment and replacement strategies, performance enhancements, nuclear power plant license extensions, and age-related regulatory oversight decisions. The DOE role focuses on aging phenomena and issues that require long-term research and are generic to reactor type.

The LWRS Program consists of the following primary technical areas of R&D:

- 1. **MAaD** with R&D to develop the scientific basis for understanding and predicting long-term environmental degradation behavior of materials in nuclear power plants. The work will provide data and methods to assess the performance of SSCs essential to safe and sustained nuclear power plant operations. The R&D products will be used to define operational limits and aging mitigation approaches for materials in nuclear power plant SSCs that are subject to long-term operating conditions, providing key input to both regulators and industry.
- 2. **RISMC** with R&D to develop and deploy approaches to support the management of uncertainty in safety margins quantification to improve decision making for nuclear power plants. This pathway will (1) develop and demonstrate a risk-assessment method tied to safety margins quantification and (2) create advanced tools for safety assessment that enable more accurate

^c The R&D roadmap is being revised; an updated roadmap should be available in 2014.

representation of nuclear power plant safety margins and their associated impacts on operations and economics. The R&D products will be used to produce state-of-the-art nuclear power plant safety analysis information that yields new insights on actual nuclear power plant safety/operational margins and permits cost-effective management of those margins during periods of extended operation.

3. Advanced II&C Systems Technologies with R&D to address long-term aging and modernization of current I&C technologies through development/testing of new I&C technologies and advanced condition monitoring technologies for more automated and reliable plant operation. The R&D products will be used to design/deploy new II&C technologies and systems in existing nuclear power plants that provide an enhanced understanding of plant operating conditions/available margins and improved response strategies/capabilities for operational events.

Public Law 109-58 (National Energy Policy Act of 2005, EPAct 2005) and Congressional language establish a clear expectation that the DOE-NE funding for LWRS Program activities will be supported by industry to "cost share" the overall R&D effort. Cost sharing of LWRS R&D projects by industry ensures that federal funding is leveraged on the most important technical challenges relative to long-term operations of the current reactor fleet. Each LWRS Program pathway considers cost-share contributions from industry as part of the R&D selection process. In 2014, the value of industry cost sharing for LWRS R&D activities is approximately 22.0 million dollars. This compares to 2012 and 2013 values of 21.6 and 17.9 million dollars, respectively. The major elements of this cost sharing include the value of in-kind contributions of services/resources (subject matter expert involvement in R&D projects, shared test data, and donated/shared materials for testing). Details are provided in an appendix to this plan.

2.2 Electric Power Research Institute Long-Term Operations Program

High capacity factors and low operating costs make nuclear power plants some of the most safe and economical power generators available. Even when major plant components must be upgraded to extend operating life, nuclear power plants often represent a safe, cost-effective, low-carbon asset. The decision to extend nuclear power plant life involves inter-related technical, economic, regulatory, and public policy issues. Unknown or uncertain technical inputs impact the decision-making process both directly and indirectly: directly through design and operational contingencies and indirectly through impacts on regulatory actions and public policy.

Recognizing the many technical challenges confronting nuclear power plant operation, EPRI launched the LTO Project in 2009. LTO is defined as being high-performance nuclear power plant operation under extended service conditions. High performance is measured by reliability, availability, cost of operations, and safety.

The LTO Project at EPRI is justified by the potential benefits that long-term operations present to society and to member companies. In 2011, the EPRI LTO Project was elevated to program status and is funded by all EPRI Nuclear Sector members. However, success is contingent on timely and useful products. LTO products must provide a sound technical basis for decisions necessary to achieve high-performance nuclear power plant operation under extended service conditions. Specifically, LTO Program projects must address one or more of the following:

- 1. License renewal for long-term nuclear power plant operation
- 2. Aging management and life-cycle management throughout long-term operation

3. Opportunities for modernization and performance improvement.

Criteria for selecting technical areas and specific work scopes within technical areas are as follows:

- 1. Projects address one or more of the following needs:
 - a. Identify and characterize (or dismiss) a potential life-limiting issue
 - b. Support aging management and life-cycle management
 - c. Provide opportunities for modernization
 - d. Develop enabling technology (e.g., analysis methods) that will be needed to enhance performance or reduce cost.
- 2. Useful results are planned for the timeframe of 2014 to 2019.
- 3. It is unlikely that the planned R&D would be performed within other programs at EPRI.
- 4. EPRI involvement is necessary to provide industry input to R&D efforts with collaborating partners such as the DOE-NE LWRS Program or NRC's Office of Nuclear Regulatory Research.

The R&D portfolio addresses the following eight technical areas and associated principal objectives:

- 1. For *primary system metals*, characterize the conditions and parameters associated with aging degradation, develop data resources and predictive models for remaining useful life, and provide methods to mitigate risk and extend component life. Individual projects addressing this objective include the following:
 - a. Extension of Materials Degradation Matrix and Issues Management Tables to include Failure Mechanisms to 80 Years
 - b. Evaluation of Crack Initiation and Propagation Mechanisms in LWR Components
 - c. Identifying Mechanisms and Mitigation Strategies for Irradiation-Assisted Stress Corrosion Cracking of Stainless Steel in LWR Core Components
 - d. Reactor Pressure Vessel (RPV) Embrittlement from Long-Term Fluence
 - e. Welding of Irradiated Materials for Reactor Internals Repair and Replacement.
- 2. For *concrete structures, including containment*, identify and prioritize degradation mechanisms and locations; establish methods for issue resolution, including new nondestructive examination (NDE) and forensic concrete examination methods; prognostic modeling to determine remaining useful life; and investigate mitigation measures for issues important to long-term operations.
- 3. Through support of structured pilot studies, demonstrate and document *advanced I&C* and *information technology* to address obsolescence aging of components and systems. Pilot studies will address a highly integrated control room, highly automated nuclear power plant, integrated operations, human performance improvement for field workers, outage safety and efficiency, and centralized online monitoring and information integration. EPRI will participate on a working

group that oversees these studies. EPRI also will document good practices and requirements for these studies into an accessible database. For mature applications with generic applicability, EPRI will develop guidelines for future applications.

- 4. Create *advanced safety and risk analysis tools* to address anticipated needs during the period of long-term operation and develop an approach for best estimate safety margins assessments that can identify the contributions of design and operational changes, aging effects, and key uncertainties.
- 5. Provide industry with *integrated life-cycle management* data, methods, and software for key components that will improve the cost and certainty of high-performance operation and will support optimization of integrated refurbishment and uprate plans. Individual projects addressing this objective include the following:
 - a. Integrated Life-Cycle Management Data Resource and Method
 - b. Pilot Application of Électricité de France Asset Management Tools
 - c. Transfer software tools and application to industry for routine use in optimizing economic decisions for major component repairs and replacements
- 6. Develop the *technical basis for aging management and life-cycle management of cables*, specifically, identifying cable aging management activities, classes of cables that can be life limiting, and data and methods for life-cycle management of aging cables. Enhanced testing and end-of-life predictive methods will be investigated.
- 7. Investigate *aging management program scope* for long-term operation. Research results and operating experience might identify additional components of concern, failure mechanisms, or conditions that would be part of aging management programs for long-term operation. R&D activities will be identified where risk-important gaps exist for aging management activities, including time-limited aging assessments, one-time inspections, and periodic inspections or monitoring.
- 8. Develop an *integrated strategy, process plan, and demonstration plants* to support license renewal, the decision to extend operation, and life-cycle management of assets. Demonstration plants will pilot applications of monitoring methods, inspection guidelines, testing methods, demonstrations of new technologies, and analyses. The principal projects addressing this objective are as follows:
 - a. LTO Integration and Collaboration
 - b. Nuclear Plant Life-Extension Demonstration Project (effort to be completed in 2014)
 - c. Plant support for subsequent license renewal by identifying issues and developing more accurate aging assessments of key components

In addition, a "living" Issues Tracking Table (ITT) maintains the status of all identified issues and their priorities. This table is regularly reviewed for accuracy and completeness by EPRI stakeholders, LWRS Progam representatives, a working group of the Nuclear Energy Institute, and EPRI advisors. The objectives and associated projects listed in this document have been selected from high-priority issues in

the ITT that meet the selection criteria and have received concurrence of the LTO Integration Committee. A copy of the latest ITT is included as Attachment A to this plan.

Finally, it is important to emphasize that considerable supporting R&D is pursued within EPRI that is driven by current operating nuclear power plant issues rather than by a specific LTO need. For example, buried and underground piping and tank research is an area where the impact is primarily directed at resolving issues for the operating fleet with respect to identifying the extent of in-service degradation and technology to detect and/or mitigate degradation. Additional areas are summarized in Section 5 to include Integrated Life Cycle Management (ILCM), Technical Bases Gap Assessment for Aging Management Programs to Support Subsequent License Renewal, Nuclear Plant Chemistry, and Steam Generator Management Program. If appropriate, work with an LTO focus and objective may be identified as the in-progress R&D efforts yield data and direction.

2.3 Reporting of Research and Development Projects

Consistent with the memorandum of understanding, the R&D projects described in the program plans for the LWRS and LTO Programs are presented in this joint plan using the following categories:

- 1. Section 3 discusses "Coordinated (but independent) Activities," meaning that "in general, work in the category will be managed by either DOE or EPRI, using standard, approved processes for R&D management. Funding is also likely to be independent for work in this category. Coordination will be limited to joint planning and communications to limit possible overlaps and gaps that may exist in the planned activities."
- 2. Section 4 discusses "Collaborative Activities," meaning that "DOE and EPRI intend work in the category to be planned and executed on a collaborative basis. The collaborative efforts between DOE and EPRI may involve, to a significant degree, joint funding as permitted by law and available appropriations. DOE and EPRI will determine which organization will lead each effort based on which party is positioned to most efficiently and effectively execute the work."
- 3. Section 5 (added in 2014) discusses "Program Unique Activities," that is, R&D activities supported by DOE-NE (under LWRS) or EPRI that are not considered (per the memorandum of understanding) to be coordinated or collaborative in nature, but yet add to the body of knowledge that may be consulted by nuclear power plant owners and operators as they weigh the technology, regulatory, and business factors involved with pursuing renewals of their plant's operating license from the NRC.

In Sections 3 and 4, the work of the lead program for the R&D activity is described first, followed by a similar description of the work by the supporting program (in some cases, the lead for the activity is jointly shared by the LWRS Program and the LTO Program).

Table 1 represents a summary overview of the joint R&D plan. The table lists (beginning in the left column) the LWRS Program's R&D activities, the corresponding (coordinated or collaborative) LTO Program's R&D activities, and the program-unique R&D activities. For the purposes of this plan, multiple R&D activities are, in selected instances, rolled up under a single heading.

7

^d As committed to in the memorandum of understanding, "DOE and EPRI endeavor to plan, integrate, and prioritize nuclear R&D in Coordinated Activities and Collaborative Activities, and intend to keep each other informed of meetings, correspondence, and the status of work in order to strengthen the partnership." Further, the LWRS and LTO Programs are committed to maintaining an inventory of the relevant technical results from these R&D projects and sharing each program's R&D results with the other organization.

Table 1. Summary overview of the joint research and development plan.

Table 1. Summary overvi	ew of the joint research and develor	oment plan.		
LWRS Project	Related LTO Project	Coor- dinated Activity	Collabo- rative Activity	Program Unique Activity
Materials Aging and Degradation	Understanding, Prediction, and Mitigation of Primary System Aging Degradation			
Expanded Materials Degradation Assessment				LWRS
	Materials Degradation Matrix and Issues Management Tables			LTO
Reactor Metals				
RPV – High Fluence, Materials Variability, and Attenuation Effects on RPV Steels	RPV Embrittlement from Long- Term Fluence (focus on power reactor surveillance capsules irradiation and analyses)	LWRS- LTO joint lead		
Mechanisms of Irradiation-Assisted Stress Corrosion Cracking (IASCC)	IASCC: Identifying Mechanisms and Mitigation Strategies for IASCC of Austenitic Steels and LWR Core Components		LWRS- LTO joint lead	
Irradiation Effects (core internals – IASCC, swelling, and phase transformations)	Irradiation Effects (core internals – IASCC, swelling, and phase transformations)	LWRS- LTO joint lead		
Crack Initiation in Ni-Base Alloys	Environmental-Assisted Cracking: Evaluation of Crack Initiation and Propagation Mechanisms in LWR Components	LWRS- LTO joint lead		
Environmentally Assisted Fatigue (EAF)	EAF – Long-term focus; EPRI has a short-term focus (current operating plants) effort as well	LWRS- LTO joint lead		
Thermal Aging of Cast Austenitic Stainless Steel (CASS)	Thermal Aging of CASS	LWRS- LTO joint lead		
Concrete	Comprehensive Aging Management of Concrete Structures (Technology Roadmap)		LWRS- LTO joint lead	
Cabling	Technical Basis for Aging Management and Life-Cycle Management of Cables		LWRS- LTO joint lead	

Table 1. (continued).

Table 1. (continued).				
LWRS Project	Related LTO Project	Coor- dinated Activity	Collabo- rative Activity	Program Unique Activity
Mitigation Strategies				
Advanced Weld Repair	Advanced Welding Methods for Irradiated Materials		LWRS- LTO joint lead	
Advanced Replacement Alloys	Advanced Radiation-Resistant Materials Program		LWRS- LTO joint lead	
Thermal (Post- Irradiation) Annealing				LWRS
Integrated Research – International Activities (Halden Project, International Forum on Reactor Aging Management)	Participation in both Halden Project and International Forum on Reactor Aging Management	LWRS- LTO joint lead		
Integrated Research – International Activities (Materials Aging Institute)	Partnership in Materials Aging Institute (EPRI Nuclear Sector)	LTO Lead		
Constellation ^e Demonstration Project	Ginna and Nine Mile Point Unit 1 Demonstration Plant Activities		LWRS- LTO joint lead	
Zion Materials Management and Coordination				LWRS
NDE Technologies	Opportunities to Employ NDE Technologies for Automatic, Continuous, In-Situ Monitoring	LWRS- LTO joint lead		
Advanced II&C Systems Technologies				
New Instrumentation and Control and Human System Interfaces and Capabilities (including Advanced II&C Pilot Projects)	Requirements Database and Guidelines for Advanced I&C, Human System Interface, and Information Technology		LWRS lead	

^e Ownership of the plants hosting the demonstration project has been transferred from Constellation to Exelon.

Table 1. (continued).

Table 1. (continued).		Coor- dinated	Collabo- rative	Program
LWRS Project	Related LTO Project	Activity	Activity	Unique Activity
Halden Project	Halden Project	LWRS lead		
Centralized Online Monitoring and Information Integration	Centralized Online Monitoring Methodology, Guidelines, and Pilot Studies (Part of Advanced II&C Pilot Projects)		LTO lead	
Industrial and Regulatory Engagement	Requirements Database and Guidelines for Advanced I&C, Human System Interface, and Information Technology		LTO lead	
RISMC				
Margins Analysis Techniques Modeling and Simulation Activities	Enhanced Safety Analysis Capability		LWRS- LTO joint lead	
	Enhanced Risk Assessment and Management Capability	LTO lead		
Other Projects				
	Integrated Life-Cycle Management			LTO
	Technical Bases Gap Assessment for Aging Management Programs to Support Subsequent License Renewal			LTO
	Buried Piping and Tanks			EPRI (Plant Engineering and NDE)
	Chemistry			EPRI (Water Chemistry)
	Steam Generator Management			EPRI (Steam Generator Management Program)

3. LIGHT WATER REACTOR SUSTAINABILITY/ LONG-TERM OPERATIONS COORDINATED RESEARCH AND DEVELOPMENT ACTIVITIES

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
Reactor Metals	
Reactor Metals LWRS – RPV: High Fluence, Materials Variability, and Attenuation Effects on RPV Steels	R&D Scope and Objectives: High-Fluence Effects – The last few decades have seen much progress in developing a mechanistic understanding of irradiation embrittlement for RPV. However, there are still significant technical issues that need to be addressed to reduce the uncertainties in regulatory application. The objective of this research task is to examine and understand the influence of irradiation at high fluences on RPV embrittlement. Both industrial capsules and single variable experiments may be required to evaluate potential for embrittlement and to provide a better mechanistic understanding of this form of degradation. Acquisition of samples from past programmatic campaigns (e.g., NRC programs), specimens harvested from decommissioned reactors (e.g., Zion Units 1 and 2), surveillance specimens from operating nuclear power plants, and materials irradiated in new test campaigns all have value in understanding high-fluence effects. Testing will include impact and fracture toughness evaluations, hardness, and microstructural analysis (i.e., atom probe tomography, small angle neutron scattering, and/or positron-annihilation spectroscopy). These research tasks all support development of a predictive model for transition-temperature shifts for RPV steels under a variety of conditions. This tool can be used to predict RPV embrittlement over a variety of conditions key to irradiation-induced changes (e.g., time, temperature, composition, flux, and fluence) and extends the current tools for RPV management and regulation to extended-service conditions. This model will be delivered in 2015 in a detailed report, along with all supporting research data. In addition, the library of assembled materials will be available for examination and testing by other stakeholders.
	Materials Variability and Attenuation Effects – The subject of material variability has experienced increasing attention in recent years as additional research programs began to focus on the development of statistically viable databases. The objective of this task is to develop new methods to generate meaningful data out of previously tested specimens. Embrittlement margins for a vessel can be accurately calculated using supplementary alloys and experiments using higher flux test reactors. The potential for non-conservative estimates resulting from these methodologies must be evaluated to fully understand the potential influence on safety margins. Critical assessments and benchmark experiments will be conducted. Harvesting of through-thickness RPV specimens may be used to evaluate attenuation effects in a detailed and meaningful manner. Testing will include impact and fracture toughness evaluations, hardness, and microstructural analysis (i.e., atom probe tomography, small angle neutron scattering, and/or positron-annihilation spectroscopy). The results of these examinations can be used to assess the operational implications of high-fluence effects on the RPV. Furthermore, the predictive capability developed in earlier tasks will be modified to address these effects.

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
LTO – RPV Embrittlement from Long-Term Fluence	R&D Scope and Objectives: Currently, RPV embrittlement is not considered to be a life-limiting factor for 60 years of operation because of the relatively low fluence level. However, for 80 or more years, refinement of analysis, testing, and validation of embrittlement models using irradiated samples will be needed. This project will design, fabricate, and irradiate one or more supplemental surveillance capsules that will provide high-fluence irradiated data to support future development of embrittlement trend curves applicable for LWR operation at high fluences. This project also will develop and refine an embrittlement trend correlation using the Master Curve approach to convert the shift in Charpy V-notch energy data at different temperatures and irradiations to a fracture toughness equivalent shift. This embrittlement trend correlation is necessary to bridge the gap between the Charpy V-notch energy evaluation approach and the fracture toughness Master Curve approach. In addition, there is a need to develop new testing methods to extend the use of existing surveillance specimens to generate Master Curve fracture toughness data. This project will participate in a round robin test program to assess one such method that has been developed.
LWRS – RPV: High-Fluence, Materials Variability, and Attenuation Effects on RPV Steels	 Milestones: High-fluence effects: (2014) Complete acquisition of experimental data on commercial and model RPV alloys. (2015) Provide validated model for transition temperature shifts in RPV steels. Future milestones and specific subtasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. The experimental data and model are of value to both industry and regulators. Completion of data acquisition to permit prediction of embrittlement in RPV steels at high fluence is a major step in informing long-term operation decisions; high-quality data can be used to inform operational decisions for RPV by industry. For example, data and trends will be essential in determining operating limits. The data also will allow for extension of regulatory limits and guidelines to extended service conditions. The delivery of a validated model for prediction of transition temperature shifts in RPV steels will allow for estimation of RPV performance over a wide range of conditions. This will enable extension of current tools for RPV embrittlement (e.g., Fracture Analysis of Vessels: Oak Ridge^f) to extended service conditions. Materials variability and attenuation effects: (2015) Complete a detailed review of the NRC pressurized thermal shock re-evaluation project relative to the subject of material variability and identify specific remaining issues. (2018) Complete analysis of hardening and embrittlement through the RPV thickness for the Zion RPV sections.

 $^f NUREG/CR-6854, ORNL/TM-2004/244, Fracture\ Analysis\ of\ Vessels-Oak\ Ridge\ FAVOR, v04.1, Computer\ Code:\ Theory\ and\ Implementation\ of\ Algorithms,\ Methods,\ and\ Correlations,\ P.\ T.\ Williams,\ T.\ L.\ Dickson,\ and\ S.\ Yin,\ Oak\ Ridge\ National\ Laboratory,\ October\ 2004.$

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
	Future milestones and specific subtasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. The analysis of hardening and variability through the thickness of an actual RPV section from service has considerable value to all stakeholders. These data will provide a first look at embrittlement trends through the thickness of the RPV wall and inform operating limits, fracture mechanics models, and safety margins.
LTO – RPV	Milestones:
Embrittlement from Long-Term Fluence	This project involves irradiation of supplemental surveillance specimens to high fluence in a pressurized water reactor (PWR). The follow-up testing and analysis must be performed in a laboratory with the capability of handling irradiated materials and reconstituting Charpy specimens. The project requires 10 or more years to complete the work. The work will be coordinated with ongoing and planned work within the PWR Materials Reliability Program and Boiling Water Reactor (BWR) Vessel and Internals Project to address RPV embrittlement after extended operation.
	• (2014) Participate in a round robin test of a new method to extend the use of existing surveillance specimens to generate Master Curve data.
	(December 2015) Design, fabricate, and insert a supplemental surveillance capsule in a host PWR.
	• (2014) Develop and refine an embrittlement trend correlation; report on revisions to the embrittlement trend correlation.
LWRS – Irradiation Effects (core internals – IASCC, swelling, and phase transformations)	R&D Scope and Objectives: IASCC – The objective of this task is to assess high-fluence effects on IASCC for core internals. Crack growth-rate testing is especially limited for high-fluence specimens. Intergranular fracture observed in recent experiments suggests more work is needed. Also of interest is identification of high-fluence materials available for research and testing in all tasks. Research includes a detailed plan to obtain high-fluence specimens for IASCC testing from irradiation of as-received material to high fluence in a test reactor, obtaining high-fluence materials for sample manufacturing, or a combination of those two factors. In addition, both tests (i.e., crack growth and tensile tests) will be performed in simulated water environments in addition to complementary post-irradiation examination of irradiation effects. Results from this task can be used to investigate the potential for IASCC under extended service conditions, extend the mechanistic studies from other tasks in the LWRS Program, and be used to validate predictive models at high fluence.
	Swelling – This task will provide detailed microstructural analysis of swelling in key samples and components (both model alloys and service materials), including transmission electron microscopy and volumetric measurements. These results will be used to develop and validate a phenomenological model of swelling under LWR conditions. This will be accomplished by extension of past models developed for fast reactor conditions. The data generated and mechanistic studies will be used to identify key operational limits (if any) to minimize swelling concerns, optimize inspection and maintenance schedules to the most susceptible materials/locations, and, if necessary, qualify swelling-resistant

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
	materials for LWR service.
	Phase Transformations – This task will provide detailed microstructural analysis of phase transformation in key samples and components (both model alloys and service materials), including transmission electron microscopy, magnetic measurements, and hardness examinations. Mechanical testing to quantify any impacts on embrittlement also may be performed. These results will be used to develop and validate a phenomenological model of phase transformation under LWR operating conditions. This will be accomplished by use of computational thermodynamics and extension of models for radiation-induced segregation. The generated data and mechanistic studies will be used to identify key operational limits (if any) to minimize phase transformation concerns, optimize inspection and maintenance schedules to the most susceptible materials/locations, and, if necessary, qualify radiation-tolerant materials for LWR service.
LTO – Irradiation	R&D Scope and Objectives:
Effects (core internals – IASCC, swelling, and phase transformations)	EPRI work on IASCC, swelling, and phase transformations is coordinated under the Materials Reliability Program for PWRs and under the BWR Vessel and Internals Program for BWRs. Significant work, including international cooperative programs, is funded under these two EPRI Programs. For example, the Gondole Project is a multi-national effort that includes EPRI funding that specifically seeks to develop data via test reactor irradiation of prototypical materials to characterize irradiation-induced swelling degradation effects in stainless steels. The current Phase 2 of the project seeks to drive irradiation to doses of 30 dpa. This phase is in progress with completion expected in 2018.
	Additionally, EPRI is performing thermal and irradiation embrittlement studies on weld material removed from the retired Zorita PWR in Spain. This information will be used to inform both PWR and BWR fracture toughness considerations. This effort is in progress and planned for completion in 2014.
LWRS – Irradiation	Milestones:
Effects (core	IASCC:
internals – IASCC, swelling, and phase	• (2014) Complete revised joint plan with EPRI for very high fluence testing of core internals.
transformations)	Future milestones and specific subtasks will be based on the plan developed in 2013 and partnerships developed in early 2014. Completing a detailed experimental plan for high-fluence IASCC testing is an essential first step in estimating the impact of IASCC at high fluence. This plan also is critical for building support and partnerships with industry and regulators.
	Swelling: • (2014) Complete model development for swelling in LWR components. • (2016) Deliver predictive capability for swelling in LWR components.
	Future milestones and specific tasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. The development and delivery for a validated model for swelling in core internal components at high fluence is an important step in estimating the useful life of core internal components. Understanding which components are susceptible to this form of degradation is of value to industry and regulators, because it will permit more

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
	focused component inspections, component replacements, and more detailed regulatory guidelines. Phase transformations: (2014) Complete basic model development for phase transformations in LWR components. (2017) Deliver experimentally validated, physically-based thermodynamic and kinetic model of precipitate phase stability and formation in Alloy 316 under anticipated extended lifetime operation of LWRs.
	Future milestones and specific tasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. Development and delivery for a validated model of phase transformations in core internal components at high fluence is an important step in estimating the useful life of the core internal components. Understanding which components are susceptible to this form of degradation is of value to industry and regulators, because it will permit more focused component inspections, component replacements, and more detailed regulatory guidelines.
LTO – Irradiation Effects (core internals – IASCC, void swelling, and phase transformations)	 Milestones: (2015) Interim results of IASCC crack growth and irradiation embrittlement studies on Zorita weld and HAZ material in BWR environments. (2018) Completion of Gondole Phase 2. (2019) Final report on Phase 2 Gondole Void Swelling Irradiation and Testing.
LWRS – Crack Initiation in Ni-Base Alloys	R&D Scope and Objectives: The objective of this task is the identification of underlying mechanisms of stress corrosion cracking (SCC) in Ni-base alloys. Understanding and modeling the mechanisms of crack initiation is a key step in predicting and mitigating SCC in the primary and secondary water systems. An examination into the influence of surface conditions on precursor states and crack initiation also is a key need for Ni-base alloys and austenitic stainless steels. This effort focuses on SCC crack-initiation testing of Ni-base alloys and stainless steels in simulated LWR water chemistries, but includes direct linkages to SCC crack-growth behavior. Carefully controlled microstructure and surface states will be used to generate single-variable experiments. The experimental effort in this task will be highly complementary to efforts being initiated at the Materials Aging Institute, which are focused primarily on modeling of crack initiation. This mechanistic information could provide key operational variables to mitigate or control SCC in these materials, optimize inspection and maintenance schedules to the most susceptible materials/locations, and potentially define SCC-resistant materials.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
LTO -	R&D Scope and Objectives:
Environmental- Assisted Cracking: Evaluation of Crack Initiation and Propagation Mechanisms in LWR Components	Environmental-assisted cracking of primary system components is the most prevalent degradation mechanism that directly impacts the sustainability of reliable operation of LWRs. To achieve long-term operation, it is imperative to extend the useful life of components in LWRs through better understanding of the crack initiation and propagation processes, improved predictive models, and identify effective countermeasures against SCC. The objectives of this project include the following:
	 Determine the composition and impedance properties of metal surface oxides resulting from interaction with LWR environments, including the effects of Fe²⁺, Ni²⁺, and Zn²⁺ cations, to identify the key process leading to cracking. Evaluate the effect of Fe²⁺, Ni²⁺, and Zn²⁺ cations on oxide properties. Investigate the influence of hydrogen partial pressure on the damage processes prior to crack initiation in Alloy 600 in PWR primary water. Understand the mechanistic reasons for the superior performance of Alloy 690 relative to Alloy 600, particularly in the context of long-term performance; such a mechanistic basis will support proposals for optimizing the inspection frequency of Alloy 690 components. Participate in a collaborative research program in Japan to deepen the understanding of interface oxidation dynamics through the use of in-situ and ex-situ measurements by synchrotron x-rays at the Spring-8 synchrotron radiation facility in Japan. Identify the mechanisms leading to decreased fracture resistance in component materials in LWR environments. Develop improved prediction models of IASCC initiation and propagation and evaluation methodologies for assessing the reliability of LWR structural materials to support LTO and xLPR programs.
	Develop strategies to mitigate the risk of environmental-assisted cracking degradation and to extend component life based on a sound mechanistic understanding.
LWRS – Crack	Milestones:
Initiation in Ni-Base Alloys	 (2014) Complete Phase 1 mechanistic testing for SCC research. (2017) Deliver predictive model capability for Ni-base alloy SCC susceptibility.
	Completing research to identify the mechanisms and precursor states is an essential step in predicting the extent of this form of degradation under extended service conditions. Understanding the underlying causes for crack initiation may allow for more focused material inspections and maintenance, new SCC-resistant alloys, and development of new mitigation strategies, all of which are of high interest to the nuclear industry. This mechanistic understanding also may drive more informed regulatory guidelines and aging-management programs. In the long-term, mechanistic understanding also enables development of a predictive model, which has been sought by industry and regulators for many years.

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
LTO –	Milestones:
Environmental- Assisted Cracking: Evaluation of Crack Initiation and Propagation Mechanisms in	Activity 1: In-situ surface oxide film characterization and correlation between oxidation and crack initiation:
	• (2014) Summarize results of in-situ surface oxide film composition and impedance properties as functions of materials/LWR environment combinations, including the effects of cations.
LWR Components	• (2013-2014) Damage Processes Prior to Crack Initiation in Ni Alloys.
•	• (2014) Summarize the results of in-situ surface oxide structure and oxidation kinetics.
	• (September 2016) Establish correlation between oxidation and crack initiation.
	Activity 2: Local strain-stress behavior associated with crack:
	• (2014) Results from in-situ synchrotron x-ray stress measurement.
	• (2016) Establish correlation between strain rate and crack growth rate.
	Activity 3: Parametric study and development of mitigation strategy:
	• (2015) Summary of parametric experiments on crack growth rate.
	• (2017) Develop and validate mitigation strategies.
	Activity 4: Modeling: • (2012) Program on Technology Innovation: Hybrid Models of SCC Propagation for Nickel Alloy Welds in Low-Electrochemical Potential PWR Primary Water Environments (1024863, February 2012).
	• (2016) Environmental-assisted cracking crack growth prediction model.
	• (September 2019) Environmental-assisted cracking crack initiation model.
	Activity 5: Consolidation of knowledge base for long-term operations:
	• (2013, 2015, and 2018) Environmental-assisted cracking knowledge base updates for long-term operations.
LWRS –EAF	R&D Scope and Objectives:
	The objective of this task is to develop a model of EAF mechanisms. This will be supported by experimental studies to provide data for the identification of mechanisms and key variables and provide data for model validation. The experimental data will inform regulatory and operational decisions, while the model will provide a capability to extrapolate the severity of this mode of degradation to extended-life conditions. A final report will be delivered in the 2017 to 2021 timeframe, providing both the model of fatigue mechanisms and the supporting experimental data.

D.D	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
LTO – EAF	R&D Scope and Objectives:
(long-term focus)	The lack of definite design rules for EAF creates uncertainty for both new and operating nuclear power plants, where design compliance must be shown for the extended operating period (significant uncertainty for a potential 80-year life). To attain acceptable fatigue usage, design changes that increase design, construction, and operations costs without meaningful safety benefits may be required for previously certified designs, as well as designs currently under review by NRC. Affected items in the design may include materials selection, piping thickness, fitting tolerances, and number and locations of piping supports. Additionally, for license renewal, there is uncertainty as to the requirements that may be imposed by NRC because the scope of locations requiring environmental fatigue analysis is open to interpretation.
	Several EPRI programs will combine expertise and share final EAF results to address the current data and analysis process. Upon completion of this work, EPRI intends to work through the American Society of Mechanical Engineers code process to support effective code revisions that resolve the fatigue issue. These actions will include the following:
	Publication of reports and related documents that form the technical basis of code modifications in order to obtain code approval and regulatory acceptance
	Development of EPRI guidance and code cases that provide evaluation procedures for assessing fatigue environmental factors that are accepted by regulatory authorities
	 Promoting an understanding of new procedures to provide for consistency of application by nuclear power plant vendors, construction firms, and utilities (new and operating plant owners)
	• Supporting American Society of Mechanical Engineers Section III and XI code revisions that permanently include EAF procedures within the body of the code.
	Note that EPRI continues to perform projects that address fatigue and EAF in the current operating fleet.
LWRS – EAF	 Milestones: (2014) Complete base model development for EAF in LWR components. (2017) Complete experimental validation and deliver model for EAF in LWR components.
	Completing the research to identify the mechanisms of EAF to support model development is an essential step in predicting the extent of this form of degradation under extended service conditions. This knowledge has been identified as a key need by regulators and industry. Delivering a model for EAF will enable more focused material inspections, material replacements, and more detailed regulatory guidelines.
LTO – EAF	Milestones:
	• (2013) Publish guidance for EAF methodology.
	• (2013 through 2015) Continue international research collaboration with

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
	 expert panel review and advice. (2013 through 2016) Initiate specimen testing and R&D to resolve EAF knowledge gaps – address inconsistencies in test data vs. operating plants experience on crack initiation. (2013 through 2015): Formulate and validate models of EAF enhancement and retardation in BWR and PWR environments based on fundamental understanding of EAF.
LWRS – Thermal Aging of CASS	R&D Scope and Objectives: In this research task, the effects of elevated temperature service in CASS will be examined. Possible effects include phase transformations that can adversely impact mechanical properties. This task will provide conclusive predictions for the integrity of the CASS components of nuclear power plants during extended service life. Mechanical and microstructural data obtained through accelerated aging experiments and computational simulation will be key input for the prediction of CASS behaviors and for the integrity analyses for various CASS components. While accelerated aging experiments and computational simulations will comprise the main components of the knowledge base for CASS aging, the data also will be obtained from operational experience. These data are required to validate the accelerated aging methodology. Therefore, in addition to using existing data, a systematic campaign to obtain mechanical data from used materials or components will be pursued. Further, the detailed studies on aging and embrittlement mechanisms and on deformation and fracture mechanisms are performed to understand and predict the aging behavior over an extended lifetime.
LTO – Thermal Aging of CASS and Stainless Steel Welds	R&D Scope and Objectives: Investigate fundamental mechanisms of thermal aging in ferritic-austenitic stainless welds and CASS material and at LWR temperatures, as well as effects of thermal aging on mechanical properties and corrosion resistance. Additionally, EPRI is developing evaluation and acceptance criteria to be applied for currently operating nuclear power plants. A technical report submittal to NRC for review and approval is planned for 2014.
LWRS – Thermal Aging of CASS	 Milestones: (2017) Complete analysis of CASS specimens harvested from service conditions. (2018) Complete analysis and simulations on aging of CASS components and deliver predictive capability for CASS components under extended service conditions. Completing research to identify potential thermal aging issues for CASS components is an essential step to identifying possibly synergistic effects of thermal aging (e.g., corrosion or mechanical) and predicting the extent of this form of degradation under extended service conditions. Understanding the mechanisms of thermal aging will enable more focused material inspections, material replacements, and more detailed regulatory guidelines. These data also will help close gaps identified in the EPRI Materials Degradation Matrix and upcoming Expanded Materials Degradation Assessment reports.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
LTO – Thermal Aging of CASS and Stainless Steel Welds	 Milestones: (2014) White paper on R&D relating to CASS and stainless steel weld metals in PWRs. (2014) Technical bases for evaluation and acceptance criteria for CASS materials in service.
Mitigation Strategies	
LWRS – Integrated Research/ International Collaborations (Halden Project and the International Forum on Reactor Aging Management)	R&D Scope and Objectives: Participate in international collaborations that offer opportunities for a broader and more detailed research program than possible in an isolated research program. Coordinated research with international institutions (such as the Materials Aging Institute of which EPRI is a member) will provide more collaboration and cost sharing. Research opportunities also can be explored through cooperative efforts with the International Forum on Reactor Aging Management, which facilitates the appropriate exchange of information among those parties and organizations around the world that presently are planning to address or are addressing issues of nuclear power plant SSCs aging management. In addition, research opportunities through information exchanges with the Halden Project are a planning element of the R&D collaboration.
LTO – Integrated	R&D Scope and Objectives:
Research/ International Collaborations (Materials Aging Institute)	Participate in international collaborations (such as the Halden Project) that offer opportunities for a highly leveraged and more detailed research program than is possible in an isolated research program. Coordinated research with the Materials Aging Institute (of which EPRI is a member) will provide more collaboration and cost sharing.
LWRS – Integrated	Milestones:
Research/ International Collaborations	LWRS milestones related to international collaborations are identified under the specific MAaD R&D areas.
LTO – Integrated Research/ International Collaborations	 Milestones (2014) Participate in the Halden IASCC Advisory Group meeting to review progress and establish future direction of the program.
LWRS – NDE	R&D Scope and Objectives: NDE R&D is planned for the following MAaD R&D areas: RPV – In the context of long-term operations, the RPV will see increased exposure to time-at-temperature, along with the effects of extended irradiation as described in previous sections. This exposure is expected to reduce the fracture toughness of the RPV. As a result of this exposure and the operational stresses experienced, issues of concern in RPV durability will include phase transformations due to irradiation and embrittlement and hardening. Preexisting flaws in the RPV also are of interest for their implications on RPV structural performance during accident scenarios. Development of one or more NDE techniques that can assist in the determination of current RPV fracture toughness and in prediction of fracture toughness with further aging of the vessel is

_	
R&D Area	
R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO) essential. The NDE measurements and the corresponding models that can verify their applicability to the problem, sensitivity to embrittlement and microcracking, and accuracy in characterizing physical properties of RPV steels to establish correlations with RPV fracture toughness will provide important information for long-term operation. Cracking Precursors – The purpose of this task is to investigate and demonstrate the technical basis for, and feasibility of, advanced NDE methods for evaluation of cracking precursors. These activities will build on the current state-of-the-art in NDE and leverage advances occurring in non-nuclear applications. EAF – In parallel with research on long-term performance of reactor metals, techniques for NDE of key reactor metals are needed toward development of technologies to monitor material and component performance. This task follows the R&D plan developed in 2012 for sensor development to monitor reactor metal performance. In future years, sensor development will be performed with a demonstration of key prototypes. This ambitious date will require collaboration with other tasks within the LWRS Program and other programs and critical assessment and use of technologies from other industries. Validation and qualification of the sensors will be established and documented. Concrete – Techniques for NDE of concrete provide new technologies to monitor material and component performance. This task will build on an R&D plan developed in 2012 for sensor development to monitor reactor concrete performance. Key issues for consideration can include new or adapted techniques for concrete surveillance. Specific areas of interest may include reinforcing steel condition, chemical composition, strength, or stress state.
	Cabling – The objectives of this task include development and validation of new NDE technologies for the monitoring of cable insulation condition. This task will build on an R&D plan developed in 2012 for sensor development to monitor reactor metal performance. In future years, this research will include an assessment of key aging indicators; development of new and transformational NDE methods for cable insulation; and utilization of NDE signals and mechanistic knowledge from other areas of the LWRS Program to provide predictions of remaining useful life. A key element underpinning these three
LTO NDE	thrusts will be harvesting of aged materials for validation.
LTO – NDE	R&D Scope and Objectives: Identification and management of aging degradation for critical structures and components is fundamental to long-term operation. One-time inspections are specified to establish the extent of degradation; periodic inspections are specified as part of aging management programs. For quantitative and trendable results, NDE technology is used for these inspections. For some degradation mechanisms, in-situ online monitoring that employs NDE technology can provide quantitative and sometimes predictive results. These monitoring systems can have advantages over traditional periodic inspections (e.g., cost, accuracy, radiation exposure, and prognostic capability).
	The EPRI NDE program provides NDE technology, procedures, validation, and training for identified materials, mechanisms, components, and locations of concern. This process is on-going and robust and is expected to be effective for the life of the nuclear power plant, including subsequent license renewal periods.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
New Arren	Additionally, the NDE program continues to investigate new technologies that may provide enhanced detection and flaw characterization performance that may be incorporated into aging management programs. The LTO Program investigates opportunities to employ NDE technologies that can be installed for automatic, continuous, in-situ monitoring for certain identified aging degradation concerns. The investigations will include identification of parameters, design of sensors and sensor configurations, data capture and analysis, validation of the NDE/monitoring system, and demonstration of the process in an operational environment.
LWRS – NDE	 Milestones: RPV: (2017) Evaluate, research and develop microstructure characteristics throughout the RPV thickness to RPV NDE development. (2021) Demonstrate and deploy new or improved NDE technologies for RPV components. Cracking precursors: (2019) Complete capability demonstrations for crack precursor detection on prototypic materials. (2022) Complete demonstration of the technical basis and feasibility for use of crack precursor detection NDE, diagnostics, and prognostics for LWR long-term operation (60 to 80 years). EAF: (2019) Demonstrate key prototypes of fatigue damage NDE sensors in field test. (2022) Complete validation of fatigue damage NDE sensors. Concrete: (2016) Complete prototype proof-of-concept system for NDE of concrete sections. (2018) Complete prototype of concrete NDE system. Cabling: (2015) Complete assessment of cable insulation degradation precursors to
	 correlate with performance and NDE signals. (2017) Demonstrate field testing of prototype system for NDE of cable insulation. (2019) Deliver predictive capability for end of useful life for cable insulation.
LTO – NDE	 Milestones: (2014) Final report on application of in-situ monitoring (tendons at Ginna Nuclear Plant) of material degradation of passive assets. Joint milestone with Online Monitoring Project.

R&D Area	Advanced II&C Technologies
LWRS –	R&D Scope and Objectives:
International Collaborations (Halden Project)	The programs of the Halden Reactor Project extend to many aspects of nuclear power plant operations; however, the area of interest to this R&D program is the man-machine-technology research program that conducts research in the areas of computerized surveillance systems, human factors, and man-machine interaction in support of control room modernization. Halden has been on the cutting edge of new nuclear power plant technologies for several decades and their research is directly applicable to the capabilities being pursued under the pilot projects. In particular, Halden has assisted a number of European nuclear power plants in implementing II&C modernization projects, including control room upgrades. The II&C Pathway will work closely with Halden to evaluate their advanced II&C technologies to take advantage of the applicable developments. In addition to the technologies, the validation and human factors studies conducted during development of the technologies will be carefully evaluated to ensure similar considerations are incorporated into the pilot projects. INL has entered into a bilateral agreement in areas of research where collaborative efforts with Halden will accelerate development of the technologies associated with the pilot projects.
LTO – Halden	R&D Scope and Objectives:
Project	EPRI has established the Productivity Improvements through Advanced Technology Advisory Group. This group is looking at II&C enabled productivity improvements in nuclear power plants and is interacting closely with the LWRS Program's II&C Pathway, including a joint meeting held in August 2012. The Advanced Technology Advisory Group had the Halden Reactor Project give presentations in the June 2010 and April 2012 meetings. The intent is to identify opportunities to support productivity improvements in nuclear power plants, taking advantage of activities in Halden's Man-Machine-Technology Program. EPRI, as an associated member of the Halden Reactor Project, is providing input to Halden on their research activities in the man-machine-technology program.
LWRS –	Milestones:
International Collaborations (Halden Project)	(2011) Agreement between Halden and INL signed.
LTO – Halden	Milestones:
Project	EPRI membership is at a level above the specific LTO Program focus such that LTO-relevant R&D is evaluated on a case-by-case basis.

R&D Area	RISMC (see "Margins Analysis Techniques" for LWRS cooperative R&D)
LTO – Enhanced	R&D Scope and Objectives:
Risk Assessment and	To achieve successful long-term operations of the current fleet of operating
Management	nuclear power plants, it will be imperative that high levels of safety and
Capability	economic performance are maintained. Therefore, operating nuclear power
	plants will have a continuing need to undergo design and operational changes
	and manage aging degradation while simultaneously preventing the occurrence
	of safety significant events and analytically demonstrating improved nuclear
	safety. This portion of the EPRI LTO Program addresses the following two
	specific issues that are imperative to achieving these objectives:

R&D Area	RISMC (see "Margins Analysis Techniques" for LWRS cooperative R&D)
	(1) First, as the current fleet of operational nuclear power plants ages, it is anticipated that new challenges to plant safety will emerge. These challenges could be due to any number of causes such as a change in regulatory policy or the occurrence of an event at one or more operational nuclear power plants.
	(2) Second, as new technologies and capabilities become available, it will be desirable to take advantage of these opportunities to enhance nuclear power plant technical and economic performance. Examples of such enhancements could include performing extended power uprates or implementation of new technologies or materials.
	In each situation, a comprehensive and integrated assessment of the impact on nuclear safety will be required to support effective and efficient decision making.
	This research project will develop and validate enhanced risk assessment and management capabilities and tools. A critical element of this research effort will be to integrate the results obtained from the EPRI PHOENIX software development effort, which is being conducted to develop an advanced probabilistic risk assessment and configuration risk management integrated tool suite. This research effort will support development of PHOENIX by integrating risk management analytical capabilities that are necessary for nuclear power plant long-term operations (e.g., RISMC/Risk Informed Margin Management [RIMM]) and providing for the capability of the Phoenix software to link to the RELAP-7 software to permit its uses as a risk simulation tool. This project also provides significant interface and coordination of research efforts being conducted in safety analysis code development and safety margin analyses being performed by INL as part of the LWRS Program.
LTO – Enhanced	Milestones:
Risk Assessment and Management Capability	In previous years, this LTO research effort has supported the Phase 1 and Phase 2 portions of the PHOENIX research effort. A key milestone provided by this research was development of the PHOENIX functional requirements document and roadmap (EPRI Report 1019207). During 2013, a "beta" version of the Phoenix software was produced that concentrates on enhanced methods for configuration risk management applications. During 2014, the support of PHOENIX development, testing, and initial deployment will continue. The following activities are planned:
	• (2014) Since the basic Phoenix infrastructure has been developed and is being tested 2014 represents the first opportunity to have a more integrated interaction between the Phoenix/RAVEN/RELAP-7 development teams. The primary activity in 2014 will be to identify and prioritize the appropriate linkages to the Reactor Analysis and Virtual Control ENvironment (RAVEN) controller being developed for use in the interface with the RELAP-7 systems analysis code being developed by INL.
	• Initiate an evaluation of PHOENIX LTO for application to LTO-related issues and to integrate necessary capability development/external interfaces into the PHOENIX development plan.

4. LIGHT WATER REACTOR SUSTAINABILITY/LONG-TERM OPERATIONS COLLABORATIVE RESEARCH AND DEVELOPMENT ACTIVITIES

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
Reactor Metals	
LWRS – Mechanisms of IASCC	R&D Scope and Objectives: The objective of this work is to evaluate the response and mechanisms of IASCC in austenitic stainless steels with single-variable experiments. Crack growth rate tests and complementary microstructure analysis will provide a more complete understanding of IASCC by building on past EPRI-led work for the Cooperative IASCC Research Group ^g . Experimental research will include crack-growth testing on high-fluence specimens of single-variable alloys in simulated LWR environments, tensile testing, hardness testing, microstructural and microchemical analysis, and detailed efforts to characterize localized deformation. Combined, these single-variable experiments will provide mechanistic understanding that can be used to identify key operational variables to mitigate or control IASCC, optimize inspection and maintenance schedules to the most susceptible materials/locations, and, in the long-term, design IASCC-resistant materials.
LTO – IASCC: Identifying Mechanisms and Mitigation Strategies for IASCC of Austenitic Steels and LWR Core Components	 R&D Scope and Objectives: A better fundamental understanding of key parameters that affect IASCC is required to develop improved materials. For extended operation, IASCC is potentially a major failure mechanism that could impact the reliability of reactor core internal components due to higher fluence. The metallurgical modifications caused by neutron irradiation generally increase IASCC susceptibility of austenitic stainless steels. Currently, this long-term LTO project is co-funded by EPRI and DOE. The project work is performed by the University of Michigan. The objectives of this LTO project include the following: Full assessment of high-purity solute addition alloys and, in particular, the roles of C, Mo, Ti, Nb, Cr+Ni, and P on crack growth rate and crack initiation. Full assessment of the roles of commercial alloy microstructure on crack growth rate and crack initiation.
	 Linkage between irradiated microstructure and crack growth rate or crack initiation for solute addition and commercial alloys, as well as effects of cold work and dose. Relation between IASCC cracking susceptibility and neutron-irradiated alloys. Determination of the predictive capability of crack initiation due to proton irradiation by assessment against crack initiation due to neutron irradiation.

_

^g EPRI, "Final Review of the Cooperative Irradiation-Assisted Stress Corrosion Cracking Research Program," Product ID. 1020986, June 3, 2010.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
R&D Alea	Role of localized deformation on the IASCC susceptibility in
	neutron-irradiated materials. In addition to testing the neutron-irradiated stainless steels, the similar stainless steels irradiated to the similar fluence by proton irradiation will be tested by constant extension-rate tensile tests. The cracking susceptibilities associated with neutron irradiation and with proton irradiation will be cross compared. The role of localized deformation on IASCC susceptibility will be investigated. This LTO project is a 5-year effort that started in 2009. The scope of this LTO project can be summarized as investigating the following:
	Role of solutes in crack initiation
	Role of solutes in crack propagation
	Role of starting microstructure in crack initiation
	Role of starting microstructure in crack propagation
	• Effectiveness of proton irradiation in forecasting relative crack growth rate behavior
	Comparison of crack initiation following proton and neutron irradiation
	Comparison of crack initiation and crack growth in neutron-irradiated samples as a function of solute addition or starting microstructure
	Structure property relationship for neutron irradiated alloys
	Effect of alloy, alloy purity, heat, and dose on crack growth and crack initiation
	• Investigate whether small-volume mechanical testing can provide an alternate method of assessing IASCC susceptibility to enable potential strategy of retrieval and subsequent mechanical examination of materials from the field, in support of long-term operation
	Compile crack growth rate data on irradiated stainless steels from several EPRI and international programs and convene an expert panel to screen the available crack growth rate data on irradiated materials using appropriate screening criteria and recommend crack growth disposition curves for BWRs and PWRs to support current and long-term operation.
LWRS – Mechanisms of IASCC	Milestones: • (2017) Complete mechanistic testing for IASCC research.
	• (2019) Deliver predictive model capability for IASCC susceptibility.
	Detailed testing and specific subtasks will be based on the results of the previous years testing, as well as ongoing, industry-led research. Understanding the mechanism of IASCC will enable more focused material inspections, material replacements, and more detailed regulatory guidelines. In the long-term, mechanistic understanding also enables development of a predictive model, which has been sought for IASCC for decades.
LTO – IASCC: Identifying Mechanisms and Mitigation Strategies	Milestones: • (2014) Report on key factors in IASCC initiation and propagation of austenitic alloys in core internals and mitigation measures that could minimize IASCC in current LWR stainless steel components.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
for IASCC of Austenitic Steels and LWR Core	(2014) Report on improved IASCC crack growth prediction models for BWRs and PWRs. (2016) Report of IASCC crack growth prediction models for BWRs and PWRs.
Components	• (2018) Report on IASCC-resistant materials for repair and replacement.
Concrete	
LWRS - Concrete	R&D Scope and Objectives:
	Large areas of most nuclear power plants have been constructed using concrete and there are some data on performance through the first 40 years of service. In general, the performance of reinforced concrete structures in nuclear power plants has been very good. Although the vast majority of these structures will continue to meet their functional or performance requirements during the current and any future licensing periods, it is reasonable to assume that there will be isolated examples where, primarily as a result of environmental effects, the structures may not exhibit the desired durability (e.g., water-intake structures and freezing/thawing damage of containments) without some form of intervention.
	Although a number of organizations have sponsored work addressing the aging of nuclear power plant structures (e.g., NRC, Nuclear Energy Agency, and International Atomic Energy Agency), there are still several areas where additional research is desired to demonstrate that the structures will continue to meet functional and performance requirements (e.g., maintain structural margins). Activities under the MAaD Pathway are focused on compilation of material property data for long-term performance and trending, evaluation of environmental effects, and assessment and validation of NDE methods; evaluation of long-term effects of elevated temperature and radiation; non-intrusive methods for inspection of thick, heavily-reinforced concrete structures and basemats; and data on application and performance (e.g., durability) of repair materials and techniques.
	Complementary activities are being conducted under an NRC program at Oak Ridge National Laboratory, by EPRI, and by the Nuclear Energy Standards Coordination Collaborative headed by the National Institute for Standards and Technology.
	To support these activities, a detailed and populated database on concrete performance, with data for performance into the first life-extension period, high-temperature effects, and irradiation effects, will be delivered by 2016. Plans for research at EPRI and NRC will continue to be evaluated to confirm the complementary and cooperative nature of concrete research under the MAaD Pathway. In addition, the formation of an Extended Service Materials Working Group for concrete issues will provide a valuable resource for additional and diverse input.
LTO –	R&D Scope and Objectives:
Comprehensive Aging Management of Concrete Structures	Adequate understanding and (where necessary) inspection techniques of concrete civil infrastructure in commercial nuclear power plants is an essential need for comprehensive decision making for long-term operation. There are a variety of kinetic processes that can lead to degradation of civil structures and these may be accelerated by operating environments specific to nuclear power

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
	plants. It is important that industry understand the impact of accelerated aging of civil infrastructure, particularly for LTO, as individual utilities will be required to provide both sound technical and economic justifications for long-term operation.
	The interim goal of this project is to create a project that looks at various degradation phenomena being experienced in operating nuclear power plants. The initial stage of the project compiled an Aging Reference Manual, which defined the physics of kinetic degradation processes and discussed operational issues dealt with by the industry over the past 40+ years. The manual contains a framework for identifying at-risk structures and applicable degradation mechanisms. Building upon this, a number of individual research projects, aimed at further understanding of those degradation mechanisms and structures identified as "at-risk," will be commenced. The results of the individual studies will be merged into an Aging Management Toolbox Platform, which will be an open-ended tool for operators to assess the severity of damage and explore repair or mitigation options. It is anticipated that this investigation will yield one or more industry examination guidelines for a concrete aging assessment. Key areas of research will cover aging degradation due to irradiation and thermal environments, risks and impact of alkali silica reaction (ASR), and assessment of nuclear power plant risks due to concrete creep effects. Related work covering spent fuel pools, including boric acid corrosion assessment, will be addressed.
LWRS – Concrete	 Milestones: (2016) Complete detailed and populated database on concrete performance, with data for performance into the first life-extension period, high temperature effects and irradiation effects.
	• (2018) Complete concrete and civil infrastructure toolbox development with EPRI and Materials Aging Institute partners.
	Future milestones and specific tasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. The database of concrete performance completed in 2013 is a high-value tool accessible to all stakeholders and is being used to focus research on the remaining knowledge gaps and will enable more focused material inspections. In the long-term, completion of a concrete and civil structures toolkit may allow for more robust prediction of concrete performance over extended service conditions. These tools are of high value to industry, a partner in their development.
LTO –	Milestones:
Comprehensive Aging Management of Concrete Structures	• (2014) Initial report on preliminary findings of the effect of irradiation damage on reactor cavity concrete.
Concrete Structures	• (2013) Containment aging pilot plant investigation Outage 2011 and Outage 2012 reports (results of destructive examination/NDE at Ginna and Nine Mile Point); industry guideline(s) for examination of structures for concrete aging.
	• (2014) Literature review of creep in concrete
	• (2015) Report on experimental study of the effects of boric acid corrosion

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
	on concrete. • (2015) Report on risk screening for ASR in concrete structures in existing plants
	 (2016) Report on radiation damage effects on concrete. (2018) Complete concrete and civil infrastructure toolbox development
Cabling	with DOE and Materials Aging Institute partners.
Cabling LWRS – Cabling	
LWKS - Cabing	R&D Scope and Objectives: Cable aging mechanisms and degradation is an important area of study. The nuclear power plant operators carry out periodic cable inspections using NDE techniques to measure degradation and determine when replacement is needed. Degradation of these cables primarily is caused by long-term exposure to high temperatures. Additionally, stretches of cables that have been buried underground are frequently exposed to groundwater. Wholesale replacement of cables is likely economically undesirable for nuclear power plant operation beyond 60 years.
	This task provides an understanding about the role of material type, history, and the environment on cable insulation degradation; understanding of accelerated testing limitations; and support to partners in modeling activities, surveillance, and testing criteria. This task will provide experimental characterization of key forms of cable and cable insulation in a cooperative effort with NRC and EPRI. Tests will include evaluations of cable integrity following exposure to elevated temperature, humidity, and/or ionizing irradiation. These experimental data will be used to evaluate mechanisms of cable aging and determine the validity or limitations of accelerated aging protocols. The experimental data and mechanistic studies can be used to help identify key operational variables related to cable aging, optimize inspection and maintenance schedules to the most susceptible materials/locations, and, in the long-range, design tolerant materials.
LTO – Advanced	R&D Scope and Objectives:
Cable Testing Technology for Life- Cycle Management of Cables	In 2014, a report will be issued with results on the advanced cable testing work that was performed in 2012 and 2013 into online partial discharge monitoring of medium voltage cable. In the area of cable life-cycle management, a follow-up to the 2013 research to identify actual containment temperature and dose conditions in actual cable locations will continue. The 2013 collection of data did support the belief that cables see only a fraction of the dose used for environmental qualification, but the data could not be correlated to actual cable locations. A means of gathering actual data at various cable locations at representative boiling and pressurized reactors will be pursued to further clarify expected cable exposure through subsequent license renewal. The second major research area in 2014 will be evaluation of existing research data for cables that make up roughly 90% of those used in the U.S. operating fleet of nuclear power plants. The purpose is to identify gaps in aging curves (thermal and thermal + radiation) that would be needed to quantify remaining cable useful life. Those cables needing development of aging curves versus an appropriate condition monitoring technology will be identified. This may identify a need for service aged cables to be harvested from nuclear power plants either being

Dan t	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
	decommissioned or operating so that this research can be carried out. Associated work of interest to LTO is being funded by EPRI's Plant Engineering group to develop the technical basis for aging management and life-cycle management of cable systems.* Specifically, EPRI is performing a submergence qualification for Kerite ethylene propylene rubber insulation and plans are to add pink Okonite ethylene propylene rubber to the project this year. An aging acceleration regime is being attempted in this project using high frequency (i.e., 450 Hz and 900 Hz) along with 2.5 times line voltage. Additionally, research on medium voltage water-related degradation is continuing in 2014 to identify causes of insulation breakdown. Analysis of member-provided Tan δ data and EPRI recommended acceptance criteria has been validated to classify the degree of wet cable insulation degradation. Further analysis will be done that may provide insight into rates of degradation and perhaps remaining life predictability. EPRI's Plant Engineering group continues to support aging management implementation through the cable user group meetings. All of these projects support identifying cable system aging management activities, the portions of the cable system having limited life, and data and methods for life-cycle management of aging cable systems. Enhanced testing and end-of-life predictive methods will continue to be investigated. * Cable systems include the field cables, their terminations and splices, and local wiring, as well
LWRS – Cabling	 as the support and protective systems such as trays, conduits, and ducts. Milestones: (2014) Complete analysis of key degradation modes of cable insulation. (2015) Complete assessment of cable degradation mitigation strategies. (2017) Deliver predictive model for cable degradation. Future milestones and specific tasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. Completing research to identify and understand the degradation modes of cable insulation is an essential step to predicting the performance of cable insulation under extended service conditions. These data are critical to develop and deliver a predictive model for cable insulation degradation. Both will enable more focused inspections, material replacements, and better informed regulations. The development of in-situ mitigation strategies also may allow for an alternative to cable replacement and would be of high value to industry by avoiding costly replacements.
LTO – Advanced	Milestones:
Cable Testing Technology for Life- Cycle Management of Cables	 (June 2014) Assessment of online continuous differential partial discharge test for medium voltage cable has been completed and a report will be issued on the results. (2014) Determine containment cable temperature and radiation levels for representative, current nuclear power plants for input into cable aging
	research. • (2014) Assess existing cable aging research data for major cable types and identify research gaps for cables needed to be addressed to qualify condition and remaining useful life.

202	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
Mitigation Strategies	
LWRS – Advanced Weld Repair	R&D Scope and Objectives: The objective of this task is to develop advanced welding technologies that can be used to repair highly irradiated reactor internals without helium-induced cracking. This is being performed collaboratively with EPRI. Research includes mechanistic understanding of helium effects in weldments. This modeling task is supported by characterization of model alloys before and after irradiation and welding. This model can be used by stakeholders to further improve best practices for repair welding for both existing technology and advanced technology. In addition, this task will provide validation of residual stress models under development using advanced characterization techniques such as neutron scattering. Residual stress models also will improve best practices for weldments of reactors today and under extended service conditions. These tools could be expanded to include other industry practices such as peening. Finally, advanced welding techniques (such as friction-stir welding, laser welding, and hybrid techniques) will be developed and demonstrated on relevant materials (model and service alloys). Characterization of the weldments and qualification testing will be an essential step.
LTO – Advanced	R&D Scope and Objectives:
Welding Methods for Irradiated Materials	As the existing LWR fleet ages, the weldability of the structural material used to construct the RPVs and reactor internals may be diminished. The decrease in weldability is caused by formation of helium in the base material structure. This is caused by nuclear transmutation reactions of boron and nickel within the reactor materials and increases as neutron fluence accumulates. Helium-induced weld cracking is a complex phenomenon that is related to the concentration of helium in the material, heat input of the welding technique used, and stresses during cooling of the weld. Modest improvement in the weldability of irradiated material can be achieved by lowering the heat input using conventional laser beam welding, but once stainless steel components reach a certain fluence (typically at 20 to 30 years of exposure), some may be welded by current welding methods. As nuclear power plants age further (40 years and beyond) consideration of the embrittlement effect of helium on weld repair becomes critical. The development of advance welding processes (hybrid fusion and solid state) is needed to extend the weldability of these irradiated reactor components. There is significant justification for development of advanced welding methods to repair irradiated reactor materials. However, development of advanced welding processes for repair of irradiated reactor components is a relatively complex task and will take both fundamental research related to welding of irradiated materials and refinement of existing welding technologies. This is a relatively long-lead-time development process and research needs to be started now if welding repair options are to be available for reactor material and internals as they age and require repair or replacement. Expected work includes the following: • Perform review and prepare summary report on advanced welding processes and the potential application for welding of irradiated reactor components in the underwater environment.

R&D Area	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and Mitigation of Primary System Aging Degradation (LTO)
R&D Area	 Mitigation of Primary System Aging Degradation (LTO) Prepare a detailed project plan for the multi-year project: Sample irradiation plan Welding hot cell design/fabrication/installation Advanced welding equipment technical requirements and procurement specification Welding experiments to benchmark models and provide process development/refinement Budgeting and detailed task planning Design and procurement of stainless steel sample set for irradiation. Project tasks are funded by the LTO Program and the DOE LWRS Program, with some tasks being co-funded. LTO-related work supported by the LWRS Program is performed at Oak Ridge National Laboratory. The Oak Ridge National Laboratory scope will focus on development of fundamental science for developing predictive models and simulations for advanced welding processes and measurement of residual stress at high temperatures. Oak Ridge National Laboratory has the following facilities to achieve the project goals: High-Flux Isotope Reactor – Irradiation of the sample set will occur at this facility, as well as potential measurement of residual stresses at high temperature. Material Process Hot Cell – Welding of irradiated material requires facilities that can remotely handle radioactive materials.
	Advanced Microstructure Characterization Laboratory – Examination of radioactive material at the sub-grain level is a unique capability of Oak Ridge National Laboratory.
LWRS – Advanced Weld Repair	 Milestones: (2015) Demonstrate initial solid-state welding on irradiated materials. (2018) Complete transfer of weld-repair technique to industry. Future milestones and specific tasks will be based on the results of the previous years' testing, as well as ongoing, industry-led research. Demonstration of advanced weldment techniques for irradiated materials is a key step in validating this mitigation strategy. Successful deployment also may allow for an alternative to core internal replacement and would be of high value to industry by avoiding costly replacements. Further, these technologies also may have utility in repair or component replacement applications in other locations within a nuclear power plant.

	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
LTO – Advanced Welding Methods for	Milestones: • (2013) Completed sample set fabrication.
Irradiated Materials	• (2013) EPRI technical update report on project status and results.
	• (2014) Initial irradiation campaign for sample set.
	• (2014) Complete fabrication of welding cubicle.
	• (2015) Installation of welding cubicle at Oak Ridge National Laboratory.
	• (2015) Initial welding experiments on irradiated material sample set.
LWRS – Advanced Replacement Alloys	R&D Scope and Objectives: Advanced replacement alloys provide new alloys for use in LWR applications that may provide greater margins and performance and support to industry partners in their programs. This task will explore and develop new alloys in collaboration with the EPRI Advanced Radiation-Resistant Materials Program. Specifically, the LWRS Program will participate in expert panel groups to develop a comprehensive R&D plan for these advanced alloys. Future work will include alloy development, alloy optimization, fabrication of new alloys, and
	evaluation of their performance under LWR-relevant conditions (e.g., mechanical testing, corrosion testing, and irradiation performance among others) and, ultimately, validation of these new alloys. Based on past experience in alloy development, an optimized alloy (composition and processing details) that has been demonstrated in relevant service conditions can be delivered to industry by 2020.
LTO – Advanced	R&D Scope and Objectives:
Radiation-Resistant Materials Program	EPRI has initiated a new international collaborative project with DOE on development of radiation-resistant materials for LWR applications. EPRI and DOE have jointly prepared a comprehensive report on the state of current knowledge of radiation-induced degradation in LWRs and a roadmap to develop and qualify more radiation-resistant materials. The report was prepared by a team of world-class experts and widely reviewed by the international research community. The roadmap will be used to formulate a long-range R&D plan to develop improved materials for long-term operation of current and new nuclear power plants.
LWRS – Advanced Replacement Alloys	 Milestones: (2014) Deliver characterization of select as-received advanced alloys as part of joint efforts on Advanced Radiation Resistant Materials effort.
	Future milestones and specific tasks will be informed by EPRI's Advanced Radiation Resistant Materials plan that was released in 2013 and joint assessment of partnerships and available funding. Completing the joint effort with EPRI on the alloy down-select and development plan is an essential first step in this alloy development task. This plan will help identify future roles and responsibilities in this partnership with EPRI.
LTO – ARRM	Milestones: • (2015) Interim report on the results of Phase 1, documenting the results of microstructural, mechanical, and SCC studies on proton-irradiated commercial alloys to identify promising materials for further evaluation in

DOD A	Materials Aging and Degradation (LWRS)/Understanding, Prediction, and
R&D Area	Mitigation of Primary System Aging Degradation (LTO)
	 Phase 2. (2017) Final report on the results of Phase 1, recommending alloys for further evaluation under neutron irradiation. (2019) Interim report on the results of Phase 2, documenting microstructural, mechanical, and SCC studies on neutron-irradiated commercial and advanced alloys. (2022) Final report on the results of Phase 2, identifying one or two radiation-resistant commercial alloys for LWR internals.
LWRS –	R&D Scope and Objectives:
Constellation ^h	The Constellation Pilot Project is a joint venture between the LWRS Program,
Demonstration	EPRI, and the Constellation Energy Nuclear Group. The project utilizes two of
Project	Constellation's nuclear stations, R. E. Ginna and Nine Mile Point 1, for research opportunities to support extended operation of nuclear power plants. Specific
	areas of joint research have included development of a concrete inspection
	guideline, installation of equipment for monitoring containment rebar and
	concrete strain, and additional analysis of RPV surveillance coupons. A
	document describing containment inspection guidelines for extended service was
	developed in 2013. Opportunities for additional and continued collaboration will
	be explored in the coming years.
LTO – Ginna and	R&D Scope and Objectives:
Nine Mile Point	The Nuclear Plant Life Extension Project was jointly undertaken by EPRI, DOE,
Unit 1 Demonstration	and Constellation Energy Nuclear Group to assess aging degradation behavior at
Plant Activities	the Ginna and Nine Mile Point Unit 1 nuclear power plants. Both plants are
	operating beyond 40 years. Specific efforts began in 2010 and were focused on containment, reactor internals, and RPVs. Results are documented in a series of
	technical reports. The project is slated to conclude in 2014.
LWRS –	Milestones:
Constellation	None.
Demonstration	TVOIIC.
Project	
LTO – Ginna and	Milestones:
Nine Mile Point	Demonstration activities on comprehensive containment examination:
Unit 1 Demonstration	• (2013) Comprehensive Containment Guideline.
Plant Activities	
	• (2014) Final Report on Containment Tendon Monitoring Project using fiber optic strain gauges.
	• (2014) Report on Containment Temperature Monitoring at Ginna using Self-Powered Thermocouples
	Incremental inspection and examination of RPVs:
	• (2013) Final Reactor Internals and Vessel Assessment.

R&D Area	Advanced II&C Technologies
LWRS – New	R&D Scope and Objectives:
Instrumentation and	This research program will address aging and long-term reliability issues of the

-

^h Ownership of the plants hosting the demonstration project has been transferred from Constellation to Exelon.

R&D Area	Advanced II&C Technologies
Control and Human System Interfaces and Capabilities (including Advanced II&C Pilot Projects)	legacy II&C systems used in the current LWR fleet by demonstrating new technologies and operational concepts in actual nuclear power plant settings. This approach drives the following two important outcomes:
	 Reduces the technical, financial, and regulatory risk of upgrading the aging II&C systems to support extended nuclear power plant life to and beyond 60 years. Provides the technological foundation for a transformed nuclear power plant operating model that improves plant performance and addresses the challenges of the future business environment.
	The research program is being conducted in close cooperation with the nuclear utility industry to ensure that it is responsive to the challenges and opportunities in the present operating environment. The scope of the research program is to develop a seamless integrated digital environment as the basis of the new operating model.
	The program is advised by a Utility Working Group composed of leading nuclear utilities across the industry and EPRI. The Utility Working Group developed a consensus vision of how a more integrated approach to modernizing nuclear power plant II&C systems could address a number of challenges to the long-term sustainability of the LWR fleet. A strategy was developed to transform the nuclear power plant operating model by first defining a future state of plant operations and support based on advanced technologies and then developing and demonstrating the needed technologies to individually transform the plant work activities. The collective work activities were grouped into the following major areas of enabling capabilities:
	1. Human performance improvement for nuclear power plant field workers
	2. Outage safety and efficiency
	3. Online monitoring and information integration
	4. Integrated operations
	5. Automated nuclear power plant
	6. Hybrid control room.
	In each of these areas, a series of pilot projects are planned that enable the development and deployment of new II&C technologies in existing nuclear power plants. A pilot project is an individual demonstration that is part of a larger strategy needed to achieve modernization according to a plan. Note that pilot projects have value on their own, as well as collectively. A pilot project is small enough to be undertaken by a single utility, it demonstrates a key technology or outcome required to achieve success in the higher strategy, and it supports scaling that can be replicated and used by other nuclear power plants. Through the LWRS Program, individual utilities and nuclear power plants are able to participate in these projects or otherwise leverage the results of projects conducted at demonstration plants.

ⁱ Long-Term Instrumentation, Information, and Control Systems (II&C) Modernization Future Vision and Strategy, INL/EXT-11-24154, Revision 3, November 2013.

R&D Area	Advanced II&C Technologies
	The pilot projects conducted through this program serve as stepping stones to achieve longer-term outcomes of sustainable II&C technologies. They are designed to emphasize success in some crucial aspect of nuclear power plant technology refurbishment and sustainable modernization. They provide the opportunity to develop and demonstrate methods to technology development and deployment that can be broadly standardized and leveraged by the commercial nuclear power fleet. Each of the R&D activities in this program achieves a part of the longer-term goals of safe and cost-effective sustainability. They are limited in scope so they can be undertaken and implemented in a manner that minimizes technical and regulatory risk. In keeping with best industry practices, prudent change management dictates that new technologies are introduced slowly so that they can be validated within the nuclear safety culture model.
LTO – Requirements Database for Advanced I&C, Human System Interface, and Information Technology	R&D Scope and Objectives: EPRI will participate in the LWRS working group for Advanced II&C. This working group includes utility representatives from Exelon, Entergy, Duke, Southern, STP, APS, Constellation, Progress, TVA, and the STARS Alliance. Through the working group, the LWRS Program is sponsoring pilot studies of advanced applications of I&C and other information technology projects at individual utilities. The LWRS Program also has developed a Human Systems Simulation Laboratory to support these applications and to perform related R&D at INL. The Human Systems Simulation Laboratory employs 15 bench-board-style touch panels that resemble the control panels currently used in nuclear power plants. This equipment is capable of running nuclear power plant simulators to produce a high-fidelity control room environment for control room modernization R&D. EPRI will participate in these activities on behalf of the LTO project membership. EPRI will interact with the working group on the LTO requirements database activities. EPRI is making relevant EPRI technical reports available to INL for work in the LWRS Advanced II&C area.
LWRS – New Instrumentation and Control and Human System Interfaces and Capabilities (including advanced II&C pilot projects)	 Milestones: Human performance improvement for nuclear power plant field workers: (2014) Develop a requirements specification for an automated work package prototype. (2015) Develop automated work package prototype technologies for work processes with associated study of field trials at a nuclear power plant. (2016) Develop human factors evaluations and an implementation strategy for deploying automated field activity work packages built on mobile technologies, resulting in more efficient and accurate plant work processes, adherence to process requirements, and improved risk management. (2017) Develop and demonstrate augmented reality technologies for visualization of radiation fields for mobile plant workers. (2018) Develop and demonstrate augmented reality technologies for visualization of real-time plant parameters (e.g., pressures, flows, valve positions, and restricted boundaries) for mobile plant workers. (2019) Publish a technical report on augmented reality technologies developed for nuclear power plant field workers, enabling them to visualize abstract data and invisible phenomena, resulting in significantly improved situational awareness, access to context-based plant information, and generally improved effectiveness and efficiency in conducting field work

R&D Area	Advanced II&C Technologies
	activities.
	 Outage safety and efficiency: (2014) Develop human factors studies and publish a technical report for an advanced outage control center that is specifically designed to maximize the usefulness of communication and collaboration technologies for outage coordination, problem resolution, and outage risk management. (2015) Develop enhanced information displays for the advanced OCC that improves decision-making and safety requirements awareness. This will include display of real-time operations and plant configuration data. (2016) Develop and demonstrate (in the Human Systems Simulation Laboratory) technologies for detecting interactions between plant status (configuration) states and concurrent component manipulations directed by in-use procedures, in consideration of regulatory requirements, technical specifications, and risk management requirements (defense-in-depth). (2017) Develop and demonstrate (in the Human Systems Simulation Laboratory) technologies to detect undesired system configurations based on concurrent work activities (e.g., inadvertent drain paths and interaction of clearance boundaries). (2018) Develop a real-time outage risk management strategy and publish a technical report to improve nuclear safety during outages by detecting configuration control problems caused by work activity interactions with changing system alignments.
	 Integrated operations: (2019) Develop a digital architecture and publish a technical report for an advanced online monitoring facility, providing long-term asset management and providing real-time information directly to control room operators, troubleshooting and root cause teams, suppliers and technical consultants involved in component support, and engineering in support of the system health program. (2019) For chemistry activities, conduct a study and publish a technical report on opportunities to provide remote services from centralized or third-party service providers, based on advanced real-time communication and collaboration technologies built on the digital architecture for a highly automated plant. Demonstrate representative remote activities with a host plant. (2020) For maintenance activities, conduct a study and publish a technical report on opportunities to provide remote services from centralized or third-party service providers, based on advanced real-time communication and collaboration technologies built on the digital architecture for a highly automated plant. Demonstrate representative remote activities with a host plant. (2021) For radiation protection activities, conduct a study and publish a technical report on opportunities to provide remote services from centralized or third-party service providers, based on advanced real-time communication and collaboration technologies built on the digital architecture for a highly automated plant. Demonstrate representative remote activities with a host plant.

D 0 D 4	Advanced HOCT charles a
R&D Area	Advanced II&C Technologies
	 (2022) Publish human and organizational factors studies and a technical report for a virtual plant support organization technology platform consisting of data sharing, communications (voice and video), and collaboration technologies that will compose a seamless work environment for a geographically dispersed nuclear power plant support organization. (2025) Publish human and organizational factors studies and a technical report for a management decision support center consisting of advanced digital display and decision-support technologies, thereby enhancing nuclear safety margin, asset protection, regulatory performance, and production success.
	Automated plant:
	 Automated plant: (2015) Publish a technical report that provides a current state and gap analysis for integrating plant information residing in plant II&C systems, plant work processes, and information resources needed for mobile worker technologies. (2017) Publish a technical report on an advanced digital architecture, integrating plant systems, plant work processes, and plant workers in a seamless digital environment, with guidance on how to apply the architecture to a nuclear power plant's established data network systems. (2018) For nuclear power plant chemistry activities, analyze the staffing, tasks, and cost models to identify the opportunities for application of digital technologies to improve nuclear safety, efficiency, and human performance based on optimum human-technology function allocation. Demonstrate representative activities as transformed by technology with results published in a technical report. (2019) For nuclear power plant maintenance activities, analyze the staffing, tasks, and cost models to identify the opportunities for application of digital technologies to improve nuclear safety, efficiency, and human performance, based on optimum human-technology function allocation. Demonstrate representative activities as transformed by technology with results published in a technical report. (2020) For nuclear power radiation protection activities, analyze the staffing, tasks, and cost models to identify the opportunities for application of digital technologies to improve nuclear safety, efficiency, and human performance based on optimum human-technology function allocation. Demonstrate representative activities as transformed by technology with results published in a technical report. (2020) Develop and publish a transformed nuclear power operating model and organizational design derived from a top-down analysis of plant
	 operational and support activities, quantifying the efficiencies that can be realized through highly automated plant activities using advanced digital technologies. (2025) Develop the strategy and priorities and publish a technical report for automating operator control actions for important plant state changes, transients, and power maneuvers, resulting in nuclear safety and human performance improvements founded on engineering and human factors principles.

D & D A was	Advanced H & C Technologies
R&D Area	Hybrid control room: (2016) Publish a technical report for computer-based procedures that enhance worker productivity, human performance, plant configuration control, risk management, regulatory compliance, and nuclear safety margin. (2016) Develop an end-state vision and strategy, based on human factors engineering principles, for the implementation of an advanced hybrid control room as new digital technologies and operator interface systems are introduced into traditional control rooms. (2016) Publish a technical report for an advanced alarm management system in a nuclear power control room and a methodology for integrating diverse alarms and annunciators across all systems and digital platforms. (2019) Develop an operator advisory system fully integrated into a control room simulator that provides plant steady-state performance monitoring, diagnostics and trending of performance degradation, operator alerts for intervention, and recommended actions for problem mitigation, with application of control room design and human factors principles. (2021) Develop an end-state vision and implementation strategy for an advanced computerized operator support system, based on an operator advisory system that provides real-time situational awareness, prediction of the future plant state based on current conditions and trends, and recommended operator interventions to achieve nuclear safety goals. (2022) Complete a technical report on operator attention demands and limitations on operator activities based on the current conduct of operations protocols. This report will identify opportunities to maximize operator efficiency and effectiveness with advanced digital technologies. (2025) Develop validated future concepts of operations for improvements in control room protocols, staffing, operator proximity, and control room management, enabled by new technologies that provide mobile information and control capabilities and the ability to interact with other control centers (e.g., emergency response facilities for sever
LTO – Requirements Database for Advanced I&C, Human System Interface, and Information Technology	 Milestones: Summary Report on Database Structure Capability Levels and Simple Prototype (2013). The following deliverables will be jointly developed by LWRS and LTO and are listed identically as milestones for each program: (2014) Publish guidelines for developing a human factors engineering program for an operating nuclear plant. (2015) Publish interim guidelines to implement technologies for improved outage safety and efficiency. (2016) Publish revised interim guidelines to implement technologies for human performance improvement for nuclear power field workers. (2018) Publish interim guidelines to implement technologies for a hybrid control room. (2018) Publish final guidelines to implement technologies for improved outage safety and efficiency.

R&D Area	Advanced II&C Technologies
Reco Arrea	 (2019) Publish final guidelines to implement technologies for human performance improvement for nuclear power field workers. (2020) Publish interim guidelines to implement technologies for integrated operations. (2021) Publish interim guidelines to implement technologies for an automated plant (2021) Publish revised interim guidelines to implement technologies for a hybrid control room. (2022) Publish revised interim guidelines to implement technologies for integrated operations. (2025) Publish final guidelines to implement technologies for an automated plant. (2025) Publish final guidelines to implement technologies for integrated operations.
	• (2025) Publish final guidelines to implement technologies for a hybrid control room.
LWDC Controlled	
LWRS – Centralized Online Monitoring and Information Integration	R&D Scope and Objectives: As nuclear power plant systems begin to be operated during periods longer than originally licensed, the need arises for more and better types of monitoring of material and component performance. This includes the need to move from periodic, manual assessments and surveillances of physical components and structures to centralized online condition monitoring. This is an important transformational step in the management of nuclear power plants. It enables real-time assessment and monitoring of physical systems and better management of components based on their performance. It also provides the ability to gather substantially more data through automated means and to analyze and trend performance using new methods to make more informed decisions concerning long-term nuclear power plant asset management. Of particular importance will be the capability to determine the remaining useful life of a component to justify its continued operation over an extended nuclear power plant life.
	Working closely with the MAaD Pathway and EPRI, this pathway will develop technologies to complement sensor development and monitoring of materials to assess the performance of SSC materials during long-term operation for purposes of decision making and asset management. The MAaD Pathway would be responsible for developing the scientific basis for modeling the degradation mechanisms and determining the types of sensors needed to monitor the degradation.
LTO – Centralized	R&D Scope and Objectives:
Online Monitoring	To achieve continued safe and economical long-term operation of the U.S. domestic and international nuclear power plants, it will be imperative that nuclear power plants maintain high levels of operational performance and efficiency. Nuclear power plants have a continuing need to undergo design and operational changes, as well as manage aging SSCs. Effective management of SSCs will require integration of advanced information monitoring and analysis capabilities into nuclear power plant operations, maintenance, and engineering activities.

R&D Area	Advanced II&C Technologies
	Centralized online monitoring is a highly automated condition analysis and asset management system designed to capture and build in knowledge, experience, and intelligence from many diversified operating systems and monitoring environments. Domestic nuclear power plants can be described as having constrained resources to support programs not required for direct plant operation or regulatory issues. These constraints dictate that a comprehensive online monitoring capability will be an evolutionary development determined by the functional capabilities needed to support current operational requirements and to provide for long-term asset management. A key functional requirement of a well-developed monitoring program is its information interface with the operating nuclear power plant and associated staff.
	To achieve the stated strategic goals of EPRI's LTO project, industry must develop an effective monitoring program that has a well-designed data and information integration platform with advanced technologies, including anomaly detection; automated diagnostic capabilities; a repository of equipment failure signatures captured from industry events; and, ultimately, prognostics-remaining useful life capabilities designed to evaluate critical nuclear power plant assets for optimized maintenance and investment decisions to support LTO. EPRI's research will build on previously developed monitoring technologies and leverage the LTO resources with our strategic partners. The EPRI LTO project completed an in-depth industry analysis of monitoring capabilities and identified the needed analytical and programmatic capabilities (gap analysis). These results provide the foundation to define project priorities, identify needed technologies, project the costs and schedule, obtain required funding to execute the research, and manage all the implementation phases through successful implementation. In support of implementation of nuclear power plant monitoring programs, EPRI has published comprehensive centralized online monitoring implementation guidelines, based on current state-of-the-art diagnostics and prognostics technology developed by EPRI, with guidance based on early adopter and generations experience from the power industry's operational monitoring centers.
	The development and execution of the required research must include broad and frequent interfacing with all of EPRI's strategic partners, including member advisors and technical specialists and their commercial support organizations. Other partners include qualified vendors, universities, government laboratories, and utility research programs.
LWRS – Centralized Online Monitoring and Information Integration	 Milestones: (2017) Publish a technical report on measures, sensors, algorithms, and methods for monitoring active aging and degradation phenomena for a large passive plant component/structure, involving NDE-related online monitoring technology development and including the diagnostic and prognostic analysis framework to support utility implementation of online monitoring for the component type. (2019) Publish a technical report on measures, sensors, algorithms, and methods for monitoring active aging and degradation phenomena for second large passive plant component structure, involving NDE-related online monitoring technology development and including the diagnostic and prognostic analysis framework to support utility implementation of online monitoring for the component type.

R&D Area	Advanced II&C Technologies
LTO – Centralized	Milestones:
Online Monitoring	• (2014) Complete EPRI prognostics and health management software installation at the pilot plant utilities.
	• (2014) Proof-of-concept applications of in-situ monitoring of material degradation of passive assets.
	• (2014) Production release of EPRI's prognostics and health management software and access to the associated databases.
	• (2014) Complete joint research on diagnostics and prognostics (remaining useful life) application to critical plant assets.
	• (2015) Pilot applications of in-situ monitoring of material degradation of passive assets.
	• (2015) Publish interim guidelines to implement technologies for centralized online monitoring and information integration.
	• (2017) Complete transient analysis R&D.
	• (2018) Publish final guidelines to implement technologies for centralized online monitoring and information integration.
LWRS – Industrial	R&D Scope and Objectives:
and Regulatory Engagement	Nuclear asset owner engagement is a necessary and enabling activity to obtain data and accurate characterization of long-term operational challenges, assess the suitability of proposed research for addressing long-term needs, and gain access to data and representative infrastructure and expertise needed to ensure success of the proposed R&D activities. Engagement with vendors and suppliers will ensure that vendor expectations and needs can be translated into requirements that can be met through technology commercialization.
	To ensure appropriate transfer of technology to the nuclear power industry, guidelines documents will be published for each of the areas of enabling capabilities, incorporating the specific technologies and technical reports produced under each of the pilot projects for the respective areas. EPRI has agreed to assume responsibility for development and publication of these guidelines, using their standard methods and utility interfaces to develop the documents and validate them with industry. The LWRS Program's Advanced II&C Systems Technologies Pathway will support this effort by providing the relevant information and participating in the development activities.
LTO – Requirements	R&D Scope and Objectives:
Database for Advanced I&C, Human System Interface, and Information Technology	EPRI will develop a repository of advanced I&C, human system interface, and other information technology requirements and good practices from the pilot studies and from other industry activities. The purpose of this repository is to have a living resource for utilities to review state-of-the-art and good practices in the industry related to I&C enhancement projects.
LWRS – Industrial	Milestones:
and Regulatory Engagement	• (2018) Publish final guidelines to implement technologies for improved outage safety and efficiency.
	• (2019) Publish final guidelines to implement technologies for centralized

R&D Area	Advanced II&C Technologies
	online monitoring and information integration.
	• (2019) Publish final guidelines to implement technologies for human performance improvement for nuclear power plant field workers.
	• (2025) Publish final guidelines to implement technologies for an automated plant.
	• (2025) Publish final guidelines to implement technologies for a hybrid control room.
	• (2025) Publish final guidelines to implement technologies for integrated operations.
	See also the technical report milestones for the II&C pilot projects identified under "New Instrumentation and Control and Human System Interfaces and Capabilities."
LTO - Requirements	Milestones:
Database for Advanced I&C,	(2018, 2020, and 2025) Releases of repository of advanced I&C requirements
Human System	based on pilot studies within the advanced I&C working group, other industry
Interface, and	pilot studies, and LWRS user facility results.
Information	
Technology	

R&D Area	RISMC
LWRS – Margins Analysis Techniques and Modeling and Simulation Activities in Support of RISMC	R&D Scope and Objectives: The purpose of the RISMC Pathway R&D is to support nuclear power plant decisions for risk-informed margins management with the aim to improve the economics and reliability and sustain the safety of current nuclear power plants over periods of extended operations. The goals of the RISMC Pathway are twofold: 1. Develop and demonstrate a risk-assessment method that is coupled to safety margin quantification that can be used by nuclear power plant decision makers as part of risk-informed margin management strategies.
	Create an advanced RISMC Toolkit that enables more accurate representation of nuclear power plant safety margins and their associated impacts on operations and economics.
	Margin Management Strategies: One of the primary items inherent in the goals of the RISMC Pathway is the ability to propose and evaluate margin management strategies. For example, a situation could exist that causes margins associated with one or more key safety functions to become degraded; the methods and tools developed in this pathway can be used to model and measure those margins. These evaluations will then support development and evaluation of appropriate alternative strategies for consideration by key decision makers to maintain and enhance the impacted margins as necessary. When alternatives are proposed that mitigate reductions in the safety margin, these changes are referred to as margin <i>recovery</i> strategies. Moving beyond current limitations in safety analysis, the RISMC Pathway will develop techniques to conduct margins analysis using simulation-based studies of safety margins.

R&D Area	RISMC
	Central to this pathway is the concept of a safety margin. In general terms, a "margin" is usually characterized in one of two ways:
	 A <i>deterministic</i> margin, defined by the ratio (or, alternatively, the difference) of an applied capacity (i.e., strength) to the load. For example, a pressure tank is tested to failure where the tank design is rated for a pressure C, and it is known to fail at pressure L, thus the margin is (L – C) (safety margin) or L/C (safety factor). A <i>probabilistic</i> margin, defined by the probability that the load exceeds the capacity. For example, if failure of a pressure tank is modeled where the tank design capacity is a distribution f(C), its loading condition is a second distribution f(L), the probabilistic margin would be represented by the expression Pr[f(L) > f(C)].
	In practice, actual loads (L) and capacities (C) are uncertain and, as a consequence, most engineering margin evaluations are, in fact, of the probabilistic type. In cases where deterministic margins are evaluated, the analysis is typically very conservative in order to account for uncertainties. The RISMC Pathway uses the probability margin approach to quantify impacts to economics, reliability, and safety to avoid excessive conservatisms (where possible) and treat uncertainties directly. Further, this approach is used in risk-informed margins management to present results to decision makers as it relates to margin evaluation, management, and recovery strategies.
	To successfully accomplish the pathway goals, the risk-informed safety margin approach must be defined and demonstrated. The determination of the degree of a safety margin requires an understanding of risk-based scenarios. Within a scenario, an understanding of nuclear power plant behavior (i.e., operational rules such as technical specifications, operator behavior, and SSC status) and associated uncertainties will be required to interface with a systems code. Then, to characterize safety margin for a specific safety performance metric of consideration (e.g., peak fuel clad temperature), the nuclear power plant simulation will determine the time and scenario-dependent outcomes for both the load and capacity. Specifically, the safety margin approach will use the physics-based nuclear power plant results (the "load") and contrast these to the capacity (for the associated performance metric) to determine if safety margins have been exceeded (or not) for a family of accident scenarios. Engineering insights will be derived based on the scenarios and associated outcomes.
	The RISMC methodologies are captured in a set of technical reports. These reports describe how the RISMC Pathway captures the protocols for analysis and evaluation related to safety margin characterization. The RISMC technical reports are intended to be companion documents to EPRI-produced reports. The reports will be developed to support industry use in their life-extension decisions.
	Margin Analysis Techniques: This research area develops techniques to conduct margins analysis, including the

_

^j Safety performance metrics may be application-specific, but, in general, they are engineering characteristics of the nuclear power plant; for example, as defined in 10 CFR 50.36, "safety limits for nuclear reactors are limits upon important process variables that are found to be necessary to reasonably protect the integrity of certain of the physical barriers that guard against the uncontrolled release of radioactivity."

R&D Area	RISMC
New Inta	methodology for carrying out simulation-based studies of safety margin, using the following generic process steps for RISMC applications:
	1. Characterize the issue to be resolved in a way that explicitly scopes the modeling and analysis to be performed. Formulate an "issue space" that describes the safety figures of merit to be analyzed and the proposed decision criteria to be employed.
	2. Quantify the decision-maker and analyst's state-of-knowledge (uncertainty) of the key variables and models relevant to the issue. For example, if long-term operation is a facet of the analysis, then potential aging mechanisms that may degrade components should be included in the quantification.
	3. Determine issue-specific, risk-based scenarios and accident timelines. The scenarios will be able to capture timing considerations that may affect the safety margins and nuclear power plant physical phenomena, as described in Steps 4 and 5. As such, there will be strong interactions between the analysis in Steps 3 through 5. Also, to "build up" the load and capacity distributions representing the safety margins (as part of Step 6), a large number of scenarios will be needed for evaluation.
	4. Represent nuclear power plant operation probabilistically using the scenarios identified in Step 3. For example, nuclear power plant operational rules (e.g., operator procedures, technical specifications, and maintenance schedules) are used to provide realism for scenario generation. Because numerous scenarios will be generated, the nuclear power plant and operator behavior cannot be manually created similar to current risk assessment using event and fault trees. In addition to the <i>expected</i> operator behavior (plant procedures), the probabilistic plant representation will account for the possibility of failures.
	5. Represent nuclear power plant physics mechanistically. The nuclear power plant systems level code will be used to develop distributions for the key plant process variables (i.e., loads) and the capacity to withstand those loads for the scenarios identified in Step 4. Because there is a coupling between Steps 4 and 5, they each can impact the other. For example, a calculated high loading (from pressure, temperature, or radiation) in an SSC may disable a component, thereby impacting an accident scenario.
	6. Construct and quantify a probabilistic load and capacity distributions relating to the figures of merit that will be analyzed to determine the probabilistic safety margins.
	7. Determine how to manage uncharacterized risk. Because there is no way to guarantee that all scenarios, hazards, failures, or physics are addressed, the decision maker should be aware of limitations in the analysis and adhere to protocols of "good engineering practices" to augment the analysis. This step relies on effective communication from the analysis steps in order to understand the risks that <i>were</i> characterized. As part of this step, it also is appropriate to evaluate the decision criteria proposed in Step 1 and modify (the criteria, the analysis, or both) as appropriate.

R&D Area	RISMC
	8. Identify and characterize the factors and controls that determine the relevant safety margins within the issue being evaluated to develop appropriate RIMM strategies. Determine whether additional work to reduce uncertainty would be worthwhile or if additional (or relaxed) safety control is justified.
	Case Study Collaborations:
	Jointly with EPRI, the LWRS Program's RISMC Pathway is working on specific case studies of interest to the commercial nuclear power plant industry. In Fiscal Year 2014, the team will continue the collaboration that began in 2013 on a BWR extended power uprate case study. Safety margin recovery strategies will be determined that will mitigate the potential safety impacts due to the postulated increase in nominal reactor power that would result from the postulated extended power uprate. A second case study of interest to industry that began in 2013 is the task to develop a technical report that will describe how to perform safety margin-based configuration risk management. Configuration risk management currently involves activities such as NRC's Significance Determination Process, which traditionally uses core damage frequency as the primary safety metric. The research for the second case study will focus on how the safety-margin approach may be used to determine risk levels as different nuclear power plant configurations are considered.
	RISMC Toolkit:
	The RISMC Toolkit is being built using INL's Multi-physics Object Oriented Simulation Environment (MOOSE) high-performance computing framework. MOOSE is the INL development and runtime environment for the solution of multi-physics systems that involve multiple physical models or multiple simultaneous physical phenomena. Models built on the MOOSE framework can be coupled as needed for solving a particular problem. The RISMC Toolkit and roles are described as follows:
	• RELAP-7: RELAP-7 (Reactor Excursion and Leak Analysis Program) will be the main reactor systems simulation tool for RISMC and the next generation tool in the RELAP reactor safety/systems analysis application series. RELAP-7 development will leverage 30 years of advancements in software design, numerical integration methods, and physical models. RELAP-7 will simulate behavior at the nuclear power plant level with a level of fidelity that will support the analysis and decision-making necessary to economically and safely extend and enhance the operation of the current nuclear power plant fleet.
	RAVEN: RAVEN (Reactor Analysis and Virtual Control Environment) is a multi-tasking application focused on RELAP-7 simulation control, reactor plant control logic, reactor system analysis, uncertainty quantification, and performing probabilistic risk assessments for postulated events. RAVEN will drive RELAP-7 (and other MOOSE-based reactor applications) for conduct of RISMC analyses.
	Grizzly: Grizzly will simulate component aging and damage evolution events

_

^k Gaston, D., G. Hansen, and C. Newman, 2009, "MOOSE: A Parallel Computational Framework for Coupled Systems for Nonlinear Equations. International Conference on Mathematics," *Computational Methods, and Reactor Physics*. Saratoga Springs, NY: American Nuclear Society.

R&D Area	RISMC			
R&D Alea	for LWRS Program-specific applications. Grizzly will be able to simulate component damage evolution for the RPV, core internals, and concrete support and containment structures subjected to a neutron flux, corrosion, and high temperatures and pressures. Grizzly will be able to couple with RELAP-7 and RAVEN to provide aging analysis in support of the RISMC methodology. • Peacock: Peacock is a general graphical user interface for MOOSE-based applications. Peacock has been built in a very general fashion to allow specialization of the graphical user interface for different applications. The specialization of Peacock for RELAP-7/RAVEN allows both a graphical input of the RELAP-7 input file and online data visualization and is moving forward to provide direct user control of the simulation and data mining capabilities in support of probabilistic risk assessment analysis.			
LTO – Enhanced				
Safety Analysis Capabilities	This research project will develop and validate an integrated framework and advanced tools for conducting risk-informed assessments that enable accurate characterization, visualization, and management of nuclear power plant safety margins. This LTO task is intended to develop an integrated methodology to assess plant safety margins and perform cost-effective, risk-informed safety analyses to meet these needs. It will achieve this objective through demonstration of effective and efficient application of the RISMC approach to issues important to the long-term operation of nuclear power plants. This project also provides significant interface and coordination of research efforts being conducted in safety analysis code development and safety margin analyses being performed by INL as part of the LWRS Program.			
LWRS – Margins	Milestones:			
Analysis Techniques and Modeling and Simulation Activities in Support of RISMC	 Margin Management Strategies: (2014) Complete detailed boiling water reactor station blackout analysis. (2015) Application of risk-informed margin management (RIMM) process to an issue of interest to industry stakeholder. (2017) Final technical report for RIMM process, including description of pilot application of RISMC/RIMM to an issue of interest at a host plant. 			
	 Margin Analysis Techniques: (2014) Support the evaluation of new accident tolerant fuels using the RISMC methodology (this activity will be done collaboratively with the DOE Fuel Cycle R&D Program). (2014) Demonstrate current margins analysis techniques on selected case studies using the completed software structure. The case studies will be selected in consultation with external stakeholders and will be chosen based on their potential to address an issue important to LWR sustainability and/or to achieve widespread stakeholder acceptance of the RISMC approach. (2015) The margins analysis techniques will be sufficiently mature to enable initial industry margins quantification exercises, including using the RISMC Toolkit. (2016) Complete a full-scope margins analysis of a commercial reactor power uprate scenario. Use margins analysis techniques, including a fully coupled RISMC Toolkit, to analyze an industry-important issue (e.g., assessment of 			

R&D Area	RISMC
RecD Anca	 major component degradation in the context of long-term operation or assessment of the safety benefit of advanced fuel forms). Test cases will be chosen in consultation with external stakeholders. (2020) Ensure development and validation to the degree that by the end of 2020, the margins analysis techniques and associated tools are an accepted approach for safety analysis support to plant decision-making, covering analysis of design-basis events and events within the technical scope of internal events probabilistic risk assessment.
	 RISMC Toolkit: (2014) Complete the software structure of the coupled RAVEN/RELAP-7 portion of the RISMC Toolkit. At this time, RELAP-7 can be fully controlled by RAVEN for complete systems analysis. RELAP-7/RAVEN will have the capability to be coupled to other applications (e.g., aging and fuels modules) and perform as a balance-of-plant capability for the multidimensional core simulators under development in other DOE programs. (2014) Complete the RELAP-7 Theory Manual that will allow end users to understand the technical basis behind the software development. (2014) Deliver the RELAP-7 verification and validation plan. (2015) Release the beta version of RELAP-7, including limited benchmarking (2015) Release the beta version 1.0 of Grizzly. This version will include aging of steel (embrittlement) and a modular architecture to enable inclusion of additional mechanisms. (2016) RELAP-7 will be validated against an accepted set of data. (2016) Release the beta version 2.0 of Grizzly. This version will include the capabilities of Version 1.0, as well as aging of selected concrete. (2018) Grizzly will be validated against an accepted set of data.
LTO – Enhanced Safety Analysis Capabilities	Milestones: In previous years, this LTO research effort successfully demonstrated that the RISMC methodology could be applied in an economical and efficient manner to analyze issues important to nuclear power plant safety. Key results of this research were documented in EPRI Report 1023032 (Technical Framework for Management of Safety Margins - Loss of Main Feedwater Pilot Application), which applied the RISMC methodology to evaluate the safety margins associated with a loss-of-all-feedwater event at a hypothetical PWR. An initial application of the RISMC approach to evaluate the impact on safety margins in the context of LTO decision-making was conducted in 2012 and documented in EPRI Report 1025291 (Pilot Application of Risk Informed Safety Margins to Support Nuclear Plant Long Term Operation Decisions: Impacts on Safety Margins of Power Uprates for Loss of Main Feedwater Events). In 2013 (and continuing in 2014), the EPRI LTO portion of the RISMC research expanded and will continue to expand upon this research by performing additional analyses of safety-significant applications that have the potential to impact critical long-term operation decision making. The EPRI research also will engage nuclear power plant owners/operators to initiate transfer of the technology for application to relevant safety issues with impact on nuclear power plant LTO. To support these objectives, the following activities will be conducted during 2013 and 2014: Project 1: RISMC Pilot Projects

R&D Area	RISMC
	Conduct RISMC analysis of safety margins associated with an extended station blackout event at a large BWR that desires to implement an extended power uprate. This project was initiated in 2012, with final results provided in an EPRI technical report published in 2013 (Report Number 3002000573, "Pilot Application of Risk Informed Safety Margins to Support Nuclear Plant Long Term Operation Decisions: Impact on Safety Margins of Extended Power Uprates for BWR Station Blackout Event).
	Assess the potential for the RISMC approach to be used to support utility and regulatory evaluations of the safety impact on nuclear power plant events by application of the RISMC approach to one or more previous events that resulted in a regulatory significance determination process analysis.
	 Project 2: Socialize RISMC Approach Among External Stakeholders An EPRI Technical Advisory Group will be formed of industry experts to review and guide the application of RISMC to issues of importance to nuclear power plant safety management and long-term operation. This group also will provide input to EPRI's continuing interaction with RISMC research activities being conducted by INL for the LWRS Program. This Technical Advisory Group will include participation from both U.S. and international members of EPRI's nuclear sector.
	EPRI will continue engagement with NRC researchers who are involved with similar regulatory research into development and application of the RISMC methodology. This interaction will be conducted under the existing memorandum of understanding between EPRI and NRC'S Office of Nuclear Regulatory Research.
	EPRI also will continue to participate in external communication of RISMC research at appropriate venues, including conduct of EPRI industry workshops, presentations at applicable conferences, and reporting results of pilot applications in peer-reviewed scientific literature.
	In addition to application of the RISMC methodology, EPRI will continue to support INL development of the next generation safety analysis software (RELAP-7). Previously, EPRI provided important contributions to this work via EPRI Reports 1019206 (Framework for Risk Informed Safety Margin Characterization), which summarized the current state-of-the-art (as of 2009) for the RISMC methodology and deterministic safety analysis and probabilistic risk assessment software tools, and 1021085 (Desired Characteristics for Next Generation Integrated Nuclear Safety Analysis Methods and Software), which specified desired elements for the next generation safety analysis tool suite (from the perspective of a plant owner/operator). During 2014 and beyond, EPRI will continue to support INL's development of RELAP-7 by providing input to its development and conducting trial applications as modules become available.
	Project 3: RISMC Safety Margin Method and Tool Development (LWRS)
	• Support development of RELAP-7 by closely working with the INL RELAP-7 development team to provide input to software development and by conducting testing on trial safety analysis applications as modules become available. In particular, it is intended that the RELAP-7 software will be applied to support/confirm results from RISMC analysis of the station

R&D Area	RISMC			
	blackout event for a BWR, with an extended power uprate being conducted by			
	EPRI during 2013. EPRI also will work closely with INL to develop			
	appropriate benchmarking and validation plans and identify relevant data			
	sources for code verification and validation activities. In particular, in 2014			
	EPRI will publish a report that provides a compendium of such available			
	validation data sources. During 2014 EPRI, will work with the INL RELAP			
	development team to select an appropriate high value data set for use in the			
	planned 2015 RELAP-7 validation effort.			

5. LIGHT WATER REACTOR SUSTAINABILITY/ LONG-TERM OPERATIONS PROGRAM-UNIQUE RESEARCH AND DEVELOPMENT ACTIVITIES

LWRS – Expanded
Materials
Degradation
Assessment (EMDA)

R&D Scope and Objectives:

The objectives of this research task are to provide comprehensive assessment of materials degradation, relate to consequences of SSCs and economically important components, incorporate results, guide future testing, and integrate with other pathways and programs. This task will provide an organized and updated assessment of key materials aging degradation issues and support NRC and EPRI efforts to update the Proactive Materials Degradation Assessment or the Materials Degradation Matrix (MDM) documents. Successful completion will provide a valuable means of task identification and prioritization within this pathway, as well as identify new needs for research.

An EMDA of degradation mechanisms for 60 to 80 years or beyond was identified as a useful tool in further prioritizing degradation for research needs. Based on joint discussions between DOE and NRC, it was decided that the EMDA would consist of separate and focused documents covering the key SSCs. This approach will yield a series of independent assessments (i.e., core internals and primary and secondary piping, RPV, concrete civil structures, and electrical power and I&C cabling and insulation) that, when combined, will create a comprehensive EMDA. The LWRS Program will use this as a tool for identifying and prioritizing research in future years. NRC will use the EMDA to inform the regulatory framework. The nuclear industry will use the EMDA results as a complementary tool to their MDM.

Milestone:

• (2014) Complete and deliver gap analysis of key materials degradation modes via the EMDA.

LTO –MDM and Issues Management Tables

R&D Scope and Objectives:

EPRI's MDM, PWR Issues Management Tables (IMTs), and BWR IMTs are three key reference documents that are part of industry's materials initiative guided by NEI 03-08. The MDM and IMTs identify knowledge gaps based on likely degradation mechanisms and aging issues through an expert elicitation process. The MDM and IMTs also assess the state of industry knowledge worldwide, survey the laboratory data and field experience data, and prioritize the gaps for industry to resolve in the most effective way.

MDM results are used as direct inputs into the BWR IMT and PWR IMT. Degradation mechanisms identified in MDM are used as primary input for the set of degradation mechanisms considered by the IMT process. The MDM was first published in 2004 (Rev. 0), and it has been revised three times in 2007 (Rev. 1), 2010 (Rev. 2), and 2013 (Rev. 3). Sequentially, two IMTs were first published in 2005 (Rev. 0) and then revised in 2008 (Rev. 1), 2010 (Rev. 2), and 2013 (Rev. 3). Rev. 0 and Rev. 1 of MDM and the IMTs only addressed issues related to current license period (40 years operation) and the license renewal period (from 40 to 60 years operation).

Long-term operation of nuclear power plants up to 80 years may pose additional materials degradation issues that may not be deemed to be life-limiting factors for 60 years operation. For example, the increased fluence level can be a serious concern to some of reactor internal components. The increased fluence level not only can lead to changes in materials properties and cracking susceptibility, but also can be an issue on repairing the internal components.

In support of the LTO Program, an LTO 'flag' has been added to the MDM (starting with Revision 2 in 2010), indicating on-going work or evaluation that is needed to support 60 to 80 years of operation. The objective of this addition to the MDM is to:

- 1. Identify applicable degradation mechanisms and assess the extent to which applicable degradation mechanisms are understood
- 2. Evaluate the state of industry knowledge worldwide associated with mitigation of degradation mechanisms
- 3. Address any concerns related to regulatory and licensing renewal considerations.

MDM and IMTs are based on an expert elicitation process. A panel consisting of materials experts, industry personnel, and EPRI staff provided the key inputs for the on-going revisions. The expert panel considered relevant operating experience, information from newly published and ongoing research projects worldwide, the consequence of failure, and the availability of mitigation strategies, when developing the results.

- 1. Develop a fundamental understanding of the degradation phenomena/mechanisms and determine materials (and locations) that are known or can logically be assumed to be susceptible to aging/degradation phenomena when exposed to the operating environment.
- 2. Conduct generic operability and safety assessments for the locations of the various materials potentially susceptible to damage/degradation phenomena.
- 3. Develop inspection and evaluation guidelines and technology for the identified locations, starting with those for which the potential consequences of failure are most severe.
- 4. Evaluate available mitigation options and, if necessary, develop additional options.
- 5. Evaluate repair/replace options and, where necessary, encourage/support the development of additional options.
- 6. Monitor, evaluate, and feedback nuclear power plant operating experience.
- 7. Obtain regulatory acceptance of the items above and support licensees on nuclear power plant-specific applications as needed.

The MDM focuses on the development of a fundamental understanding of the degradation phenomena/mechanisms, based on the materials/environment combination. Expert elicitation, laboratory studies, and field experience were used to identify potential mechanisms by which each of the materials might degrade.

The PWR IMT and BWR IMT are component-based evaluations of consequence of failure. This component-based approach also emphasizes the considerations of mitigation strategies, repair/replacement, inspection and evaluation guidelines, and regulatory requirements. All considerations will be captured in IMT gaps, which will then be prioritized. The prioritization of IMT gaps provides a basis for industry to prioritize R&D efforts to address materials' reliability issues and LTO concerns effectively.

The LTO Program will also support the current EPRI online Materials Information Portal. With built-in navigation and interlinks, the EPRI online Materials Information Portal integrates multiple EPRI resources (i.e., MDM, PWR IMT, BWR IMT, and the Materials Handbook). This portal provides a comprehensive, integrated view of materials issues and associated information necessary for materials aging management at nuclear power plants.

Milestones:

MDM and IMTs are living documents and they require updates and revisions periodically to reflect the knowledge gained and evolving challenges. The MDM and IMTs are scheduled to be revised every three years, and more frequent interim updates of underlying information can be achieved through the maintenance of the Materials Information Portal. The Materials Information Portal maintenance frequency is semi-annual (twice a year). The LTO-supported work will be coordinated with the planned work within the Primary System Corrosion Research program to update and maintain the MDM and Materials Information Portal and also the work within the PWR Materials Reliability Project and BWR Vessel and Internals Project to update and maintain the IMTs.

(2013, 2016, 2019) Update the MDM.

(2013, 2016, 2019) Update the IMTs.

LWRS – Thermal (Post-Irradiation) Annealing

R&D Scope and Objectives:

This task provides critical assessment of thermal annealing as a mitigation technology for RPV and core internal embrittlement and research to support deployment of thermal annealing technology. This task will build on other RPV tasks and extend the mechanistic understanding of irradiation effects on RPV steels to provide an alternative mitigation strategy. This task will provide experimental and theoretical support to resolving technical issues required to implement this strategy. Successful completion of this effort will provide the data and theoretical understanding to support implementation of this alternative mitigation technology.

Milestones:

• (2024) Complete characterization of RPV sections (harvested from a reactor) that have been irradiated, annealed (post-harvesting), and then reirradiated in a test reactor.

While a long-term effort, demonstration of annealing techniques and subsequent

irradiation for RPV sections is a key step in validating this mitigation strategy. Successful deployment also may allow for recovery from embrittlement in the RPV, which would be of high value to industry by avoiding costly replacements.

LWRS – Zion Materials Management and Coordination

R&D Scope and Objectives:

The Zion Harvesting Project, in cooperation with Zion Solutions, is coordinating the selective procurement of materials, structures, components, and other items of interest to the LWRS Program, ERPI, and NRC from the decommissioned Zion 1 and Zion 2 nuclear power plants, as well as possible access to perform limited, onsite testing of certain structures and components. Materials of high interest include low-voltage cabling, concrete core samples, and through-wall thickness sections of RPV.

Milestones:

• (2014) Document statement of work to obtain reactor pressure vessel segments (beltline weld and cold nozzle) from Zion Unit 2.

Discussions regarding continued harvesting of material (including cables, concrete and RPV samples) are underway. Additional milestones will be identified once a revised decommissioning schedule is available.

LTO – Integrated Life-Cycle Management

R&D Scope and Objectives:

To achieve long-term operation, nuclear power plant operators must maintain and/or enhance high levels of safety, reliability, and economic performance as are typical today. Nuclear power plant operators will need to be equipped with sound scientific, and consistent technical knowledge bases to provide them the optimum information in support of their plant asset extended operation decisions of 60 years and beyond. Refurbishment and/or replacement of large capital assets not normally considered during the original licensed life may now come into play. This project will identify those large capital assets. Some of these assets may not have the operating experience and research sufficient for providing technical bases input into operators' business models. The project will develop methods that nuclear operators can utilize in the determination of the likelihood of failure for selected large capital assets that is supported by science and enabling technology and operating experience. This methodology is ILCM and will provide consistency of information nuclear power plant operators can utilize in support of the optimization of their long-range nuclear power plant and/or fleet strategic technical and business decision models. For example, what large capital assets will be required to be refurbished and/or replaced, when they will be required to be addressed in the life cycle, and how much it will cost?

The design phase of work will be complete in 2013, with technical transfer scheduled for 2014.

- The initiative commenced in 2010 with the following accomplishments:
 - Project requirement documents (database and methods).
 - Likelihood of failure methodology.
 - Proof of concept for likelihood of failure methods using actual site data for initial components.

- Governance and communication through quarterly advisor meetings and periodic LTO executive committee presentations.
- Completion of failure curves for 2010 scoped SSCs.
- Completion of life-limiting and Constellation Energy Nuclear Group demonstration projects.
- Entering into a memorandum of understanding with Électricité de France to proceed with collaboration.
- Publication of EPRI Technical Update 1021188, Integrated Life Cycle Management Status Report, December 2010.
- Using the results from prior year work, develop the modified optimization tools and release them as a production product by mid-2014.
- EPRI Software Engineering to complete the ILCM optimization framework that incorporates failure calculator and ILCM modified IPOP into a single software package. Formal release after pilot applications and user beta testing is planned for 2014.
- Perform full site pilot (second quarter of 2013).
- Establish the necessary code support, users group, and training for the
 optimization tools. After 2013, it is anticipated that the users group would not
 only provide for continuity of the optimization tool, but would also provide
 for continuous improvement.
- In 2013/2014, technical transfer through workshops and/or seminars, failure curve ongoing development and final report. It is anticipated that an ILCM users group will be created to foster continued component data, failure curve development, and refinement to the methods. Organize users group.

LTO – Technical Bases Gap Assessment for Aging Management Programs to Support Subsequent License Renewal

R&D Scope and Objectives:

The Aging Management Program (AMP) Assessment Project is focused on the technical bases of the currently defined AMPs per the NRC report "Generic Aging Lessons Learned" (NUREG-1801, Revision 2). Technical bases are the data and associated implementation tools (e.g., guidelines, analytical models, evaluation bases, etc...) that provide reasonable assurance that the current condition of the subject SSC is assessed to allow safe, continued operation as is through a defined period prior to reassessment or to allow remedial actions prior to risk of failure. Under this project, the current set of AMPs will be reviewed for their applicability to a period of extended operation (i.e., 60 to 80 years) that may be allowed via a successful subsequent license renewal (SLR). The review process is intended to help define additional technical needs and/or changes to allow the AMPs to be successfully used for the period from 60 to 80 years of operation. The AMP reviewers will include subject matter experts drawn from both EPRI staff and external sources, utility staff involved in the design and implementation of AMPs at operating nuclear power plants, and appropriate third parties such as owner's groups and vendors. The review focus will be on binning AMPs according to the future technical bases required or gaps in those technical bases. The key points of the review are as follow:

Are there changes in the aging mechanisms, their rates, or their extent that

may occur after operation to 60 years?

- Are such changes after 60 years being addressed by current or planned R&D efforts?
- Are there technical tools required to effectively address new or changed aging management requirements?

The overall goal is to identify "gaps" in the industry technical bases for utilizing AMPs for the operating period from 60 to 80 years. Such "gaps" will then be used to refine industry R&D efforts and to reduce the uncertainties for utility decision making concerning SLR for a specific nuclear power plant.

Follow-on efforts will be focused on tracking closure of identified R&D gaps and refining the state-of-knowledge with respect to aging management, including incorporation of operating experience that may better frame research needs.

Buried Piping and Tanks (work not directly in LTO scope due to near-term, nuclear power plant operational impact)

R&D Scope and Objectives:

This research area is under the NEI 09-14 initiative. EPRI buried pipe research is focused on furthering state-of-the-art technologies for inspection, analysis, repair, and mitigation of ongoing corrosion in buried infrastructure. This includes the following:

- Development and delivery of appropriate reference documents and training to support broad knowledge awareness for buried and underground piping.
- Development and transfer of new buried pipe inspection technologies, such as remote field NDE inspection robotics.
- Identification and evaluation of existing technologies that may be directly applied or easily adapted for nuclear power plant buried piping inspection.
- Improved understanding regarding the usefulness of guided wave acoustic NDE technologies for buried piping inspections.
- Availability of repair and replacement alternatives for buried pipe applications, including high-density polyethylene.
- Enhanced buried pipe risk-ranking technologies through updates to existing software.

Research activities are coordinated across EPRI's Plant Engineering and NDE Programs.

The Plant Engineering Program provides buried pipe program owner guidance documents, reference materials, and upgraded risk ranking software (BPWORKSTM) and also supports the development of various American Society of Mechanical Engineers Code Cases for repair/replacement activities. Training courses are offered for newly assigned Buried Pipe Program owners to help ensure buried pipe management guidance is appropriately deployed in the field. Reference materials on cathodic protection and coatings have been developed to address buried and underground pipe program needs. Through the Buried Pipe Integrity Group, EPRI provides a forum for information exchange among nuclear power plant personnel, vendors, and other stakeholders to identify and transfer best practices for buried pipe inspection and assessment.

The NDE Program is pursuing the identification and assessment of existing robotic and inspection technologies, as well as the development of new robotic

inspection technologies using remote field detection technology. Efforts continue to identify, demonstrate, evaluate, and qualify inspection technologies suitable for buried pipe applications, with special emphasis on guided wave ultrasonic technologies.

Chemistry (work not directly in LTO scope due to near-term, nuclear power plant operational impact)

R&D Scope and Objectives:

No specific water chemistry program LTO-related R&D gaps were identified. The benefit of water chemistry technologies is generally time independent. Although mitigation through chemical means is vital to long-term aging management, any changes to program implementation over time are not likely to be related to time-dependent factors.

Importantly, implementation of the water chemistry program is specifically within the scope of NEI 03-08. A robust industry program exists to ensure that water chemistry guidelines are periodically reviewed and updated and that related R&D gaps are proactively addressed. Opportunities for AMP implementation improvements may be realized from these on-going research efforts.

Key existing EPRI reports include the following:

- BWRVIP-190: BWR Vessel and Internals Project, BWR Water Chemistry Guidelines 2008 Revision. EPRI, Palo Alto, CA: October 2008.
- Pressurized Water Reactor Primary Water Chemistry Guidelines Revision
 EPRI, Palo Alto, CA: December 2007.
- Pressurized Water Reactor Secondary Water Chemistry Guidelines, Revision
 7. EPRI, Palo Alto, CA: February 2009.

Steam Generator Management Program (work not directly in LTO scope due to near-term, nuclear power plant operational impact)

The EPRI Steam Generator Management Program provides guidelines for inspection, repair, monitoring, and flaw evaluation of steam generator components and tubing materials. The Steam Generator Management Program includes aging management activities for the steam generator tubes, plugs, sleeves, and secondary side components that are contained within the steam generator. Program implementation is consistent with nuclear power plant technical specifications and includes commitments to NEI 97-06. The NDE techniques used to inspect tubes, plugs, sleeves, and secondary side internals are intended to identify components (e.g., tubes and plugs) with degradation that may need to be removed from service or repaired. The program additionally provides for degradation assessments, condition monitoring (assessment of past performance), and operational assessments (forward-looking assessment of anticipated performance until the next inspection). The Steam Generator Management Program is based on these six EPRI guidelines:

- PWR Steam Generator Examination Guidelines
- PWR Primary-to-Secondary Leak Guidelines
- PWR Secondary Water Chemistry Guidelines
- PWR Primary Water Chemistry Guidelines
- Steam Generator Integrity Assessment Guidelines
- Steam Generator In-Situ Pressure Test Guidelines.

These guideline documents are supported by both evaluation handbooks (e.g., flaw evaluation and foreign object evaluation) and by technical reports that document the results of EPRI research. Reports are periodically updated using the latest R&D results.

Attachment A

Long-Term Operations Issues Tracking Table

LTO Issues Tracking Table

LEGEND
Active on-going work
Planned work
No planned work; potential scope
Not within LTO scope
Complete

The purpose of the Long Term Operations Issues Tracking Table (ITT) is to identify and prioritize the R&D projects needed to support safe, reliable and economic long-term operations. The ITT is the result of an expert solicitation process and is maintained as a living document. It is reviewed on an annual basis by stakeholders from EPRI, NEI (Nuclear Energy Institute), DOE, national laboratories and EPRI utility advisors to ensure accuracy and completeness. The R&D projects are colored coded to indicate status of the supporting R&D projects, and assigned a Category. The Categories are:

A – An industry-developed program <u>or</u> R&D results are needed for a utility to submit an application for SLR to NRC.

B – These are R&D projects to support the technical basis for the aging management programs. Sufficient information exists to submit a SLR application, but continued R&D projects are needed to provide informed insights for aging management, inspection intervals and repair/replacement decisions.

C – These projects are not needed for SLR, but support long-term sustainability based on addressing obsolescence and economic improvements for extended operations.

The EPRI LTO Program and the DOE LWRS Program use the ITT to ensure the necessary R&D projects are being performed at the right time to support long-term operations of nuclear power plants by plant owners and operators.

Comments	commitment to or implementation of the surveillance capsule program is needed for an SLR application The results will be available after initial SLR applications are submitted for approval	BWRVIP: Task 2.1 Task 2.11 Task 2.35 Task 2.36 Commitment to or implementation of the surveillance capsule program is needed for an SLR application The results will be available after initial SLR applications are submitted for	MDM has been expanded to include 60 to 80 years of operation and is reviewed and updated on a routine cycle.
AMP	XI.M31 Co TLAA im or im of cal is is is is is is is in i	B S S S S S S S S S S S S S S S S S S S	ex inc year op op up reverse
Category	4	4	4
IMT Gap or MDM Cell	P-AS-37 (M) B-AS-30 (M) B-RG-08		
DOE- LWRS	ΑN	∀ Z	NRC Research DOE LWRS EMDA
EPRI Program (Other)	MRP	BWRVIP	Materials Program
EPRI LTO Status	0.170	7.0	110
Detailed Description	Coupons placed in reactors to represent fluence to 60 years are important to validate analytical predictions of vessel embrittlement. There may not be adequate coupons to represent all reactors to 60 years without careful management of these samples. WRP has two projects in place to generate high fluence PWR surveillance data; 1) optimize the withdrawal schedules of the remaining capsules 2) fabrication and irradiation of supplemental surveillance capsules	Coupons placed in reactors to represent fluence to 60 years are important to validate analytical predictions of vessel embrittlement. There may not be adequate coupons to represent all reactors to 60 years without careful management of these samples. BWRVIP has a planned project to extend the Integrated Surveillance Program (ISP) from 60 to 80 years	Expansion of Materials Degradation Matrix (MDM) and Issue Management Tables (IMT) to include mechanisms acting beyond 60, to 80 years for primary metals. Expansion of the PMDA into the EMDA.
Sub-issue Description	PWR Surveillance capsules with fluence representative of 60-plus years of operation	BWR Surveillance capsules with fluence representative of 60-plus years of operation	Expansion of MDM and IMT for primary metals to 80 years.
Primary Issue Description	Primary System Metals Aging	Primary System Metals Aging	Primary System Metals Aging
Issue ID (OId)	1.9	New item added in 2013	1.6
Issue ID (New)	1	5	m

Comments	PSCR: Task 8 Subtask 9a Long-term R&D to support continued improvement of the AMPs	PSCR: Task 8 Long-term R&D to support continued improvement of the AMPs	PSCR: Task 1 BWRVIP: Task 2.5 Task 2.7 Task 2.7 Task 2.15 Task 2.34 Long-term R&D to support continued improvement of the AMPs
AMP	XI.M1 PSI XI.M2 Ta XI.M4 Sul XI.M7 XI.M8 Loi XI.M11A to XI.M19 coi XI.M32 im the	XI.M1 PS, XI.M2 Tax XI.M4 Lor XI.M8 to XI.M9 to XI.M9 cor XI.M19 im XI.M21 im XI.M25 the XI.M35 the XI.M35	XI.M9 Tax XI.M9 BW BW Tax
Category A	<u>****</u>	<u> </u>	a ×
IMT Gap or MDM Cell	P-DM-13 (L) P-AS-19 (H) P-AS-20 (M) P-AS-30 (H) B-DM-09 B-AS-27 (M) MDM: p1- 1f-1, p3-1b- c	IMT: P-DM-11 (L) P-DM-13 (L) P-AS-13 (H) P-AS-38 (M) B-DM-09 (L) B-DM-09 (L) MDM: p1- 1C-e b1-1C-e	IMT: P-AS-14 (H) P-AS-15 (M) P-AS-39 (L) B-AS-09 (H) B-AS-10 (H) B-AS-11 (L) B-AS-12 B-AS-26 (H) MDM: p2- 2a-g b2-2a-c; for creep: p2-14a-g
DOE- LWRS	DOE LWRS	∀ Z	DOE
EPRI Program (Other)	Primary System Corrosion Research (PSCR)	PSCR	BWRVIP
EPRI LTO Status	LTO	0170	LTO
Detailed Description	Predicting crack growth from environmental SCC of Ni alloy base material and weld materials (600, 690, 82/182, 52/152)	Predicting crack growth from environmental SCC of stainless steel base material and weld materials	IASCC of austenitic stainless steel internals (shrouds, baffle bolts,) and cast stainless steel. Currently includes testing of high fluence sample components. Could add irradiation and testing of X-750 and XM-19 shroud repair materials in the future. DOE-LWRS is performing swelling evaluations and investigation of irradiation-induced phase transformations.
Sub-issue Description	Environmental stress corrosion cracking of nickel alloy base and weld materials	Environmental stress corrosion cracking of stainless steel base and weld materials	assisted stress corrosion cracking of austenitic and cast stainless steel; Irradiation-induced creep of reactor internals
Primary Issue Description	Primary System Metals Aging	Primary System Metals Aging	Primary System Metals Aging
Issue ID (OId)	1.1	1.1	1.2
Issue ID (New)	4	ហ	9

Comments	Long-term R&D to support continued improvement of the AMPs	BWRVIP: Task 2.1 Task 2.11 Task 2.35 Task 2.36 Long-term R&D to support continued improvement of the AMPs	Long-term R&D to support continued improvement of the basis for the	
AMP	1 1 0 1 1 1 1	XI.M31 TLAA T T T T T T T T T T T T T T T T T T T	TLAA t	
Category	В	۵	В	В
IMT Gap or MDM Cell		P-DM-10 (L) P-AS-04 (L) P-AS-05 (M) P-AS-28 (M) B-DM-08 (L) B-AS-28 (M) B-AS-28 (M) B-AS-28 (M) B-AS-30 (M) B-AS-3	IMT: P-AS-16 (M) B-AS-14 (L) MDM: p1/2-9a-f b1/2-9a-g	
DOE- LWRS	DOE LWRS	DOE LWRS	DOE	DOE LWRS
EPRI Program (Other)	PSCR	BWRVIP MRP	Materials Program	NDE
EPRI LTO Status	710	LTO	7,10	LTO
Detailed Description	Investigate fundamental mechanisms of thermal aging on ferritic-austenitic stainless welds and CASS materials at LWR temperatures and the effects of thermal aging on mechanical properties and corrosion resistance.	Recent changes in recommended modeling and analytical prediction of RPV embrittlement from fluence expected for 60 years is expected to show increased safety margin for many plants. Continued R&D projects to develop embrittlement trend correlations and direct measurement of fracture toughness. DOE-LWRS is currently irradiating specimens at ATR-2.	Lack of definite design rules for EAF creates uncertainty for long-term operation. Upon completion of the work EPRI plans to work through the ASME code on needed code revisions	Concrete issues identification, prioritization from operating experience, expert elicitation, and consideration of experience and analysis from other industries.
Sub-issue Description	Thermal aging of CASS and Stainless Steel Welds	Analysis of reactor pressure vessel embrittlement from long-term fluence	Environmental effects on fatigue life for nickel alloys and stainless steel	Concrete issues identification
Primary Issue Description	Primary System Metals Aging	Primary System Metals Aging	Primary System Metals Aging	Concrete and Concrete Aging
Issue ID (OId)	New Item added in 2013	1.9	1.4	2.1
Issue ID (New)	7	∞	6	10

Comments		Long-term R&D to support continued improvement of the basis for the AMPs	Long-term R&D to support continued improvement of the basis for the AMPs	Long-term R&D to support continued improvement of the basis for the AMPs	Long-term R&D to support continued improvement of the basis for the AMPs	Long-term R&D to support continued improvement of the basis for the AMPs
AMP					XI.E2 XI.E3 XI.E3	
Category	В	В	ω	Δ	ω	ω
IMT Gap or MDM Cell						
DOE- LWRS	DOE LWRS		DOE LWRS		DOE LWRS	DOE LWRS
EPRI Program (Other)	NDE	NDE	NDE	нгм	ER Program	
EPRI LTO Status	LTO	LTO Co-funded with MAI	110		110	011
Detailed Description	Concrete issues resolution guidelines and analysis tools- Examples are ASR testing and inspections techniques and boric acid degradation on the SFP concrete and rebar.	Pilot study of concrete cracking of fuel pools at liner connections. The issue is corrosion of metal reinforcement from boric acid.	Concrete exposed to external stressors may age at an accelerated rate. Research should be conducted to determine if the rate of degradation will cause an issue in developing the technical basis for LTO. Examples include radiation and temperature damage to the reactor cavity and chloride attack of cooling towers.	Follow guidance for the management of BORAL and performance accelerated aging tests	Testing and aging management of cables including submerged / wetted cables, EQ and non-EQ, medium and low voltage.	Gather actual in-plant radiation and temperature data to determine the actual radiation exposure and temperature environment for 60 to 80 years. Conduct testing at SNL
Sub-issue Description	Concrete issues resolution, guidelines and analysis tools	Pilot study of concrete cracking of fuel pools at liner connections	Evaluation of concrete structures subject to external stressors (radiation, temperature, corrosion)	Neutron Absorber materials for long-term operations	Testing and aging management of cables (submerged/wet ted, EQ/non-EQ, medium and low voltage)	Understand the potential synergist effects of radiation and temperature on cable insulation for long-term operations
Primary Issue Description	Concrete and Concrete Aging	Concrete and Concrete Aging	Concrete and Concrete Aging	Neutron Absorber Materials	Cable Aging	Cable Aging
lssue ID (Old)	2.1	2.2	2.2	New item added in 2013	9.1	New item added in 2013
Issue ID (New)	11	12	13	14	15	16

Issue ID	Issue	Primary Issue	Sub-issue	Detailed Description	EPRI LTO	EPRI	DOE-	IMT Gap or	Category	AMP	Comments
(New)	ID (Old)	Description	Description		Status	Program (Other)	LWRS	MDM Cell			
17	10.1	Underground	Testing and	Development of advanced methods for	ΑN	ER Program	NA		В	XI.M41	NEI Initiative 09-
		and BOP	inspection	testing and inspection of buried piping.							14
		Equipment	methods for				_				
		Aging	buried piping				_				Long-term R&D
											to support
											continued
											improvement of
											the basis for the
							_				AMPs
18	10.1	Underground	Selective	Selective leaching of elements from buried		ER Program			В		
		and BOP	leaching of	metal piping is a form of aging		NDE					
		Equipment	buried metal	degradation. R&D could be directed at		Program					
		Aging	nining	monitoring aging management and)					
		0,0	0	lifetime estimation methodology for							
				susceptible piping.							
19	3.1	SSC	On-line	On-line monitoring, diagnostics, and	LTO				U		Initial guideline
		Monitoring	monitoring,	prognostics for active components							report issued by
		Diagnosticsan	diagnostics, and	including guidelines for monitoring.							EPRI
		d Prognostics	prognostics for	automated diagnostic advisory tools, and							
		.00	active	database of fault signatures							Supports long.
			components	ממומטמים כן וממון אפומות כא.							torm
			components								יייי
											sustainability by
											addressing
							_				opsolescence
											and economic
											improvement
20	3.1	SSC	On-line	On-line monitoring, diagnostics, and	ГТО	I&C Program	DOE		C		Duke and Exelon
		Monitoring	monitoring,	prognostic pilot studies: transformers and		Generation	LWRS				pilot plant
		Diagnostics	diagnostics, and	emergency diesel generators.							projects
		and	prognostic pilot								
		Prognostics	studies for								Supports long-
		1.0811031103	3144153 101								Sioisioddac
			transtormers and								term
			generators.								sustainability by
											addressing
											opsolescence
											and economic
											improvement

Comments	Supports long- term sustainability by addressing obsolescence and economic improvement	Case studies completed	Supports long- term sustainability by addressing obsolescence and economic improvement	WRTC: 2010-009 2010-037 Supports long- term sustainability by addressing obsolescence and economic improvement	Supports long- term sustainability by addressing obsolescence and economic improvement
AMP					
Category	v	U	o	J	U
IMT Gap or MDM Cell				P-RR-03 (M) B-RR-02 (H) B-RR-08 (M)	
DOE- LWRS	NA	δ.	DOE LWRS	DOE LWRS	DOE LWRS
EPRI Program (Other)					
EPRI LTO Status	8 EDF	710	7.0	0170	710
Detailed Description	Developing life cycle management guidelines and analysis tools to support decisions on continued operation, refurbishment, and replacement of large components including timing, costs, and engineering options	Investigation of safety assessment applications that are expected to be important to long term operations, and identification of technology gaps that could jeopardize the success of these applications.	Based on an inventory and functional mapping of current safety analysis tools and on the technology gaps identified in issue 6.1, enhanced safety analysis codes and capabilities will be specified and developed. INL is taking the lead in development of next generation code for mechanistic simulation of transients and accidents.	Repair technique- Underwater welding of irradiated reactor internals materials and weld repair.	Pilot studies and Industry Guidelines for next generation I&C, human/system interface, and information technology architecture and capabilities.
Sub-issue Description	Life-cycle management tools to support decisions on continued operation, refurbishment and replacement of large components	Identification of technical gaps in safety assessment with respect to longterm operations	Development of enhanced safety analysis codes to address technical gaps	Underwater welding of irradiated reactor internals	Next-generation 18C, human/system interface, and information technology architecture and capabilities
Primary Issue Description	Asset Management and ILCM	Risk-informed Safety Margins Characterizati on	Risk-informed Safety Margins Characterizati on	Welding technology	Digital 18C Modernizatio n and Enhanced Functionality
Issue ID (OId)	8.1	6.1	6.2	21.1	4.1
Issue ID (New)	21	22	23	24	25

Comments	Supports long- term sustainability by addressing obsolescence and economic improvement	Supports long- term sustainability by addressing obsolescence and economic improvement	Supports long- term sustainability by addressing obsolescence and economic improvement		Supports long- term sustainability by addressing obsolescence and economic improvement
AMP					
Category	O O	U	U	U	U
IMT Gap or MDM Cell					
DOE- LWRS	DOE	DOE	DOE	DOE	
EPRI Program (Other)	ER Program		NDE		ER Program NDE Program
EPRI LTO Status	140	110			
Detailed Description	Continue to push the state-of-technology on methods for condition monitoring of installed cables	On-line monitoring, diagnostics, and prognostic for passive components.	DOE-LWRS program is developing roadmaps for future sensor and NDE enhancements. EPRI NDE Program works continues to advance the ability to detect and monitor for various forms of degradation and provide Industry leadership for NDE qualification and testing	Establish an Information and I&C (IIC) user facility to support the development, modeling, verification, and testing of advanced IIC systems.	New materials and methods for BOP system replacement/refurbishment
Sub-issue Description	Condition Monitoring for Cables	On-line monitoring, diagnostics, and prognostics for passive components	Investigate techniques for NDE that can provide new technologies to monitor material and component performance.	Dedicated user facility to support development, testing, modeling, and verification of advanced information and I&C systems	New materials and methods for balance-of-plant replacement/ refurbishment
Primary Issue Description	Cable Aging	SSC Monitoring Diagnosticsan d Prognostics	NDE Technology Advancement S	Digital 1&C Modernizatio n and Enhanced Functionality	Underground and BOP Equipment Aging
Issue ID (OId)	New item added in 2013	3.2	11.1	4.1	10.2
Issue ID (New)	26	27	28	29	30

Issue ID Is	Issue Primary Issue	Issue Sub-issue	esne	Detailed Description	EPRI LTO	EPRI	DOE-	IMT Gap or	Category	AMP	Comments
	ID Description (Old)	ntion Description	ption		Status	Program (Other)	LWRS	MDM Cell			
.6	6.3 Risk-informed		:	Enhance PRA capabilities and tools to	LTO				0		Supports long-
	Sarety	probabilistic risk	Stic risk	pertorm risks assessment							term
	Characterizati		- Y								addressing
	Clarace		3								ohsolescence
	5										and economic
											improvement
9	6.4 Risk-informed	rmed Development of	nent of	Formulation of margin-based safety case	LTO		DOE		C		Supports long-
	Safety	margin-based		framework, analysis capability, and			LWRS				term
	Margins	safety case		calculation tool (RELAP-7).							sustainability by
	Characterizati	rizati	rk and								addressing
	ou	calculation tool	n tool								obsolescence
											and economic
											improvement
Ž	New Methods to	to Develop		Continue development and demonstration		Materials			2		Supports long-
ij	item mitigate or	or methods for	for	work on peening and other techniques for		Programs					term
ä	added improve	stress		stress improvements. Continue work on							sustainability by
2.	in stresses	improvement	nent	weld overlays as a repair technique for							addressing
7	2013	and repair		long-term operations.							obsolescence
		options									and economic
											improvement
1.	1.9 Primary		liation	Issues associated with annealing must be	ГТО		30 0		Э		Supports long-
	System Metals		j of	investigated before it can be considered as			LWRS				term
	Aging	reactor pressure	ressure	a mitigation option for RPV embrittlement.							sustainability by
		vessels									addressing
											obsolescence
											and economic
											improvement
15	15.1 Fuel Pool	l Fuel pool		Fuel pool liner cracking is an aging		NDE			2		Supports long-
	Internals	internals aging	aging	degradation issue that can lead to		Program					term
		and		radiation leakage to groundwater or other							sustainability by
		deterioration	tion	clean areas and deterioration of the fuel							addressing
				pool structure. Methods to identify,							opsolescence
				mitigate and repair liners could address							and economic
				this issue.							improvement

nts					
Comments					
AMP				XI.58	
Category					
IMT Gap or MDM Cell					
DOE- LWRS			DOE LWRS		
EPRI Program (Other)		Used Fuel Managemen t & High Level Waste Program	Fuel Reliability Program	ER Program	ER Program
EPRI LTO Status					
Detailed Description	Following the terrorist attacks of September 11, 2001, every U.S. plant conducted a risk assessment against a suite of threats using a nuclear specific, some considerably beyond the Design Basis Requirements of the plant. This exercise confirmed the resiliency of the plants against these threats or identified opportunities to increase this resiliency or plant response. Realistic threat scenarios evolve, and it is appropriate to perform this RAMCAP analysis and other assessments periodically.	ISFSI licenses are generally for 20 years but must be extended much longer for long term operations. An important aging mechanism is hydrogen embrittlement that could affect the ability to transport the fuel or repackage it for transport.	SiC Cladding for Improved Operations	No LTO issues have been identified. These issues might be risks such as coatings which could block containment sumps or coating performance issues for containment liners and buried piping. Issues could be opportunities, such as new coatings which have desirable properties that could enhance safety or reduce costs. Current efforts in ER Program.	A better technical representation of the containment conditions that are used for specifying equipment qualifications could allow equipment to operate longer without repair or replacement and could reduce the procurement costs. A commitment to perform containment temperature monitoring is one consideration; use of a smaller, more accurate source term is another.
Sub-issue Description	Terrorism threat and risk assessment	Hydrogen embrittlement of on-site spent fuel storage installations	Silicon carbide cladding for improved nuclear fuel performance	Coatings issues that could impact long-term operations	Reduction in scope and costs associated with equipment qualification due to less conservative technical assumptions
Primary Issue Description	Plant Security	Nuclear Fuel Design and Performance	Nuclear Fuel Design and Performance	Coatings	Equipment Qualification Improvements
lssue ID (OId)	20.1	5.3	5.1	14.1	13.1
(New)					

Comments		Program Program			EPRI Environmental Sector has the lead in developing a strategy for this issue
AMP					
Category					
IMT Gap or MDM Cell					
DOE- LWRS			DOE CASL	DOE – FCR&D	
EPRI Program (Other)	Equipment Reliability Program	Risk Assessment	CASL	Fuels	Environment al
EPRI LTO Status					
Detailed Description	Monitoring, assessment of degradation, and estimation of RUL using the EPRI BP Works methodology.	Potential plant modifications in response to greater seismic hazards frequencies or to a seismic event was identified in the EPRI study of Life Limiting Issues. It had a relatively high priority among external conditions that could impact life extension. The seismic hazard distribution for plants in the Eastern U.S. has increased in recent years. This increase will increase the seismic risk at plants which could limit operational and design change flexibility in the future.	Advanced design, safety analysis and simulation tool. This tool includes incorporation of results from issue 5.2, models of composite cladding and other advanced fuel designs, advanced mathematical methods, and the experimental campaign to verify the tool.	Advanced fuel designs including new geometries, high enrichment, high power, and high burn-up fuels. This issue is related to the potential benefits from a next series of extended power uprates.	Plant cooling depends on the continued availability of cooling water of suitable temperature, quantity, and quality. In addition, licenses to use the water must be maintained even as other stresses on the watershed increase and environmental expectations for plant discharge could be more challenging. Enhanced cooling technologies, water availability management, and better technical understanding of the plants impact can all contribute to the assurance of long term plant cooling capability.
Sub-issue Description	Application of BPWORKS methodology to estimate remaining useful life	Potential plant modifications in response to greater seismic hazards frequencies or to a seismic event	Advanced design, safety analysis and simulation tools for new nuclear fuel approaches	Advanced nuclear fuel designs (geometries, fuel content, high burnup)	Water availability and quality and enhanced cooling technologies
Primary Issue Description	Underground and BOP Equipment Aging	Seismic Issues	Nuclear Fuel Design and Performance	Nuclear Fuel Design and Performance	Environmental Interface
Issue ID (Old)	10.1	23.1	5.4	5.4	7.1
Issue ID (New)					

Category AMP Comments				
	DOE	> .	E	
Status Program (Other)	PSCR	Chemistry and LLW	I&C Program	
Status			I&C Compatibility Equivalency Database	
Sub-issue Description	Advanced alloys and fabrication methods for reactor internals replacement	Impact of Plant Life Extensions on Low Level Waste (LLW) Management and Decommissionin g Planning	Development of I&C compatibility equivalency database	
Description	Primary System Metals Aging	Low Level Waste	Digital I&C Modernizatio n and Enhanced	Functionality
Issue ID Issue (New) ID (DIO)	1.2	22.1	4.1	

Comments			Plant licensing issues			
AMP						
Category						
IMT Gap or MDM Cell						
DOE- LWRS		DOE CASL				
EPRI Program (Other)	Fuel Users Group	Fuels Program		ANT	NDE Program	Materials/N DE Pgms
EPRI LTO Status						
Detailed Description	Advanced understanding, analysis, and modeling capability of degradation mechanisms for nuclear fuel. Specifically, issues include changes in mechanical properties with exposure, pellet clad interaction, coolant crud chemistry interactions, and mesoscale modeling.	Water chemistry is known to have both positive and deleterious effects on plant materials (including fuel behavior). There are also opportunities to improve operations, perhaps by innovative chemistry changes or nanoparticle addition.	Continued operation of hydro-dams on the same watersheds can jeopardize long term operations if conditions of FERC relicensing are unfavorable. This activity could identify and propose technical solutions to hydro-dam re-licensing issues that could jeopardize long term operation.	Manufacturing capabilities (large components, etc.)	Total in-service inspectability using NDE methods cannot always be achieved due to inaccessibility of the components. Risk informed sampling procedures can be developed and validated where access issues exist.	NDE methods (irreg. welds, vol. exam of CASS and J-grooves, eddy current of SGs)
Sub-issue Description	Advanced understanding, analysis, and modeling of nuclear fuel degradation mechanisms	Effect of water chemistry on fuel behavior over extended operation	Identify and propose technical solutions to hydro-dam relicensing issues that could jeopardize long term operation.	Assessment of large component manufacturing capabilities	Risk-informed sampling for in- service inspection	Nondestructive evaluation methods for irregular welds, cast austenitic stainless steels, J-grooves, etc.
Primary Issue Description	Nuclear Fuel Design and Performance	Nuclear Fuel Design and Performance	Environmental Interface	Integrated, Phased Refurbishmen ts and Uprates	NDE Technology Advancement S	NDE Technology Advancement S
Issue ID (Old)	5.2	5.2	7.2	8.3	11.2	11.3
Issue ID (New)						

Primary Issue	Sub-issue	Detailed Description	EPRI LTO	EPRI	DOE-	IMT Gap or	Category AMP	AMP	Comments
_			Status	Program	LWRS	MDM Cell			
,	_			(Other)					
Leakage		Need to develop a method for NDE of		NDE					
detection	_	CASS. Current inspection method is		Program					
Advancement methods for cast		enhanced VT-1							
austenitic									
stainless steels									
Analytical	_	Extremely low prob. of failure (xLPR – risk		Materials/N					
framework for		informed analysis for hidden welds, etc.)		DE Pgms					
extremely low									
probability of									
rupture									
	_	No LTO issues identified							
		No LTO issues identified		ER Program					
		No LTO issues identified							
	_								

Appendix A
Industry Cost Sharing

(This appendix is proprietary and has special access requirements)