

# HOMER Economic Models – US Navy

Kurt S. Myers  
Jason W. Bush

February 2016



The INL is a U.S. Department of Energy National Laboratory  
operated by Battelle Energy Alliance

#### **DISCLAIMER**

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

## HOMER Economic Models – US Navy

Kurt S. Myers  
Jason W. Bush

February 2016

**Idaho National Laboratory**  
**Originating Organization [optional]**  
**Idaho Falls, Idaho 83415**

<http://www.inl.gov>

Prepared for the  
U.S. Department of Energy  
Office of Energy Efficiency & Renewable Energy  
Under DOE Idaho Operations Office  
Contract DE-AC07-05ID14517

## **CONTENTS**

1.	Introduction .....	1
2.	San Nicholas Island .....	2
2.1	HOMER Analysis .....	2
3.	China Lake.....	10
3.1	HOMER Analysis .....	10
4.	New London.....	20
4.1	HOMER Analysis .....	20
5.	AUTEC.....	30
5.1	HOMER Analysis .....	30
	Appendix A – San Nicholas Scenarios .....	38
	Appendix B – China Lake Scenarios .....	39
	Appendix C – New London Scenarios.....	40
	Appendix D – AUTEC Scenarios .....	41

## **FIGURES**

Figure 1:	Navy locations modeled in HOMER.....	1
Figure 2:	San Nicholas Island HOMER.....	2
Figure 3:	San Nicholas Generator Component .....	3
Figure 4:	San Nicholas PV Component .....	3
Figure 5:	San Nicholas Wind Turbine Component.....	4
Figure 6:	San Nicholas Battery Component .....	4
Figure 7:	San Nicholas Converter Component .....	5
Figure 8:	San Nicholas Solar Resource.....	5
Figure 9:	San Nicholas Temperature Resource.....	6
Figure 10:	San Nicholas Wind Resource .....	6
Figure 11:	San Nicholas Fuel Resource.....	7
Figure 12:	San Nicholas Electrical Load .....	7
Figure 13:	China Lake HOMER .....	10
Figure 14:	China Lake Generator Component .....	11
Figure 15:	China Lake Sun Power PV Component .....	11

Figure 16: China Lake PV Distributed Component .....	12
Figure 17: China Lake Additional PV Component.....	12
Figure 18: China Lake Wind Turbine Component .....	13
Figure 19: China Lake Battery Component .....	13
Figure 20: China Lake Converter Component.....	14
Figure 21: China Lake Grid Component.....	14
Figure 22: China Lake Solar Resource .....	15
Figure 23: China Lake Wind Resource.....	15
Figure 24: China Lake Temperature Resource .....	16
Figure 25: China Lake Fuel Resource.....	16
Figure 26: China Lake Electric Load.....	17
Figure 27: New London HOMER.....	20
Figure 28: New London Generator Component 1.....	21
Figure 29: New London Generator Component 2.....	21
Figure 30: New London PV Component .....	22
Figure 31: New London Wind Turbine Component.....	22
Figure 32: New London Battery Component.....	23
Figure 33: New London Converter Component.....	23
Figure 34: New London Grid Component .....	24
Figure 35: New London Solar Resource.....	24
Figure 36: New London Wind Resource .....	25
Figure 37: New London Temperature Resource.....	25
Figure 38: New London Fuel Resource .....	26
Figure 39: New London Electric Load .....	26
Figure 40: AUTEC HOMER .....	30
Figure 41: AUTEC Generator Component .....	31
Figure 42: AUTEC PV Component .....	31
Figure 43: AUTEC Wind Turbine Component.....	32
Figure 44: AUTEC Battery Component .....	32
Figure 45: AUTEC Converter Component .....	33
Figure 46: AUTEC Solar Resource .....	33
Figure 47: AUTEC Wind Resource .....	34
Figure 48: AUTEC Temperature Resource .....	34
Figure 49: AUTEC Fuel Resource.....	35
Figure 50: AUTEC Electric Load .....	35


## TABLES

Table 1: San Nicholas Weekday Electrical Load Profile.....	8
Table 2: San Nicholas Weekend Electrical Load Profile.....	8
Table 3: San Nicholas Sensitivity & Optimization Results .....	9
Table 4: China Lake Weekday Electrical Load Profile .....	17
Table 5: China Lake Weekend Electrical Load Profile .....	18
Table 6: China Lake Grid-tied Sensitivity & Optimization Results .....	19
Table 7: China Lake Island Sensitivity & Optimization Results .....	19
Table 8: New London Weekday Electrical Load Profile .....	27
Table 9: New London Weekend Electrical Load Profile .....	27
Table 10: New London Grid-tied Sensitivity & Optimization Results.....	28
Table 11: New London Island Sensitivity & Optimization Results.....	29
Table 12: AUTEC Weekday Electrical Load Profile.....	36
Table 13: AUTEC Weekend Electrical Load Profile.....	36
Table 14: AUTEC Sensitivity & Optimization Results .....	37

# HOMER Economic Models – US Navy

## 1. Introduction

Figure 1: Navy locations modeled in HOMER




This LETTER REPORT has been prepared by Idaho National Laboratory for US Navy NAVFAC EXWC to support in testing pre-commercial SIREN (Simulated Integration of Renewable Energy Networks) computer software models. In the logistics mode SIREN software simulates the combination of renewable power sources (solar arrays, wind turbines, and energy storage systems) in supplying an electrical demand. NAVFAC EXWC will create SIREN software logistics models of existing or planned renewable energy projects at five Navy locations (San Nicolas Island, AUTEC, New London, & China Lake), and INL will deliver additional HOMER computer models for comparative analysis. In the transient mode SIREN simulates the short time-scale variation of electrical parameters when a power outage or other destabilizing event occurs. In the HOMER model, a variety of inputs are entered such as location coordinates, Generators, PV arrays, Wind Turbines, Batteries, Converters, Grid costs/usage, Solar resources, Wind resources, Temperatures, Fuels, and Electric Loads. HOMER's optimization and sensitivity analysis algorithms then evaluate the economic and technical feasibility of these technology options and account for variations in technology costs, electric load, and energy resource availability. The Navy can then use HOMER's optimization and sensitivity results to compare to those of the SIREN model.

The U.S. Department of Energy (DOE) Idaho National Laboratory (INL) possesses unique expertise and experience in the software, hardware, and systems design for the integration of renewable energy into the electrical grid. NAVFAC EXWC will draw upon this expertise to complete mission requirements.

## 2. San Nicholas Island

### 2.1 HOMER Analysis

Figure 2: San Nicholas Island HOMER



The HOMER (Hybrid Optimization of Multiple Energy Resources) model greatly simplifies the task of designing hybrid renewable microgrids, whether remote or attached to a larger grid. HOMER's optimization and sensitivity analysis algorithms allow you to evaluate the economic and technical feasibility of a large number of technology options and to account for variations in technology costs, electric load, and energy resource availability.

For San Nicholas Island inputs we have included:

- 1 – 1150kW Generator
- 7 – 100kW Northern Power Wind Turbines
- Flat panel fixed PV up from 250kW up to 2000kW
- 280kW/1MWh Primus Power EnergyPod Battery (allowed up to 4)
- System Converter up to 2000kW

This model used the location coordinates of  $33^{\circ} 15.05' N$ ,  $119^{\circ} 29.97' W$  and wind resource data from the 50m NREL Met tower. The solar resource was downloaded from the NREL Solar database and the electrical load data was analysis of spreadsheet data provided for Dec13, Jan14, Feb14, Jun14, Jul14, & Aug14. Homer requires 1 year of hourly/monthly data so a linear interpolation algorithm was used to fill

in the missing months. A temperature resource was also included and was downloaded from NASA's surface and solar database. Refer to following figures:

**Figure 3: San Nicholas Generator Component**

The screenshot shows the 'GENERATOR' component configuration screen. Key settings include:

- Name:** Generic1150kW Prime Pow
- Abbreviation:** Gen115
- Properties:**
  - Name: Generic1150kW Prime Power
  - Abbreviation: Gen1150
  - Manufacturer: Generic
  - Website:
- Costs:**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/hr)
3100	\$2,000,000.00	\$2,000,000.00	\$11.50
12400	\$8,000,000.00	\$8,000,000.00	\$34.50
- Site Specific Input:**
  - Minimum Load Ratio (%): 30.00
  - Heat Recovery Ratio (%): 0.00
  - Lifetime (Hours): 15,000.00
  - Minimum Runtime (Minutes): 0.00
- Fuel Resource:** Diesel (selected)
- Properties (Fuel Details):**
  - Lower Heating Value (MJ/kg): 43.2
  - Density (kg/m<sup>3</sup>): 820
  - Carbon Content (%): 88
  - Sulfur Content (%): 0.33
- Electrical Bus:** AC

**Figure 4: San Nicholas PV Component**

The screenshot shows the 'PV' component configuration screen. Key settings include:

- Name:** Generic flat plate PV
- Abbreviation:** PV
- Properties:**
  - Name: Generic flat plate PV
  - Abbreviation: PV
  - Panel Type: Flat plate
  - Rated Capacity (kW): 0
  - Manufacturer: Generic
  - Weight (lbs): 160
  - Footprint (in<sup>2</sup>): 9000
  - Website: [www.homerenergy.com](http://www.homerenergy.com)
- Costs:**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$3,000.00	\$3,000.00	\$20.00
- Site Specific Input:**
  - Lifetime (years): 25.00
  - Derating Factor (%): 80.00
- Electrical Bus:** AC
- Search Space (Size):** 0, 1000, 2000, 250, 500, 750
- Efficiency Table:**

Input Percentage (%)	Efficiency (%)
Click here to add new item	

Figure 5: San Nicholas Wind Turbine Component




Figure 6: San Nicholas Battery Component




Figure 7: San Nicholas Converter Component

**CONVERTER**

Name: System Converter Abbreviation: Convert Remove Copy To Library

**Properties**

- Name: System Converter
- Abbreviation: Converter
- Manufacturer: Generic
- Weight (lbs): 1500
- Footprint (in<sup>2</sup>): 2000
- Website: [www.homerenergy.com](http://www.homerenergy.com)
- Notes:  
This is a generic system converter.

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$300.00	\$300.00	\$0.0

Click here to add new item

**Search Space**

Size (kW)

- 0
- 500
- 750
- 1000
- 1500
- 2000
- 3000

**Inverter Input**

Lifetime (years): 15.00  
Efficiency (%): 90.00

Parallel with AC generator?

**Rectifier Input**

Relative Capacity (%): 100.00  
Efficiency (%): 85.00

Figure 8: San Nicholas Solar Resource




Figure 9: San Nicholas Temperature Resource




Figure 10: San Nicholas Wind Resource




Figure 11: San Nicholas Fuel Resource

**FUEL RESOURCE** 

You may add a fuel from the library to model:

Diesel

**FUELS AVAILABLE IN MODEL**

Name	LHV	Density	Carbon	Sulfur	Special
Diesel	43.2	820	88	0.33	X

**Selected Fuel**  
Name: Diesel

**PROPERTIES**


Lower Heating Value (MJ/kg): 43.20  
Density (kg/m<sup>3</sup>): 820.00  
Carbon Content (%): 88.00  
Sulfur Content (%): 0.33

**Fuel Type**  
 Conventional  
 Stored Hydrogen  
 Uses biomass resource

**Limits and Prices**

Diesel Fuel Price (\$/L): 1.00   
 Limit Consumption (L): 5,000.00   
 Units: L

Figure 12: San Nicholas Electrical Load





Two of the components are already at SNI (Wind Turbines & Generator). Inputs for these two components were set so HOMER always looks at using the 7 wind turbines and the 1 genset. HOMER then has the option to consider different amounts of PV & batteries, and different size system converter. These are the simulation results produced for the optimization cases:

**Table 3: San Nicholas Sensitivity & Optimization Results**

**RESULTS**

Sensitivity Cases: Left Click on sensitivity case to see optimization cases.

Architecture		Cost						System						Gen1150						
PV (kW)	NPS100C-21 (kW)	Gen1150 (kW)	GS200 flow (kW)	Converter (kW)	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Fuel cost (\$)	O&M (\$)	Ren. Frac (%)	Total Fuel (kWh/yr)	Cap Short (kWh/yr)	Elec Prod. (kWh/yr)	Elec Cons. (kWh/yr)	Excess Elec. (kWh/yr)	Unmet load (kWh/yr)	Hours	Production (kWh)	Fuel (l)
750	7	1150	6	1,000	\$0.406	\$27.3M	\$1.28M	\$10.8M	\$870.316	\$175,449	36	870315.8	0	6074329	5205935	132564.9	0.01486206	3,901	3,347,365	870.316

Optimization Cases: Left Double Click on simulation to examine details.


Architecture		Cost						System						Gen1150						
PV (kW)	NPS100C-21 (kW)	Gen1150 (kW)	GS200 flow (kW)	Converter (kW)	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Fuel cost (\$)	O&M (\$)	Ren. Frac (%)	Total Fuel (kWh/yr)	Cap Short (kWh/yr)	Elec Prod. (kWh/yr)	Elec Cons. (kWh/yr)	Excess Elec. (kWh/yr)	Unmet load (kWh/yr)	Hours	Production (kWh)	Fuel (l)
750	7	1150	6	1,000	\$0.406	\$27.3M	\$1.28M	\$10.8M	\$870.316	\$175,449	36	870315.8	0	6074329	5205935	132564.9	0.01486206	3,901	3,347,365	870.316
750	7	1150	6	750	\$0.424	\$28.5M	\$1.55M	\$8.44M	\$1.03M	\$175,747	24	10286866	0	5558297	5205935	12119.36	0.01719666	6,192	3,956,489	1,028,666
750	7	1150	6	500	\$0.425	\$28.6M	\$1.73M	\$8.27M	\$1.08M	\$176,481	20	1080623	0	5758145	5205935	5522041	0.02215576	8,758	4,156,337	1,080,622
750	7	1150	6	500	\$0.432	\$29.1M	\$1.69M	\$7.17M	\$1.04M	\$183,434	23	1035697	0	5960427	5205935	735565.8	0.0256958	8,751	3,983,576	1,035,697

The top case (HOMER optimized selection) includes 750 kW PV, 7 - 100kW wind turbines, 1150kW Genset, 6 Vizn GS200 Flow batteries (1MW) and a 1MW system converter. For this case the cost of energy is calculated at \$0.406 and the renewable fraction is 36%. With the input parameters HOMER was given the above cases were the only ones found feasible. See case pdf's for further details on each simulation.

### 3. China Lake

#### 3.1 HOMER Analysis

Figure 13: China Lake HOMER



The HOMER (Hybrid Optimization of Multiple Energy Resources) model greatly simplifies the task of designing hybrid renewable microgrids, whether remote or attached to a larger grid. HOMER's optimization and sensitivity analysis algorithms allow you to evaluate the economic and technical feasibility of a large number of technology options and to account for variations in technology costs, electric load, and energy resource availability.

Multiple inputs are entered into the HOMER model such as location coordinates of  $35^{\circ} 39.1' N$ ,  $117^{\circ} 39.7' W$  which is near Naval Air Weapons Station China Lake's main gate. Resources and components are the main inputs that are needed to make a HOMER model. For China Lake the components used consist of Generator, PV, Wind Turbine, Battery, Converter and the Grid. INL has created cost inputs for these components based on vendor/market data and past experience. The resource inputs created for China Lake consist of Solar, Wind, Temperature, Fuels, and Electric Load. Refer to figures (1 - 11). The solar, wind, & temperature resources were downloaded from the NASA Surface meteorology and Solar Energy database and contained monthly averaged values for a 10 to 22 year period (1983 – 2005). The fuel resource consists of a Diesel profile that was generated from current market information. The electrical load data was an analysis of naval power load spreadsheet data provided for the year 2010. Based on the power data HOMER estimates annual peak load as 27,191.86 kW. Grid purchase inputs are then set as 12000, 15000, 20000, 25000, & 27200 kW with grid sales set as 0 kW. Note in the China Lake model; both the grid-tied and off-grid (island) systems are modeled.

Figure 14: China Lake Generator Component

The screenshot shows the configuration interface for a 'GENERATOR' component. At the top, it displays the component name as 'Kohler 3250 Prime Power' and its abbreviation as 'KHLR32'. On the right side, there are buttons for 'Remove', 'Copy To Library', and a search bar for 'Search Space' with a dropdown menu showing size options: 2800, 5600, 8400, 11200, 14000, and 0. Below the search bar are buttons for 'Electrical Bus' (AC and DC).

**Properties:**

- Name: Kohler 3250 Prime Power
- Abbreviation: KHLR32
- Manufacturer: Kohler
- Website:

**Costs:**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/hr)
1	\$1,000.00	\$1,000.00	\$0.015
1000	\$1,000,000.00	\$1,000,000.00	\$15.00

**Site Specific Input:**

- Minimum Load Ratio (%): 25.00
- Heat Recovery Ratio (%): 0.00
- Lifetime (Hours): 15,000.00
- Minimum Runtime (Minutes): 0.00

**Fuel Resource:** Diesel Fuel Price (\$/L): 0.79

**Properties (Diesel Fuel):**

- Lower Heating Value (MJ/kg): 43.2
- Density (kg/m<sup>3</sup>): 820
- Carbon Content (%): 88
- Sulfur Content (%): 0.33

**Limit Consumption (L):** 5,000.00

Figure 15: China Lake Sun Power PV Component

The screenshot shows the configuration interface for a 'PV' component. At the top, it displays the component name as 'SunPower PV' and its abbreviation as 'PV'. On the right side, there are buttons for 'Remove', 'Copy To Library', and a search bar for 'Search Space' with a dropdown menu showing size options: 13780. Below the search bar are buttons for 'Electrical Bus' (AC and DC).

**Properties:**

- Name: SunPower PV
- Abbreviation: PV
- Panel Type: Flat plate
- Rated Capacity (kW): 13780
- Manufacturer: Generic
- Weight (lbs): 160
- Footprint (in<sup>2</sup>): 9000
- Website: [www.homerenergy.com](http://www.homerenergy.com)

**Costs:**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
2000	\$6,000.00	\$6,000,000.00	\$30,000.00
5000	\$14,750.00	\$14,750,000.00	\$55,000.00

**Site Specific Input:**

- Lifetime (years): 25.00
- Derating Factor (%): 80.00

**MPPT Advanced Input Temperature:**

Ignore dedicated converter

Lifetime (years): 15.00

**Costs:**

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$300.00	\$300.00	\$0.00

**Efficiency Table:**

Search Space: Size (kW) 1000, 1500

Use Efficiency Table?

Efficiency (%): 95

Input Percentage (%)	Efficiency (%)
Click here to add new item	

Figure 16: China Lake PV Distributed Component




Figure 17: China Lake Additional PV Component




Figure 18: China Lake Wind Turbine Component




Figure 19: China Lake Battery Component




Figure 20: China Lake Converter Component

**CONVERTER**

Name: System Converter Abbreviation: Convert Remove Copy To Library

**Properties**

Name: System Converter	Abbreviation: Converter
Manufacturer: Generic	Weight (lbs): 1500
Footprint (in <sup>2</sup> ): 2000	Website: <a href="http://www.homerenergy.com">www.homerenergy.com</a>
Notes: This is a generic system converter.	

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)	
1	\$300.00	\$300.00	\$0.0	X

Click here to add new item

**Search Space**

Size (kW)
2000
5000
10000
15000
20000

Multiplier:

**Inverter Input**

Lifetime (years):	15.00	<input type="button" value="..."/>
Efficiency (%):	90.00	<input type="button" value="..."/>

Parallel with AC generator?

**Rectifier Input**

Relative Capacity (%):	100.00	<input type="button" value="..."/>
Efficiency (%):	85.00	<input type="button" value="..."/>

Figure 21: China Lake Grid Component

**ADVANCED GRID**

Name: Grid Abbreviation: Grid Remove Copy To Library

Simple Rates  Real Time Rates  Scheduled Rates  Grid Extension

**Scheduled Rates**

**Parameters**

Sale capacity (kW):	0.00	<input type="button" value="..."/>
---------------------	------	------------------------------------

**Purchase Capacity**

Annual Purchase Capacity

Search Space

Capacity (kW)
27200
25000
20000
15000
12000

Monthly Purchase Capacity

Monthly

**Systems to consider**

Simulate systems with and without the grid  Include the grid in all simulations

**Net Metering**

Net purchases calculated monthly.  Net purchases calculated annually.

**Maximum net grid purchases:**

Limit (kWh/yr):	0.00	<input type="button" value="..."/>
-----------------	------	------------------------------------

**Grid Extension Costs**

Grid capital cost (\$/km): 0.00

Distance (km): 0.00

**Distributed Generation Costs**

Interconnection charge (\$):	0.00	<input type="button" value="..."/>
Standby charge (\$/yr):	0.00	<input type="button" value="..."/>

Figure 22: China Lake Solar Resource



Figure 23: China Lake Wind Resource




Figure 24: China Lake Temperature Resource





Figure 25: China Lake Fuel Resource










## 4. New London

### 4.1 HOMER Analysis

Figure 27: New London HOMER



The HOMER (Hybrid Optimization of Multiple Energy Resources) model greatly simplifies the task of designing hybrid renewable microgrids, whether remote or attached to a larger grid. HOMER's optimization and sensitivity analysis algorithms allow you to evaluate the economic and technical feasibility of a large number of technology options and to account for variations in technology costs, electric load, and energy resource availability.

Multiple inputs are entered into the HOMER model such as location coordinates of  $41^{\circ} 23.4' N$ ,  $72^{\circ} 5.2' W$  which is near Grayling Ave on Naval Submarine Base New London. Resources and components are the main inputs that are needed to make a HOMER model. For New London the components used consist of Generator, PV, Wind Turbine, Battery, Converter and the Grid. INL has created cost inputs for these components based on vendor/market data and past experience. The resource inputs created consist of Solar, Wind, Temperature, Fuels, and Electric Load. Refer to figures (1 - 9). The solar, wind, & temperature resources were downloaded from the NASA Surface meteorology and Solar Energy database and contained monthly averaged values for a 10 to 22 year period (1983 – 2005). The fuel resource consists of a Diesel profile that was generated from current market information. The electrical load data was an analysis of naval power load spreadsheet data provided for the year 2013. Based on the power data HOMER estimates annual peak load as 24,984.38 kW. Grid purchase inputs are then set as 12000, 15000, 20000, 25000, & 27200 kW with grid sales set as 0 kW. Note in the New London model; both the grid-tied and off-grid (island) systems are modeled.

Figure 28: New London Generator Component 1

**GENERATOR**

Name: Kohler 1000 Prime Power Abbreviation: KHLR100

**Properties**

Name: Kohler 1000 Prime Power  
Abbreviation: KHLR100  
Manufacturer: Kohler  
Website:

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/hr)
1	\$1,000.00	\$1,000.00	\$0.015
1000	\$1,000,000.00	\$1,000,000.00	\$15.00

Multiplier: (..) (..) (..)

**Site Specific Input**

Minimum Load Ratio (%): 25.00 (..) Heat Recovery Ratio (%): 0.00 (..)  
Lifetime (Hours): 15,000.00 (..) Minimum Runtime (Minutes): 0.00 (..)

**Fuel Resource** Fuel Curve Biogas Emissions Maintenance Schedule

**SELECT FUEL:** Diesel **Manage Fuels**

**PROPERTIES**

Lower Heating Value (MJ/kg): 43.2  
Density (kg/m<sup>3</sup>): 820  
Carbon Content (%): 88  
Sulfur Content (%): 0.33

Diesel Fuel Price (\$/L): 0.79 (..) Limit Consumption (L): 5,000.00 (..)

**Search Space**

Size (kW)

925  
1850  
2775  
3700  
0

Electrical Bus AC DC

Figure 29: New London Generator Component 2

**GENERATOR**

Name: Kohler 750 Prime Power Abbreviation: KHLR75

**Properties**

Name: Kohler 750 Prime Power  
Abbreviation: KHLR75  
Manufacturer: Kohler  
Website:

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/hr)
1	\$1,000.00	\$1,000.00	\$0.015
1000	\$1,000,000.00	\$1,000,000.00	\$15.00

Multiplier: (..) (..) (..)

**Site Specific Input**

Minimum Load Ratio (%): 25.00 (..) Heat Recovery Ratio (%): 0.00 (..)  
Lifetime (Hours): 15,000.00 (..) Minimum Runtime (Minutes): 0.00 (..)

**Fuel Resource** Fuel Curve Biogas Emissions Maintenance Schedule

**SELECT FUEL:** Diesel **Manage Fuels**

**PROPERTIES**

Lower Heating Value (MJ/kg): 43.2  
Density (kg/m<sup>3</sup>): 820  
Carbon Content (%): 88  
Sulfur Content (%): 0.33

Diesel Fuel Price (\$/L): 0.79 (..) Limit Consumption (L): 5,000.00 (..)

**Search Space**

Size (kW)

690  
1380  
2070  
2760  
0

Electrical Bus AC DC

Figure 30: New London PV Component

**PV** 

Name: Solar World 320W flat plat Abbreviation: PV

**Properties**

Name: Solar World 320W flat plate PV Copy
Abbreviation: PV
Panel Type: Flat plate
Rated Capacity (kW): 0
Manufacturer: Generic
Weight (lbs): 160
Footprint (in2): 9000
Website: <a href="http://www.homerenergy.com">www.homerenergy.com</a>

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$3,000.00	\$3,000.00	\$15.00

Click here to add new item

Multiplier:

**Site Specific Input**

Lifetime (years):	25.00	<input type="button" value="{}"/>
Derating Factor (%):	80.00	<input type="button" value="{}"/>

**Search Space** 

Size (kW)
0
1000
1500
2000

**Electrical Bus**  AC  DC

**MPPT Advanced Input Temperature**

Ignore dedicated converter

Lifetime (years): 15.00

**Costs**

Size (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
2000	\$500,000	\$500,000.00	\$5,000.00

Click here to add new item

**Search Space**

Use Efficiency Table?

Size (kW)
0
4000
9000
14000
17000

Efficiency (%): 95

Input Percentage (%)	Efficiency (%)
----------------------	----------------

Click here to add new item

Figure 31: New London Wind Turbine Component

**WIND TURBINE** 

Name: Siemens 2.3 MW - 108 Abbreviation: S2300

**Properties**

Name: Siemens 2.3 MW - 108
Abbreviation: S2300
Rated Capacity (kW): 2300.00
Manufacturer: Siemens

**Costs**

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$4,500,000.00	\$4,500,000.00	\$75,000.00

Click here to add new item

Multiplier:

**Site Specific Input**

Lifetime (years):	20.00	<input type="button" value="{}"/>	Hub Height (m):	80.00	<input type="button" value="{}"/>
-------------------	-------	-----------------------------------	-----------------	-------	-----------------------------------

Consider ambient temperature effects?


**Search Space**

Quantity
0
5
10

**Electrical Bus**  AC  DC

**Power Curve** **Turbine Losses** **Maintenance**

**Wind Turbine Power Curve**



Wind Speed (m/s)	Power Output (kW)
0	0
3.5	35
4	140
5	290
6	550

Figure 32: New London Battery Component

### BATTERY

Name: GS200 flow
Abbreviation: GS200 f
[Remove](#)
[Copy To Library](#)

**Properties**

Name: GS200 flow  
Abbreviation: GS200 flow  
Manufacturer: Zinc Battery Model  
Nominal Voltage (V): 100  
Nominal Capacity (Ah): 6,000  
Nominal Capacity (kWh): 600  
Round Trip Efficiency (%): 70.0  
Float Life (years): 25.0  
Cell stack replacement interval (yrs): 10.0  
Electrolyte replacement interval (yrs): 125  
Max. Charge Rate (A/Ah): 0.250  
Max. Charge Current (A): 1,500  
Max. Discharge Current (A): 2,200  
Website:  
Notes:

**Costs**

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$324,589.00	\$32,489.00	\$2,400.00
6	\$1,947,535.00	\$194,753.00	\$14,400.00

[Click here to add new item](#)

Multiplier:

**Search Space**

Batteries
0
1
2
3
4
5
6

Figure 33: New London Converter Component

### CONVERTER

Name: System Converter
Abbreviation: Convert
[Remove](#)
[Copy To Library](#)

**Properties**

Name: System Converter  
Abbreviation: Converter  
Manufacturer: Generic  
Weight (lbs): 1500  
Footprint (in<sup>2</sup>): 2000  
Website: [www.homerenergy.com](http://www.homerenergy.com)  
Notes:  
This is a generic system converter.

**Costs**

Capacity (kW)	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$300.00	\$300.00	\$0.0

[Click here to add new item](#)

Multiplier:

**Search Space**

Size (kW)
250
500
750
1000
1500
2000
0

**Inverter Input**

Lifetime (years):   Efficiency (%):

Parallel with AC generator?

**Rectifier Input**

Relative Capacity (%):   Efficiency (%):

Figure 34: New London Grid Component

**ADVANCED GRID**  Name:  Abbreviation:  Remove Copy To Library Grid

Simple Rates  Real Time Rates  Scheduled Rates  Grid Extension

### Scheduled Rates

- [Parameters](#) [Rate Definition](#) [Demand Rates](#) [Reliability](#) [Emissions](#)

Sale capacity (kW):	<input type="text" value="0.00"/>	<a href="#">[...]</a>
Purchase Capacity		
<input checked="" type="radio"/> Annual Purchase Capacity	<input type="checkbox"/> Simulate systems with and without the grid	
<input checked="" type="radio"/> Include the grid in all simulations		
<input type="checkbox"/> Net Metering		
<input checked="" type="radio"/> Net purchases calculated monthly.		
<input type="radio"/> Net purchases calculated annually.		
Search Space		
<input type="text" value="25000"/> <input type="text" value="20000"/> <input type="text" value="10000"/>		
<input checked="" type="radio"/> Monthly Purchase Capacity	<input type="radio"/> Limit (kWh/yr)	<input type="text" value="0.00"/>
<a href="#">Monthly</a>	<a href="#">[...]</a>	<a href="#">[...]</a>
Maximum net grid purchases:		
<input type="checkbox"/> Grid capital cost (\$/km)	<input type="text" value="0.00"/>	<a href="#">[...]</a>
Grid Extension Costs		
Distance (km):	<input type="text" value="0.00"/>	<a href="#">[...]</a>
Distributed Generation Costs		
Interconnection charge (\$):	<input type="text" value="0.00"/>	<a href="#">[...]</a>
Standby charge (\$/yr):	<input type="text" value="0.00"/>	<a href="#">[...]</a>

Figure 35: New London Solar Resource




Figure 36: New London Wind Resource




Figure 37: New London Temperature Resource




Figure 38: New London Fuel Resource

**FUEL RESOURCE**

You may add a fuel from the library to model:

**Diesel**

Name	LHV	Density	Carbon	Sulfur	Special
Diesel	43.2	820	88	0.33	X
Natural Gas	45	0.790	67	0.33	X

**Selected Fuel**  
Name: Diesel

**PROPERTIES**

Lower Heating Value (MJ/kg): 43.20  
Density (kg/m<sup>3</sup>): 820.00  
Carbon Content (%): 88.00  
Sulfur Content (%): 0.33

**Fuel Type**  
 Conventional  
 Stored Hydrogen  
 Uses biomass resource

**Limits and Prices**  
Diesel Fuel Price (\$/L): 0.79   
Limit Consumption (L): 5,000.00   
Units: L

Figure 39: New London Electric Load







Island:

**Table 11: New London Island Sensitivity & Optimization Results**


Architecture										Optimization Cases: Left Double Click on simulation to examine details.									
					Cost					System									
	PV (kW)	S2300 (kW)	KHRL3250 (kW)	GS200 flow (kW)	Converter (kW)	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Fuel cost (\$)	O&M (\$)	Ren. Frac (%)	Total Fuel (L)	Cap Short (kWh/yr)	Elec Prod (kWh/yr)	Elec Cons (kWh/yr)	Excess Elec (kWh/yr)	Unmet load (kWh/yr)	
+	5,000	15	16,800	60	24,000	\$0.263	\$330M	\$17.1M	\$109M	\$9.31M	\$2.83M	48	1.178428E+07	2328.557	1.409198E+08	9.686416E+07	3.557973E+07	0.1142578	
+	30,000		16,800	80	24,000	\$0.265	\$331M	\$16.0M	\$124M	\$8.61M	\$2.74M	52	1.090267E+07	2328.557	1.436092E+08	9.686416E+07	3.824639E+07	0.15625	
+	5,000	15	19,600		24,000	\$0.342	\$428M	\$22.4M	\$138M	\$14.3M	\$3.90M	20	1.81035E+07	27528.73	1.158162E+08	9.685917E+07	1550152	4992.927	
+	5,000		30	19,600		\$0.351	\$443M	\$26.0M	\$107M	\$10.2M	\$7.18M	44	1.297352E+07	95672.95	1.516524E+08	9.68593E+07	5.455211E+07	7857.158	
+			16,800	80	24,000	\$0.370	\$463M	\$32.1M	\$148M	\$20.8M	\$4.93M	0.0	2.634808E+07	95012.64	1.122919E+08	9.682149E+07	0.2796204	42667.16	
+				22,400		\$0.405	\$507M	\$37.7M	\$19.8M	\$18.2M	\$8.56M	0.0	2.301123E+07	52841.31	9.703326E+07	9.685865E+07	174600.8	5506.633	
+	5,000		22,400		24,000	\$0.415	\$520M	\$37.0M	\$42.0M	\$17.2M	\$8.63M	5.5	2.174392E+07	26735.8	9.801737E+07	9.686201E+07	54735.5	1350.797	

With the input parameters HOMER was given these were the only cases it found feasible. See case pdf's in appendix for further details on each simulation.

## 5. AUTEC

### 5.1 HOMER Analysis

Figure 40: AUTEC HOMER



The HOMER (Hybrid Optimization of Multiple Energy Resources) model greatly simplifies the task of designing hybrid renewable microgrids, whether remote or attached to a larger grid. HOMER's optimization and sensitivity analysis algorithms allow you to evaluate the economic and technical feasibility of a large number of technology options and to account for variations in technology costs, electric load, and energy resource availability.

For Autec inputs we have included:

- Up to 5 – 3250kW Generator
- Up to 3 – 2300kW Siemens 108 Wind Turbines
- Flat panel fixed PV up to 4000kW
- 1MW/3MWh Primus Power EnergyPod Battery (allowed up to 20)
- System Converter up to 5000kW

This model used the location coordinates of 24° 42.3' N, 77° 46.2' W and wind & solar resource data from NASA's surface and solar database. The electrical load data was not provided for Autec so an interpolated load was created from other similar military base average load data. Needless to say, the more accurate the data a model has, the more accurate the results are; any actual Autec load data could

improve model accuracy. A temperature resource was included and was also downloaded from NASA's surface and solar database. Refer to following figures:

Figure 41: AUTEC Generator Component




Figure 42: AUTEC PV Component




Figure 43: AUTEC Wind Turbine Component

### WIND TURBINE

Name: Siemens 2.3 MW - 108
Abbreviation: S2300
Remove
Copy To Library

**Properties**

Name: Siemens 2.3 MW - 108
Abbreviation: S2300
Rated Capacity (kW): 2300.00
Manufacturer: Siemens

**Costs**

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$4,500,000.00	\$4,500,000.00	\$75,000.00

Click here to add new item

Multiplier:

Consider ambient temperature effects?
**Search Space**

AC
 DC

**Power Curve**
**Turbine Losses**
**Maintenance**

Wind Speed (m/s)	Power Output (kW)
0	0
3.5	35
4	140
5	290
6	550

**Wind Turbine Power Curve**

Figure 44: AUTEC Battery Component

### BATTERY

Name: GS200 flow
Abbreviation: GS200 f
Remove
Copy To Library

**Properties**

Name: GS200 flow
Abbreviation: GS200 flow
Manufacturer:
Zinc Battery Model
Nominal Voltage (V): 100
Nominal Capacity (Ah): 6,000
Nominal Capacity (kWh): 600
Round Trip Efficiency (%): 70.0
Float Life (years): 25.0
Cell stack replacement interval (yrs): 10.0
Electrolyte replacement interval (yrs): 125
Max. Charge Rate (A/Ah): 0.250
Max. Charge Current (A): 1,500
Max. Discharge Current (A): 2,200
Website:
Notes:

**Costs**

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/year)
1	\$324,589.00	\$32,489.00	\$2,400.00
6	\$1,947,535.0	\$194,753.00	\$14,400.00

Click here to add new item

Multiplier:

**Search Space**
**Batteries**

0
 6
 8
 10
 12
 15
 20

**Site Specific Input**

Batteries per string:  (100 V bus)

Initial State of Charge (%):

Cell stack cost (% of total replacement cost)

Figure 45: AUTEC Converter Component

Figure 46: AUTEC Solar Resource




Figure 47: AUTEC Wind Resource




Figure 48: AUTEC Temperature Resource




Figure 49: AUTEC Fuel Resource

The screenshot shows the 'FUEL RESOURCE' section of the AUTEC software. On the left, a table lists 'FUELS AVAILABLE IN MODEL' with one entry: Diesel (43.2 LHV, 820 Density, 88 Carbon, 0.33 Sulfur). A dropdown menu shows 'Diesel' selected, and there's an 'Add' button. On the right, the 'Selected Fuel' is set to 'Diesel'. Properties listed include Lower Heating Value (43.20 MJ/kg), Density (820.00 kg/m³), Carbon Content (88.00 %), and Sulfur Content (0.33 %). Under 'Fuel Type', 'Conventional' is selected. In the 'Limits and Prices' section, Diesel Fuel Price is set to \$1.00/L, and Limit Consumption is set to 5,000.00 L. Units are set to L. A 'Copy To Library' button is at the bottom.

Figure 50: AUTEC Electric Load





HOMER has the option to consider different amounts of generator, wind, PV, batteries, and different size system converter. These are the simulation results produced for the optimization cases:

**Table 14: AUTEC Sensitivity & Optimization Results**

RESULTS															
Sensitivity Results: Left Click on a sensitivity case to see its Optimization Results															
Architecture					Cost					System	KHLR3250				
PV (kW)	S2300	KHLR3250 (kW)	GS200 flow	Converter (kW)	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Ren Frac (%)	Hours	Production	Fuel (L)	O&M Cost	Fuel Cost	
2	3,250	12	2,000	\$0.261	\$47.4M	\$2.44M	\$15.8M	48	3,261	7,356,060	1,697,178	32,973	1,697,178		
Optimization Results: Left Double Click on a particular system to see its detailed Simulation Results															
Architecture					Cost					System	KHLR3250				
PV (kW)	S2300	KHLR3250 (kW)	GS200 flow	Converter (kW)	COE (\$)	NPC (\$)	Operating cost (\$)	Initial capital (\$)	Ren Frac (%)	Hours	Production	Fuel (L)	O&M Cost	Fuel Cost	
2	3,250	12	2,000	\$0.261	\$47.4M	\$2.44M	\$15.8M	48	3,261	7,356,060	1,697,178	32,973	1,697,178		
2,000	3,250	15	3,000	\$0.267	\$48.6M	\$1.97M	\$23.1M	62	2,777	5,318,756	1,256,194	28,079	1,256,194		
4,000	3,250	10	3,000	\$0.323	\$58.8M	\$3.12M	\$18.5M	24	4,051	10,696,306	2,419,964	40,961	2,419,964		
2,000	2	3,250	1,000	\$0.331	\$60.1M	\$3.29M	\$17.6M	46	6,585	7,640,236	1,984,332	66,583	1,984,332		
	3,250	6	1,000	\$0.362	\$65.8M	\$4.73M	\$4.59M	0.0	7,834	14,686,122	3,480,112	79,212	3,480,112		
	3,250		2,000	\$0.362	\$65.9M	\$4.17M	\$11.9M	20	8,245	11,192,983	2,809,968	83,368	2,809,968		

The top case (HOMER optimized selection) includes 2 - 2300kW wind turbines, 1 - 3250kW Genset, 12 Vzn GS200 Flow batteries and a 2MW system converter. For this case the cost of energy is calculated at \$0.261 and the renewable fraction is 48%. With the input parameters HOMER was given the several other cases were found feasible. See each cases pdf's for further details on each simulation.

## Appendix A – San Nicholas Scenarios

11/19/2016      [Detail](#)

### System Report

#### System architecture

PV	Generic flat plate PV	750	kW
Wind Turbine	Northern Power NPS100C-21	7	
Generator	Generic 1150kW Prime Power	1,150	kW
Battery	GS200 flow	8	strings
Converter	System Converter	1,000	kW
Dispatch Strategy	Cycle Charging		

#### Cost summary

Fuel Category	Component	Net Present Cost (\$)
Capital	Northern Power NPS100C-21	~5.5m
Capital	Generic 1150kW Prime Power	~11.5m
Capital	Generic flat plate PV	~2.5m
Fuel	Northern Power NPS100C-21	~0.5m
Fuel	Generic 1150kW Prime Power	~0.5m
Fuel	Generic flat plate PV	~0.5m
Operating	Northern Power NPS100C-21	~1.5m
Operating	Generic 1150kW Prime Power	~0.5m
Operating	Generic flat plate PV	~0.5m
Replacement	Northern Power NPS100C-21	~1.5m
Replacement	Generic 1150kW Prime Power	~2.5m
Replacement	Generic flat plate PV	~0.5m
Retire	Northern Power NPS100C-21	~0.5m
Retire	Generic 1150kW Prime Power	~0.5m
Retire	Generic flat plate PV	~0.5m

Total net present cost      27320988 \$


D:\CA\www\public\appData\local\Temp\temp252d133\Detail.htm      10

# System Report

## System architecture

PV	Generic flat plate PV	750	kW
Wind Turbine	Northern Power NPS100C-21	7	
Generator	Generic1150kW Prime Power	1,150	kW
Battery	GS200 flow	6	strings
Converter	System Converter	1,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	27320988	\$

Leveled cost of energy


0.406 \$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Generic flat plate PV	2,250,000	0	193,913	0	0	2,443,913
Northern Power NPS100C-21	5,530,000	1,763,003	1,551,301	0	-993,565	7,850,739
Generic1150kW Prime Power	741,936	2,211,004	336,744	11,251,017	-88,572	14,452,129
GS200 flow	1,947,535	43,013	186,156	0	-5,832	2,170,872
Converter	300,000	127,282	0	0	-23,956	403,326
System	10,769,471	4,144,301	2,268,114	11,251,017	-1,111,924	27,320,979

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Generic flat plate PV	174,047	0	15,000	0	0	189,047
Northern Power NPS100C-21	427,770	136,376	120,000	0	-76,857	607,289
Generic1150kW Prime Power	57,392	171,031	26,049	870,315	-6,851	1,117,936
GS200 flow	150,650	3,327	14,400	0	-451	167,926
Converter	23,206	9,846	0	0	-1,853	31,199
System	833,066	320,580	175,449	870,315	-86,012	2,113,398




## Electrical

Quantity	Value	Units
Excess electricity	132565	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	1,125,156	19
Generator	3,347,365	55
Wind Turbine	1,601,808	26
Total	6,074,329	100

Load	Consumption(kWh/yr)	Fraction (%)


AC primary load	5,205,935	100
DC primary load	0	0
Total	5,205,935	100



## PV:Generic flat plate PV


Quantity	Value	Units
Rated capacity	750	kW
Mean output	128	kW
Mean output	3082.60	kWh/d
Capacity factor	17.13	%
Total production	1125156	kWh/yr
Minimum output	0.00	kW
Maximum output	758.97	kW

	Detail	
PV penetration	21.61	%
Hours of operation	4386	hrs/yr
Levelized cost	0.168	\$/kWh




## Wind Turbine:Northern Power NPS100C-21

Quantity	Value	Units
Total rated capacity	700	kW
Mean output	183	kW
Capacity factor	26.12	%
Total production	1601808	kWh/yr
Minimum output	0.00	kW
Maximum output	686.75	kW
Wind penetration	30.77	%
Hours of operation	8108	hrs/yr
Levelized cost	0.379	\$/kWh



## Generator:Generic1150kW Prime Power

Quantity	Value	Units
Hours of operation	3901	hrs/yr
Number of starts	950	starts/yr
Operational life	4	yr
Fixed generation cost	56.14	\$/hr
Marginal generation cost	0.26	\$/kWh
Electrical production	3347365	kWh/yr
Mean electrical output	858	kW
Min. electrical output	345	kW
Max. electrical output	1150	kW
Fuel consumption	870316	L/yr
Specific fuel consumption	0.26	L/kWh
Fuel energy input	8563909	kWh/yr
Mean electrical efficiency	39	%




## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	6
Batteries	6
Bus voltage	100



Quantity	Value	Units
Nominal capacity	3600	kWh
Usable nominal capacity	3600	kWh
Autonomy	6	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.356	\$/kWh
Energy in	1282096	kWh/yr
Energy out	897551	kWh/yr
Storage depletion	101	kWh/yr

Losses	384444	kWh/yr
Annual throughput	1072780	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	1,000	900	kW
Mean output	172	119	kW
Minimum output	0	0	kW
Maximum output	860	1,000	kW
Capacity factor	17	12	%
Hours of operation	4,730	2,572	hrs/yr
Energy in	1,673,117	1,226,471	kWh/yr
Energy out	1,505,805	1,042,500	kWh/yr
Losses	167,312	183,971	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	2284157	kg/yr
Carbon monoxide	9574	kg/yr
Unburned hydrocarbons	1097	kg/yr
Particulate matter	274	kg/yr
Sulfur dioxide	4703	kg/yr
Nitrogen oxides	9574	kg/yr

# System Report

## System architecture

Wind Turbine	Northern Power NPS100C-21	7	
Generator	Generic1150kW Prime Power	1,150	kW
Battery	GS200 flow	6	strings
Converter	System Converter	750	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	28522898	\$
Levelized cost of energy	0.424	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Northern Power NPS100C-21	5,530,000	1,763,003	1,551,301	0	-993,565	7,850,739
Generic1150kW Prime Power	741,936	3,744,850	534,508	13,298,348	-120,861	18,198,781
GS200 flow	1,947,535	43,013	186,156	0	-5,832	2,170,872
Converter	225,000	95,462	0	0	-17,967	302,495
System	8,444,470	5,646,327	2,271,966	13,298,348	-1,138,224	28,522,887

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Northern Power NPS100C-21	427,770	136,376	120,000	0	-76,857	607,289
Generic1150kW Prime Power	57,392	289,681	41,347	1,028,685	-9,349	1,407,756
GS200 flow	150,650	3,327	14,400	0	-451	167,926
Converter	17,405	7,384	0	0	-1,390	23,400
System	653,217	436,768	175,746	1,028,685	-88,047	2,206,369



## Electrical

Quantity	Value	Units
Excess electricity	12119	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	3,956,489	71
Wind Turbine	1,601,808	29
Total	5,558,297	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	5,205,935	100

DC primary load

Total

5,205,935

100




## Wind Turbine:Northern Power NPS100C-21

Quantity	Value	Units
Total rated capacity	700	kW
Mean output	183	kW
Capacity factor	26.12	%
Total production	1601808	kWh/yr
Minimum output	0.00	kW
Maximum output	686.75	kW
Wind penetration	30.77	%
Hours of operation	8108	hrs/yr


0.379 \$/kWh

Leveled cost



## Generator: Generic 1150kW Prime Power

Quantity	Value	Units
Hours of operation	6192	hrs/yr
Number of starts	883	starts/yr
Operational life	2	yr
Fixed generation cost	56.14	\$/hr
Marginal generation cost	0.26	\$/kWh
Electrical production	3956489	kWh/yr
Mean electrical output	639	kW
Min. electrical output	345	kW
Max. electrical output	1150	kW
Fuel consumption	1028686	L/yr
Specific fuel consumption	0.26	L/kWh
Fuel energy input	10122272	kWh/yr
Mean electrical efficiency	39	%




## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	6
Batteries	6
Bus voltage	100



Quantity	Value	Units
Nominal capacity	3600	kWh
Usable nominal capacity	3600	kWh
Autonomy	6	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.410	\$/kWh
Energy in	622609	kWh/yr
Energy out	435826	kWh/yr
Storage depletion	0	kWh/yr

Losses	186782	kWh/yr
Annual throughput	520912	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	45	71	kW
Minimum output	0	0	kW
Maximum output	558	750	kW
Capacity factor	6	9	%
Hours of operation	2,074	1,771	hrs/yr
Energy in	435,826	732,481	kWh/yr
Energy out	392,244	622,609	kWh/yr
Losses	43,583	109,872	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	2699802	kg/yr
Carbon monoxide	11316	kg/yr
Unburned hydrocarbons	1296	kg/yr
Particulate matter	324	kg/yr
Sulfur dioxide	5559	kg/yr
Nitrogen oxides	11316	kg/yr

# System Report

## System architecture

Wind Turbine	Northern Power NPS100C-21	7	
Generator	Generic1150kW Prime Power	1,150	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	28628548	\$
Levelized cost of energy	0.425	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Northern Power	\$ 530,000	1,763,000	1,551,304	0	\$ 2,525	\$ 7,850,700

Detail							
Northern Power NPS100C-21	5,250,000	1,700,000	1,100,000	0	-993,000	20,800,759	
Generic1150kW Prime Power	741,936	5,381,779	756,012	13,969,756	-71,687	20,777,796	
System	6,271,936	7,144,782	2,307,313	13,969,756	-1,065,251	28,628,536	

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Northern Power NPS100C-21	427,770	136,376	120,000	0	-76,857	607,289
Generic1150kW Prime Power	57,392	416,304	58,481	1,080,622	-5,545	1,607,254
System	485,162	552,680	178,481	1,080,622	-82,402	2,214,543




## Electrical

Quantity	Value	Units

Excess electricity		552204	kWh/yr
Unmet load		0	kWh/yr
Capacity shortage		0	kWh/yr
Renewable fraction		0	


Component	Production(kWh/yr)	Fraction (%)
Generator	4,156,337	72
Wind Turbine	1,601,808	28
Total	5,758,145	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	5,205,935	100
DC primary load	0	0
Total	5,205,935	100




## Wind Turbine:Northern Power NPS100C-21

Quantity	Value	Units
Total rated capacity	700	kW
Mean output	183	kW
Capacity factor	26.12	%
Total production	1601808	kWh/yr
Minimum output	0.00	kW
Maximum output	686.75	kW
Wind penetration	30.77	%
Hours of operation	8108	hrs/yr
Levelized cost	0.379	\$/kWh



## Generator:Generic1150kW Prime Power

Quantity	Value	Units
Hours of operation	8758	hrs/yr
Number of starts	3	starts/yr
Operational life	2	yr
Fixed generation cost	56.14	\$/hr
Marginal generation cost	0.26	\$/kWh
Electrical production	4156337	kWh/yr
Mean electrical output	475	kW
Min. electrical output	345	kW
Max. electrical output	1018	kW
Fuel consumption	1080623	L/yr
Specific fuel consumption	0.26	L/kWh
Fuel energy input	10633327	kWh/yr
Mean electrical efficiency	39	%



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	2836110	kg/yr
Carbon monoxide	11887	kg/yr
Unburned hydrocarbons	1362	kg/yr
Particulate matter	340	kg/yr
Sulfur dioxide	5839	kg/yr
Nitrogen oxides	11887	kg/yr

# System Report

## System architecture

PV	Generic flat plate PV	250	kW
Wind Turbine	Northern Power NPS100C-21	7	
Generator	Generic1150kW Prime Power	1,150	kW
Converter	System Converter	500	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	29058882	\$
Levelized cost of energy	0.432	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Generic flat plate PV	750,000	0	64,638	0	0	814,638
Northern Power NPS100C-21	5,530,000	1,763,003	1,551,301	0	-993,565	7,850,739
Generic 1150kW Prime Power	741,936	5,379,269	755,407	13,388,983	-73,761	20,191,834
Converter	150,000	63,641	0	0	-11,978	201,663
System	7,171,936	7,205,913	2,371,346	13,388,983	-1,079,304	29,058,874

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Generic flat plate PV	58,016	0	5,000	0	0	63,016
Northern Power NPS100C-21	427,770	136,376	120,000	0	-76,857	607,289
Generic 1150kW Prime Power	57,392	416,110	58,434	1,035,696	-5,706	1,561,926
Converter	11,603	4,923	0	0	-927	15,599
System	554,781	557,409	183,434	1,035,696	-83,489	2,247,831




## Electrical

Quantity	Value	Units
Excess electricity	735566	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	375,052	6
Generator	3,983,576	67
Wind Turbine	1,601,808	27
Total	5,960,437	100

Load	Consumption(kWh/yr)	Fraction (%)


AC primary load	5,205,935	100
DC primary load	0	0
Total	5,205,935	100



## PV:Generic flat plate PV


Quantity	Value	Units
Rated capacity	250	kW
Mean output	43	kW
Mean output	1027.50	kWh/d
Capacity factor	17.13	%
Total production	375052	kWh/yr
Minimum output	0.00	kW
Maximum output	252.99	kW

PV penetration	7.20	%
Hours of operation	4386	hrs/yr
Levelized cost	0.168	\$/kWh




## Wind Turbine:Northern Power NPS100C-21

Quantity	Value	Units
Total rated capacity	700	kW
Mean output	183	kW
Capacity factor	26.12	%
Total production	1601808	kWh/yr
Minimum output	0.00	kW
Maximum output	686.75	kW
Wind penetration	30.77	%
Hours of operation	8108	hrs/yr
Levelized cost	0.379	\$/kWh





## Generator:Generic1150kW Prime Power

Quantity	Value	Units
Hours of operation	8751	hrs/yr
Number of starts	10	starts/yr
Operational life	2	yr
Fixed generation cost	56.14	\$/hr
Marginal generation cost	0.26	\$/kWh
Electrical production	3983576	kWh/yr
Mean electrical output	455	kW
Min. electrical output	345	kW
Max. electrical output	979	kW
Fuel consumption	1035697	L/yr
Specific fuel consumption	0.26	L/kWh
Fuel energy input	10191258	kWh/yr
Mean electrical efficiency	39	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	500	450	kW
Mean output	19	0	kW
Minimum output	0	0	kW
Maximum output	217	0	kW
Capacity factor	4	0	%
Hours of operation	2,661	0	hrs/yr
Energy in	189,274	0	kWh/yr
Energy out	170,347	0	kWh/yr
Losses	18,927	0	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	2718202	kg/yr
Carbon monoxide	11393	kg/yr
Unburned hydrocarbons	1305	kg/yr
Particulate matter	326	kg/yr
Sulfur dioxide	5597	kg/yr
Nitrogen oxides	11393	kg/yr


## Appendix B – China Lake Scenarios

### System Report

#### System architecture

PV	SunPower PV	13,780 kW
PV #2	Remaining Generic flat plate PV	1,547 kW
Converter	System Converter	10,000 kW
Grid	Grid	27,200 kW
Dispatch Strategy	Cycle Charging	

#### Cost summary



#### Cost Summary

Total net present cost	207103792	\$
Levelized cost of energy	0.169	\$/kWh

#### Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Grid	0	0	155,698,736	0	0	155,698,736
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	48,036,792	1,272,821	157,694,624	0	-239,558	206,764,679

#### Annualized Costs


Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Grid	0	0	12,043,979	0	0	12,043,979

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	207103792	\$
Levelized cost of energy	0.169	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Grid	0	0	155,698,736	0	0	155,698,736
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	48,036,792	1,272,821	157,694,624	0	-239,558	206,764,679

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Grid	0	0	12,043,979	0	0	12,043,979

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
System	3,715,856	98,458	12,198,370	0	-18,531	15,994,153




## Electrical

Quantity	Value	Units
Excess electricity	1613916	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Grid Purchases	71,835,160	72
Total	99,246,256	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%


Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,650	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	27	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	25,797,274	0	kWh/yr
Energy out	23,217,452	0	kWh/yr
Losses	2,579,822	0	kWh/yr





## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	20,019	0	320,305
July	0	0	0	24,169	0	386,703
August	0	0	0	22,951	0	367,211
September	0	0	0	18,833	0	301,321
October	0	0	0	16,050	0	256,794
November	0	0	0	15,751	0	252,018
December	0	0	0	17,148	0	274,366
Annual	0	0	0	24,169	0	3,423,765

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,808,431	0	5,808,431	0	697,012	0
February	4,748,350	0	4,748,350	0	569,802	0
March	5,124,164	0	5,124,164	0	614,900	0
April	4,760,968	0	4,760,968	0	571,316	0
May	4,811,302	0	4,811,302	0	577,356	0
June	6,639,290	0	6,639,290	0	796,715	0
July	8,073,620	0	8,073,620	0	968,834	0
August	8,188,394	0	8,188,394	0	982,607	0

September	6,819,598 Purchased (kWh)	0 Energy Sold (kWh)	6,819,598 Purchases (kWh)	0 Peak Demand (kW)	0 Energy Charge (\$)	818,352 675,816	Demand Charge (\$)
October	5,631,799	0	5,631,799	0	0	638,177	0
November	5,318,139	0	5,318,139	0	0	638,177	0
December	5,911,110	0	5,911,110	0	0	709,333	0
Annual	71,835,160	0	71,835,160	0	0	8,620,220	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	45399820	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	196828	kg/yr
Nitrogen oxides	96259	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	207291696	\$
Levelized cost of energy	0.169	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Grid	0	0	155,524,832	0	0	155,524,832
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	48,361,380	1,279,996	157,551,744	0	-240,530	206,952,590

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061

Component	Generic flat plate PV	Capital	361,899	Replacement	0	O&M	26,224	Fuel	0	Salvage	0	Total	388,123
Grid		0		0		12,030,527		0		0		12,030,527	
GS200 flow		25,108		555		2,400		0		-75		27,988	
Converter		232,063		98,458		0		0		-18,531		311,990	
System		3,740,965		99,013		12,187,317		0		-18,606		16,008,689	




## Electrical

Quantity	Value	Units
Excess electricity	1471749	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Grid Purchases	71,745,144	72
Total	99,156,240	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%


Quantity	Value	Units
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh



### Battery:GS200 flow



Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	142166	kWh/yr
Energy out	100019	kWh/yr
Storage depletion	600	kWh/yr
Losses	41547	kWh/yr
Annual throughput	119545	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity		10,000	kW
Mean output		2,661	kW
Minimum output		0	kW
Maximum output		10,000	kW
Capacity factor		27	%
Hours of operation		4,471	hrs/yr
Energy in		25,897,278	kWh/yr
Energy out		23,307,446	kWh/yr
Losses		2,589,832	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
March	0	0	0	17,075	0	273,199
April	Purchased	Sold	Purchases	Demand	Charge	Charge
Resources.ReportingService_GenerateInputsReport_Month	(kWh)	(kWh)	(kWh)	(kW)	(\$)	(\$)
May	0	0	0	14,850	0	237,602
June	0	0	0	20,019	0	320,305
July	0	0	0	24,169	0	386,703
August	0	0	0	22,785	0	364,561
September	0	0	0	18,833	0	301,321
October	0	0	0	16,050	0	256,794
November	0	0	0	15,751	0	252,018
December	0	0	0	17,148	0	274,366
Annual	0	0	0	24,169	0	3,421,115

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,801,195	0	5,801,195	0	696,143	0
February	4,740,909	0	4,740,909	0	568,909	0
March	5,114,871	0	5,114,871	0	613,785	0
April	4,751,667	0	4,751,667	0	570,200	0
May	4,801,942	0	4,801,942	0	576,233	0
June	6,632,296	0	6,632,296	0	795,875	0
July	8,068,444	0	8,068,444	0	968,213	0
August	8,182,007	0	8,182,007	0	981,841	0
September	6,811,501	0	6,811,501	0	817,380	0
October	5,624,914	0	5,624,914	0	674,990	0
November	5,310,932	0	5,310,932	0	637,312	0
December	5,904,472	0	5,904,472	0	708,537	0
Annual	71,745,144	0	71,745,144	0	8,609,417	0



Emissions

**Emissions**

Pollutant	Emissions	Units
Carbon dioxide	45342932	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	196582	kg/yr
Nitrogen oxides	96138	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Generator	Kohler 3250 Prime Power	2,800	kW
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	207309664	\$
Levelized cost of energy	0.169	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Kohler 3250 Prime Power	2,350,000	0	41,055	181,737	-488,837	2,083,955
Grid	0	0	153,820,640	0	0	153,820,640
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	50,386,792	1,272,821	155,857,632	181,737	-728,395	206,970,587

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061

Component	Generic flat plate PV	Capital	261,899	Replacement	0	O&M	26,224	Fuel	0	Salvage	0	Total	388,123
Kohler 3250 Prime Power		181,783		0		3,176		14,058		-37,814		161,203	
Grid		0		0		11,898,700		0		0		11,898,700	
Converter		232,063		98,458		0		0		-18,531		311,990	
System		3,897,639		98,458		12,056,270		14,058		-56,345		16,010,080	




## Electrical

Quantity	Value	Units
Excess electricity	1613916	kWh/yr
Unmet load	2763	kWh/yr
Capacity shortage	35688	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Generator	71,939	0
Grid Purchases	71,760,464	72
Total	99,243,496	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,049,688	100
DC primary load	0	0
Total	95,049,688	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh




### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	79	hrs/yr
Number of starts	71	starts/yr
Operational life	190	yr
Fixed generation cost	207.82	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	71939	kWh/yr
Mean electrical output	911	kW
Min. electrical output	700	kW
Max. electrical output	2800	kW
Fuel consumption	17795	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	175104	kWh/yr
Mean electrical efficiency	41	%



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,650	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	27	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	25,797,274	0	kWh/yr
Energy out	23,217,452	0	kWh/yr
Losses	2,579,822	0	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	19,319	0	309,105
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000

	<b>Energy Purchased (kWh)</b>	<b>Energy Sold (kWh)</b>	<b>Net Purchases (kWh)</b>	<b>Peak Demand (kW)</b>	<b>Energy Charge (\$)</b>	<b>Demand Charge (\$)</b>
September	0	0	0	18,133	0	200,121
October	0	0	0	16,058	0	1794
<b>Resources.ReportingService_GenerateInputsReport_Month</b>						
November	0	0	0	15,751	0	252,018
December	0	0	0	17,148	0	274,366
Annual	0	0	0	20,000	0	3,287,451

Rate: Rate 1

<b>Resources.ReportingService_GenerateInputsReport_Month</b>	<b>Energy Purchased (kWh)</b>	<b>Energy Sold (kWh)</b>	<b>Net Purchases (kWh)</b>	<b>Peak Demand (kW)</b>	<b>Energy Charge (\$)</b>	<b>Demand Charge (\$)</b>
January	5,808,431	0	5,808,431	0	697,012	0
February	4,748,350	0	4,748,350	0	569,802	0
March	5,124,164	0	5,124,164	0	614,900	0
April	4,760,968	0	4,760,968	0	571,316	0
May	4,811,302	0	4,811,302	0	577,356	0
June	6,634,390	0	6,634,390	0	796,127	0
July	8,039,810	0	8,039,810	0	964,777	0
August	8,156,603	0	8,156,603	0	978,792	0
September	6,815,398	0	6,815,398	0	817,848	0
October	5,631,799	0	5,631,799	0	675,816	0
November	5,318,139	0	5,318,139	0	638,177	0
December	5,911,110	0	5,911,110	0	709,333	0
Annual	71,760,464	0	71,760,464	0	8,611,256	0



## Emissions

<b>Pollutant</b>	<b>Emissions</b>	<b>Units</b>
Carbon dioxide	45399316	kg/yr
Carbon monoxide	196	kg/yr
Unburned hydrocarbons	22	kg/yr
Particulate matter	6	kg/yr
Sulfur dioxide	196720	kg/yr

Pollutant	Emissions	Units
NOx	9635	kg/y


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	207496480	\$
Levelized cost of energy	0.169	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Grid	0	0	148,287,040	0	0	148,287,040
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	54,036,792	3,185,663	151,252,480	0	-1,317,567	207,157,368

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061

Component	Generic flat plate PV	Capital	261,899	Replacement	0	O&M	26,224	Fuel	0	Salvage	0	Total	388,123
Siemens 2.3 MW - 108		464,126		147,967		75,000		0	-83,389			603,704	
Grid		0		0		11,470,652		0	0			11,470,652	
Converter		232,063		98,458		0		0	-18,531			311,990	
System		4,179,983		246,425		11,700,042		0	-101,920			16,024,530	




## Electrical

Quantity	Value	Units
Excess electricity	2091590	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Wind Turbine	4,674,352	5
Grid Purchases	67,590,728	68
Total	99,676,176	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh




## Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh

## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,601	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	26	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	25,319,570	0	kWh/yr
Energy out	22,787,530	0	kWh/yr

Losses	Quantity	Inverter	2,532,040	Rectifier	0	KWh / yr
--------	----------	----------	-----------	-----------	---	----------



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	16,288	0	260,605
February	0	0	0	15,654	0	250,459
March	0	0	0	17,043	0	272,688
April	0	0	0	14,366	0	229,856
May	0	0	0	13,700	0	219,202
June	0	0	0	20,004	0	320,060
July	0	0	0	23,789	0	380,622
August	0	0	0	22,424	0	358,782
September	0	0	0	18,548	0	296,765
October	0	0	0	16,023	0	256,374
November	0	0	0	15,278	0	244,445
December	0	0	0	16,870	0	269,913
Annual	0	0	0	23,789	0	3,359,769

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,427,674	0	5,427,674	0	651,321	0
February	4,390,087	0	4,390,087	0	526,810	0

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
Resources.ReportingService_GenerateInputsReport_Month April	4,752,956 4,446,749	0	4,752,956 4,446,749	0	570,355 533,610	0
May	4,404,201	0	4,404,201	0	528,504	0
June	6,220,404	0	6,220,404	0	746,448	0
July	7,713,463	0	7,713,463	0	925,616	0
August	7,915,288	0	7,915,288	0	949,835	0
September	6,504,741	0	6,504,741	0	780,569	0
October	5,341,487	0	5,341,487	0	640,978	0
November	4,942,436	0	4,942,436	0	593,092	0
December	5,531,241	0	5,531,241	0	663,749	0
Annual	67,590,728	0	67,590,728	0	8,110,888	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42717340	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	185199	kg/yr
Nitrogen oxides	90572	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Generator	Kohler 3250 Prime Power	2,800	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	207545360	\$
Levelized cost of energy	0.169	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Kohler 3250 Prime Power	2,350,000	0	40,535	205,792	-489,775	2,106,552
Grid	0	0	153,671,936	0	0	153,671,936
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	50,711,380	1,279,996	155,739,392	205,792	-730,306	207,206,254

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Kohler 3250 Prime Power	181,783	0	3,136	15,919	-37,886	162,952
Grid	0	0	11,887,197	0	0	11,887,197
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	3,922,747	99,013	12,047,124	15,919	-56,492	16,028,311




## Electrical

Quantity	Value	Units
Excess electricity	1471749	kWh/yr
Unmet load	2499	kWh/yr
Capacity shortage	35008	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Generator	82,145	0
Grid Purchases	71,664,592	72
Total	99,157,832	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,049,952	100
DC primary load	0	0

Total	Consumption(kWh/yr)	95,049,952	Fraction (%)	100
-------	---------------------	------------	--------------	-----



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh



### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	78	hrs/yr
Number of starts	70	starts/yr
Operational life	192	yr
Fixed generation cost	207.82	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	82145	kWh/yr
Mean electrical output	1053	kW
Min. electrical output	700	kW
Max. electrical output	2800	kW
Fuel consumption	20151	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	198282	kWh/yr
Mean electrical efficiency	41	%



### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100



Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.010	\$/kWh
Energy in	153371	kWh/yr
Energy out	107862	kWh/yr
Storage depletion	600	kWh/yr
Losses	44909	kWh/yr
Annual throughput	128920	kWh/yr
Expected life	25	yr



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW

Quantity	Inverter	2,661	Rectifier	0	kW Units
Minimum output		0		0	kW
Maximum output		10,000		179	kW
Capacity factor		27		0	%
Hours of operation		4,491		23	hrs/yr
Energy in		25,897,782		4,561	kWh/yr
Energy out		23,307,908		3,877	kWh/yr
Losses		2,589,874		684	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	19,319	0	309,105
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	18,133	0	290,121
October	0	0	0	16,050	0	256,794

November	Energy Purchased (kWh)	0	Energy Sold (kWh)	0	Net Purchases (kWh)	0	Peak Demand (kW)	15,751	Energy Charge (\$)	0	Demand Charge (\$)	252,018
December	Purchased	0	Sold	0	Purchases	0	Demand	0	Charge	0	Charge	366
<b>Resources.ReportingService_GenerateInputsReport_Month</b>												
Annual		0		0		0		20,000		0		3,287,451

Rate: Rate 1

<b>Resources.ReportingService_GenerateInputsReport_Month</b>	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,801,195	0	5,801,195	0	696,143	0
February	4,740,909	0	4,740,909	0	568,909	0
March	5,114,871	0	5,114,871	0	613,785	0
April	4,751,667	0	4,751,667	0	570,200	0
May	4,801,942	0	4,801,942	0	576,233	0
June	6,626,605	0	6,626,605	0	795,193	0
July	8,031,922	0	8,031,922	0	963,831	0
August	8,147,624	0	8,147,624	0	977,715	0
September	6,807,550	0	6,807,550	0	816,906	0
October	5,624,914	0	5,624,914	0	674,990	0
November	5,310,932	0	5,310,932	0	637,312	0
December	5,904,472	0	5,904,472	0	708,537	0
Annual	71,664,592	0	71,664,592	0	8,599,752	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	45344908	kg/yr
Carbon monoxide	222	kg/yr
Unburned hydrocarbons	25	kg/yr
Particulate matter	6	kg/yr
Sulfur dioxide	196470	kg/yr
Nitrogen oxides	96252	kg/yr




# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	207672672	\$
Levelized cost of energy	0.169	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Grid	0	0	148,101,408	0	0	148,101,408
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	54,361,380	3,192,838	151,097,872	0	-1,318,539	207,333,551

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Grid	0	0	11,456,292	0	0	11,456,292
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,205,091	246,980	11,688,082	0	-101,995	16,038,158




## Electrical

Quantity	Value	Units
Excess electricity	1937470	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Wind Turbine	4,674,352	5
Grid Purchases	67,493,176	68
Total	99,578,624	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0

Total	Consumption(kWh/yr)	95,052,456	Fraction (%)	100
-------	---------------------	------------	--------------	-----



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh



### Wind Turbine:Siemens 2.3 MW - 108


Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh

### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh


Quantity	Value	0	Units
Lifetime throughput	0		
Battery wear cost	0.000	\$/kWh	
Average energy cost	0.000	\$/kWh	
Energy in	154117	kWh/yr	
Energy out	108384	kWh/yr	
Storage depletion	600	kWh/yr	
Losses	45132	kWh/yr	
Annual throughput	129544	kWh/yr	
Expected life	25	yr	



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,612	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	26	0	%
Hours of operation	4,575	48	hrs/yr
Energy in	25,427,954	0	kWh/yr
Energy out	22,885,056	0	kWh/yr
Losses	2,542,898	0	kWh/yr





## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	16,288	0	260,605
February	0	0	0	15,654	0	250,459
March	0	0	0	17,043	0	272,688
April	0	0	0	14,366	0	229,856
May	0	0	0	13,700	0	219,202
June	0	0	0	20,004	0	320,060
July	0	0	0	23,789	0	380,622
August	0	0	0	22,258	0	356,132
September	0	0	0	18,548	0	296,765
October	0	0	0	16,023	0	256,374
November	0	0	0	15,278	0	244,445
December	0	0	0	16,870	0	269,913
Annual	0	0	0	23,789	0	3,357,119

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,419,880	0	5,419,880	0	650,386	0
February	4,381,999	0	4,381,999	0	525,840	0
March	4,743,226	0	4,743,226	0	569,187	0
April	4,435,979	0	4,435,979	0	532,317	0
May	4,393,103	0	4,393,103	0	527,172	0
June	6,213,113	0	6,213,113	0	745,574	0
July	7,708,083	0	7,708,083	0	924,970	0
August	7,908,765	0	7,908,765	0	949,052	0

September	6,496,302	Energy Purchased (kWh)	0	Net Purchases (kWh)	6,496,302	Peak Demand (kW)	0	Energy Charge (\$)	779,556	Demand Charge (\$)	0
October	5,333,870		0	5,333,870	0	0	0	640,064			0
November	4,934,859		0	4,934,859		0	592,183			0	
December	5,523,998		0	5,523,998		0	662,880			0	
Annual	67,493,176		0	67,493,176		0	8,099,180			0	



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42655688	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	184931	kg/yr
Nitrogen oxides	90441	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Generator	Kohler 3250 Prime Power	2,800	kW
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	207858560	\$
Levelized cost of energy	0.169	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Kohler 3250 Prime Power	2,350,000	0	34,819	136,867	-500,096	2,021,590
Grid	0	0	146,627,520	0	0	146,627,520
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	56,386,792	3,185,663	149,627,760	136,867	-1,817,663	207,519,419

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Kohler 3250 Prime Power	181,783	0	2,693	10,587	-38,685	156,378
Grid	0	0	11,342,281	0	0	11,342,281
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,361,766	246,425	11,574,362	10,587	-140,604	16,052,536




## Electrical

Quantity	Value	Units
Excess electricity	2091590	kWh/yr
Unmet load	989	kWh/yr
Capacity shortage	26452	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Generator	53,730	0
Wind Turbine	4,674,352	5
Grid Purchases	67,536,008	68
Total	99,675,184	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,051,464	100

Category	Consumption(kWh/yr)	0	Fraction (%)	0
Total	95,051,464		100	



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW

Quantity	Value	Units
Mean output	7579.50	kWh/yr
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh

### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	67	hrs/yr
Number of starts	61	starts/yr
Operational life	224	yr
Fixed generation cost	207.82	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	53730	kWh/yr


Quantity	Value	Units
Min. electrical output	700	kW
Max. electrical output	2800	kW
Fuel consumption	13402	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	131872	kWh/yr
Mean electrical efficiency	41	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,601	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	26	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	25,319,570	0	kWh/yr
Energy out	22,787,530	0	kWh/yr
Losses	2,532,040	0	kWh/yr





## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	16,288	0	260,605
February	0	0	0	15,654	0	250,459
March	0	0	0	17,043	0	272,688
April	0	0	0	14,366	0	229,856
May	0	0	0	13,700	0	219,202
June	0	0	0	19,304	0	308,860
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	17,848	0	285,565
October	0	0	0	16,023	0	256,374
November	0	0	0	15,278	0	244,445
December	0	0	0	16,870	0	269,913
Annual	0	0	0	20,000	0	3,237,966

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,427,674	0	5,427,674	0	651,321	0
February	4,390,087	0	4,390,087	0	526,810	0
March	4,752,956	0	4,752,956	0	570,355	0
April	4,446,749	0	4,446,749	0	533,610	0
May	4,404,201	0	4,404,201	0	528,504	0
June	6,215,504	0	6,215,504	0	745,860	0
July	7,689,997	0	7,689,997	0	922,800	0
August	7,892,434	0	7,892,434	0	947,092	0

September	6,501,241 Purchased (kWh)	0 Energy Sold (kWh)	6,501,241 Purchases (kWh)	0 Peak Demand (kW)	780,149 Charge (\$)	Demand Charge (\$)
October	5,341,487	0	5,341,487	0	640,978	0
November	4,942,436	0	4,942,436	0	593,092	0
December	5,531,241	0	5,531,241	0	663,749	0
Annual	67,536,008	0	67,536,008	0	8,104,321	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42717928	kg/yr
Carbon monoxide	147	kg/yr
Unburned hydrocarbons	17	kg/yr
Particulate matter	4	kg/yr
Sulfur dioxide	185121	kg/yr
Nitrogen oxides	90646	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Generator	Kohler 3250 Prime Power	2,800	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	208078544	\$
Levelized cost of energy	0.169	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Kohler 3250 Prime Power	2,350,000	0	34,299	154,657	-501,035	2,037,921
Grid	0	0	146,469,344	0	0	146,469,344
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263

System Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	56,711,380	3,192,838	19,500,144	154,657	1,819,574	207,739,445

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Kohler 3250 Prime Power	181,783	0	2,653	11,963	-38,757	157,642
Grid	0	0	11,330,045	0	0	11,330,045
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,386,874	246,980	11,564,491	11,963	-140,752	16,069,556




## Electrical

Quantity	Value	Units
Excess electricity	1937470	kWh/yr
Unmet load	989	kWh/yr
Capacity shortage	25705	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
Generator	61,293	0
Wind Turbine	4,674,352	5
Grid Purchases	67,434,064	68

Total Component	Production(kWh/yr)	99,580,808	Fraction (%)	100
Load	Consumption(kWh/yr)		Fraction (%)	
AC primary load		95,051,464		100
DC primary load		0		0
Total		95,051,464		100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.119	\$/kWh



### PV:Remaining Generic flat plate PV

## Performance Metrics for Solar PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.014	\$/kWh




## Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh

## Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	66	hrs/yr
Number of starts	60	starts/yr
Operational life	227	yr

Quantity	Value	Units
Fixed generation cost	207.82	\$/kWh
Marginal generation cost	0.18	\$/kWh
Electrical production	61293	kWh/yr
Mean electrical output	929	kW
Min. electrical output	700	kW
Max. electrical output	2800	kW
Fuel consumption	15144	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	149013	kWh/yr
Mean electrical efficiency	41	%




## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100



Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.008	\$/kWh
Energy in	162812	kWh/yr
Energy out	114471	kWh/yr
Storage depletion	600	kWh/yr
Losses	47741	kWh/yr

Quantity	Value	136820	Units
Expected life		25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,613	0	kW
Minimum output	0	0	kW
Maximum output	10,000	179	kW
Capacity factor	26	0	%
Hours of operation	4,588	66	hrs/yr
Energy in	25,428,318	3,506	kWh/yr
Energy out	22,885,384	2,980	kWh/yr
Losses	2,542,934	526	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	10,288	0	260,605
February	0	0	0	15,654	0	250,459
March	0	0	0	17,043	0	272,688
April	0	0	0	14,366	0	229,856
May	0	0	0	13,700	0	219,202
June	0	0	0	19,304	0	308,860
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	17,848	0	285,565
October	0	0	0	16,023	0	256,374
November	0	0	0	15,278	0	244,445
December	0	0	0	16,870	0	269,913
Annual	0	0	0	20,000	0	3,237,966

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,419,880	0	5,419,880	0	650,386	0
February	4,381,999	0	4,381,999	0	525,840	0
March	4,743,226	0	4,743,226	0	569,187	0
April	4,435,979	0	4,435,979	0	532,317	0
May	4,393,103	0	4,393,103	0	527,172	0
June	6,207,422	0	6,207,422	0	744,891	0
July	7,682,359	0	7,682,359	0	921,883	0
August	7,884,209	0	7,884,209	0	946,105	0
September	6,493,163	0	6,493,163	0	779,180	0
October	5,333,870	0	5,333,870	0	640,064	0
November	4,934,859	0	4,934,859	0	592,183	0
December	5,523,998	0	5,523,998	0	662,880	0
Annual	67,434,064	0	67,434,064	0	8,092,087	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42658072	kg/yr
Carbon monoxide	167	kg/yr
Unburned hydrocarbons	19	kg/yr
Particulate matter	5	kg/yr
Sulfur dioxide	184851	kg/yr
Nitrogen oxides	90528	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	208627504	\$
Levelized cost of energy	0.170	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Grid	0	0	154,198,048	0	0	154,198,048
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	51,120,124	1,272,821	156,474,048	0	-239,558	208,627,435

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061

Component	Generic flat plate PV	Capital	361,899	Replacement	0	O&M	26,224	Fuel	0	Salvage	0	Total	388,123
Solar World 320W flat plate PV Copy			238,509		0		21,667		0		0		260,176
Grid			0		0		11,927,894		0		0		11,927,894
Converter			232,063		98,458		0		0		-18,531		311,990
System			3,954,366		98,458		12,103,953		0		-18,531		16,138,246




## Electrical

Quantity	Value	Units
Excess electricity	2364865	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Grid Purchases	70,901,448	71
Total	100,100,976	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



### PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,757	0	kW

Quantity	Inverter	0	Rectifier	0	kW Units
Maximum output		10,000		0	kW
Capacity factor		28		0	%
Hours of operation		4,386		0	hrs/yr
Energy in		26,834,786		0	kWh/yr
Energy out		24,151,150		0	kWh/yr
Losses		2,683,636		0	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	20,019	0	320,305
July	0	0	0	24,158	0	386,525
August	0	0	0	22,709	0	363,351
September	0	0	0	18,833	0	301,321
October	0	0	0	16,050	0	256,794
November	0	0	0	15,751	0	252,018

December	Energy Purchased (kWh)	0	Energy Sold (kWh)	0	Net Purchases (kWh)	0	Peak Demand (kW)	17148	Energy Charge (\$)	0	Demand Charge (\$)	274,366
Annual Resources.ReportingService_GenerateInputsReport_Month												26

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,751,815	0	5,751,815	0	690,218	0
February	4,692,684	0	4,692,684	0	563,122	0
March	5,049,504	0	5,049,504	0	605,940	0
April	4,681,443	0	4,681,443	0	561,773	0
May	4,726,141	0	4,726,141	0	567,137	0
June	6,541,892	0	6,541,892	0	785,027	0
July	7,964,076	0	7,964,076	0	955,689	0
August	8,092,122	0	8,092,122	0	971,055	0
September	6,744,112	0	6,744,112	0	809,293	0
October	5,548,274	0	5,548,274	0	665,793	0
November	5,255,797	0	5,255,797	0	630,696	0
December	5,853,593	0	5,853,593	0	702,431	0
Annual	70,901,448	0	70,901,448	0	8,508,174	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	44809716	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	194270	kg/yr
Nitrogen oxides	95008	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	208789744	\$
Levelized cost of energy	0.170	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Grid	0	0	153,998,464	0	0	153,998,464
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	51,444,712	1,279,996	156,305,472	0	-240,530	208,789,650

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Grid	0	0	11,912,456	0	0	11,912,456
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	3,979,474	99,013	12,090,913	0	-18,606	16,150,794




## Electrical

Quantity	Value	Units
Excess electricity	2196428	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Grid Purchases	70,794,880	71
Total	99,994,408	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0

Total	Consumption(kWh/yr)	95,052,456	Fraction (%)	100
-------	---------------------	------------	--------------	-----



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d

Quantity	Value	Units
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh




Battery:GS200 flow

Quantity	Value
String size	1


String(s) in parallel	Value	1
Batteries		1
Bus voltage		100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	168438	kWh/yr
Energy out	118409	kWh/yr
Storage depletion	600	kWh/yr
Losses	49429	kWh/yr
Annual throughput	141526	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,769	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	28	0	%
Hours of operation	4,479	0	hrs/yr
Energy in	26,953,204	0	kWh/yr
Energy out	24,257,696	0	kWh/yr
Losses	2,695,508	0	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	20,019	0	320,305
July	0	0	0	24,158	0	386,525
August	0	0	0	22,544	0	360,700
September	0	0	0	18,833	0	301,321
October	0	0	0	16,050	0	256,794
November	0	0	0	15,751	0	252,018
December	0	0	0	17,148	0	274,366
Annual	0	0	0	24,158	0	3,417,076

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,743,823	0	5,743,823	0	689,259	0
February	4,684,560	0	4,684,560	0	562,147	0
March	5,039,282	0	5,039,282	0	604,714	0

	<b>Energy Purchased</b> <small>(kWh)</small>	<b>Energy Sold</b> <small>(kWh)</small>	<b>Net Purchases</b> <small>(kWh)</small>	<b>Peak Demand</b> <small>(kW)</small>	<b>Energy Charge</b> <small>(\$)</small>	<b>Demand Charge</b> <small>(\$)</small>
April	4,670,348 4,714,417	0	4,670,348 4,714,417	0	560,442 (\$65,730)	0
May						
June	6,532,493	0	6,532,493	0	783,899	0
July	7,956,805	0	7,956,805	0	954,817	0
August	8,083,955	0	8,083,955	0	970,075	0
September	6,734,741	0	6,734,741	0	808,169	0
October	5,540,203	0	5,540,203	0	664,824	0
November	5,248,187	0	5,248,187	0	629,782	0
December	5,846,067	0	5,846,067	0	701,528	0
Annual	70,794,880	0	70,794,880	0	8,495,386	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	44742364	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	193978	kg/yr
Nitrogen oxides	94865	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 3250 Prime Power	2,800	kW
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	208874000	\$
Levelized cost of energy	0.170	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Kohler 3250 Prime Power	2,350,000	0	38,457	168,760	-493,528	2,063,689
Grid	0	0	152,380,880	0	0	152,380,880
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	53,470,124	1,272,821	154,695,296	168,760	-733,086	208,873,915

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Kohler 3250 Prime Power	181,783	0	2,975	13,054	-38,177	159,635
Grid	0	0	11,787,328	0	0	11,787,328
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,136,148	98,458	11,966,359	13,054	-56,707	16,157,312




## Electrical

Quantity	Value	Units
Excess electricity	2364865	kWh/yr
Unmet load	2334	kWh/yr
Capacity shortage	33532	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Generator	66,764	0
Grid Purchases	70,832,352	71
Total	100,098,648	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,050,112	100

Load	Primary load	Consumption(kWh/yr)	0	Fraction (%)	0
Total		95,050,112			100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW

Quantity	Value	Units
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



### PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh



### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Mean output	7579.50	kWh/d

Quantity	Value	74	hrs/yr
Number of starts	66	starts/yr	
Operational life	203	yr	
Fixed generation cost	207.82	\$/hr	
Marginal generation cost	0.18	\$/kWh	
Electrical production	66764	kWh/yr	
Mean electrical output	902	kW	
Min. electrical output	700	kW	
Max. electrical output	2800	kW	
Fuel consumption	16524	L/yr	
Specific fuel consumption	0.25	L/kWh	
Fuel energy input	162601	kWh/yr	
Mean electrical efficiency	41	%	



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,757	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	28	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	26,834,786	0	kWh/yr
Energy out	24,151,150	0	kWh/yr
Losses	2,683,636	0	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	17,079	0	273,262
February	0	0	0	15,668	0	250,685
March	0	0	0	17,075	0	273,199
April	0	0	0	14,394	0	230,299
May	0	0	0	14,850	0	237,602
June	0	0	0	19,319	0	309,105
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	18,133	0	290,121
October	0	0	0	16,050	0	256,794
November	0	0	0	15,751	0	252,018
December	0	0	0	17,148	0	274,366
Annual	0	0	0	20,000	0	3,287,451

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,751,815	0	5,751,815	0	690,218	0
February	4,692,684	0	4,692,684	0	563,122	0
March	5,049,504	0	5,049,504	0	605,940	0

	<b>Energy Purchased</b> <small>(kWh)</small>	<b>Energy Sold</b> <small>(kWh)</small>	<b>Net Purchases</b> <small>(kWh)</small>	<b>Peak Demand</b> <small>(kW)</small>	<b>Energy Charge</b> <small>(\$)</small>	<b>Demand Charge</b> <small>(\$)</small>
April	4,681,443 4,726,141	0	4,681,443 4,726,141	0	561,773 (\$567,137)	0
May						
June	6,536,992	0	6,536,992	0	784,439	0
July	7,931,617	0	7,931,617	0	951,794	0
August	8,063,882	0	8,063,882	0	967,666	0
September	6,740,612	0	6,740,612	0	808,873	0
October	5,548,274	0	5,548,274	0	665,793	0
November	5,255,797	0	5,255,797	0	630,696	0
December	5,853,593	0	5,853,593	0	702,431	0
Annual	70,832,352	0	70,832,352	0	8,499,882	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	44809416	kg/yr
Carbon monoxide	182	kg/yr
Unburned hydrocarbons	21	kg/yr
Particulate matter	5	kg/yr
Sulfur dioxide	194170	kg/yr
Nitrogen oxides	95097	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	2	
Battery	GS200 flow	3	strings
Converter	System Converter	10,000	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	208878272	\$
Levelized cost of energy	0.170	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Siemens 2.3 MW - 108	11,925,000	3,801,774	1,034,201	0	-2,142,543	14,618,432
Grid	0	0	138,744,976	0	0	138,744,976
GS200 flow	973,767	21,510	93,078	0	-2,917	1,085,439
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263

System Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	64,018,892	5,096,105	112,148,240	0	2,285,017	208,878,220

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Siemens 2.3 MW - 108	922,451	294,084	80,000	0	-165,735	1,130,800
Grid	0	0	10,732,531	0	0	10,732,531
GS200 flow	75,325	1,664	7,200	0	-226	83,963
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,952,142	394,206	10,995,789	0	-184,491	16,157,646




## Electrical

Quantity	Value	Units
Excess electricity	3171029	kWh/yr
Unmet load	7341	kWh/yr
Capacity shortage	94840	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	24
PV	2,766,525	3
PV	1,788,429	2
Wind Turbine	9,348,703	9
Grid Purchases	62,415,532	62

Total Component	Production(kWh/yr)	100,963,760	Fraction (%)	100
Load	Consumption(kWh/yr)		Fraction (%)	
AC primary load		95,045,120		100
DC primary load		0		0
Total		95,045,120		100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


## Performance metrics for flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



## PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh



### Wind Turbine:Siemens 2.3 MW - 108


Quantity	Value	Units
Total rated capacity	4600	kW
Mean output	1067	kW
Capacity factor	23.20	%
Total production	9348703	kWh/yr
Minimum output	0.99	kW
Maximum output	4625.40	kW
Wind penetration	9.84	%
Hours of operation	8760	hrs/yr
Levelized cost	0.121	\$/kWh

### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	3
Batteries	3
Bus voltage	100



Quantity	Value	Units
Nominal capacity	1800	kWh
Usable nominal capacity	1800	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	539759	kWh/yr
Energy out	379338	kWh/yr
Storage depletion	1800	kWh/yr
Losses	158620	kWh/yr

Quantity	Value	Units
Annual throughput	453396	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity		10,000	kW
Mean output		2,658	kW
Minimum output		0	kW
Maximum output		10,000	kW
Capacity factor		27	%
Hours of operation		4,618	hrs/yr
Energy in		25,868,908	kWh/yr
Energy out		23,281,934	kWh/yr
Losses		2,586,974	kWh/yr




## Grid

Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	15,872	0	253,957
February	0	0	0	15,640	0	250,233
March	0	0	0	17,011	0	272,176
April	0	0	0	14,338	0	229,412
May	0	0	0	13,482	0	215,718
June	0	0	0	19,988	0	319,816
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	18,527	0	296,432
October	0	0	0	15,997	0	255,953
November	0	0	0	15,220	0	243,516
December	0	0	0	16,591	0	265,460
Annual	0	0	0	20,000	0	3,242,673

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,990,218	0	4,990,218	0	598,826	0
February	3,978,615	0	3,978,615	0	477,434	0
March	4,319,255	0	4,319,255	0	518,311	0
April	4,071,989	0	4,071,989	0	488,639	0
May	3,927,020	0	3,927,020	0	471,242	0
June	5,697,224	0	5,697,224	0	683,667	0
July	7,227,189	0	7,227,189	0	867,263	0
August	7,524,698	0	7,524,698	0	902,964	0
September	6,095,000	0	6,095,000	0	731,400	0
October	4,969,575	0	4,969,575	0	596,349	0
November	4,508,634	0	4,508,634	0	541,036	0
December	5,106,119	0	5,106,119	0	612,734	0
Annual	62,415,532	0	62,415,532	0	7,489,864	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	39446616	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	171019	kg/yr
Nitrogen oxides	83637	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 3250 Prime Power	5,600	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	15,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	209014160	\$
Levelized cost of energy	0.170	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Kohler 3250 Prime Power	4,821,429	1,386,639	1,495,738	3,040,480	-985,608	9,758,678
Grid	0	0	144,464,208	0	0	144,464,208
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263

System Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	56,266,140	2,666,635	140,266,944	3,040,480	1,226,139	209,014,060

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Kohler 3250 Prime Power	372,959	107,263	115,702	235,194	-76,241	754,877
Grid	0	0	11,174,939	0	0	11,174,939
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,352,433	206,276	11,469,097	235,194	-94,847	16,168,153




## Electrical

Quantity	Value	Units
Excess electricity	2364608	kWh/yr
Unmet load	16214	kWh/yr
Capacity shortage	91448	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Generator	1,200,312	1
Grid Purchases	69,686,976	70

Total Component	Production(kWh/yr)	100,086,816	Fraction (%)	100
Load	Consumption(kWh/yr)		Fraction (%)	
AC primary load		95,036,248		100
DC primary load		0		0
Total		95,036,248		100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


## Performance metrics for flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh




## PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh



### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	688	hrs/yr
Number of starts	438	starts/yr
Operational life	22	yr
Fixed generation cost	511.50	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	1200312	kWh/yr
Mean electrical output	1745	kW
Min. electrical output	1400	kW
Max. electrical output	5600	kW
Fuel consumption	297715	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	2929512	kWh/yr
Mean electrical efficiency	41	%




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units

Quantity	Value	600	kWh	Units
Usable nominal capacity	600	kWh		
Autonomy	0	hr		
Lifetime throughput	0			
Battery wear cost	0.000	\$/kWh		
Average energy cost	0.281	\$/kWh		
Energy in	5137	kWh/yr		
Energy out	3596	kWh/yr		
Storage depletion	0	kWh/yr		
Losses	1541	kWh/yr		
Annual throughput	4298	kWh/yr		
Expected life	25	yr		



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,757	0	kW
Minimum output	0	0	kW
Maximum output	10,000	179	kW
Capacity factor	28	0	%
Hours of operation	4,389	25	hrs/yr
Energy in	26,836,728	3,795	kWh/yr
Energy out	24,152,896	3,225	kWh/yr
Losses	2,683,832	569	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	15,000	0	240,000
February	0	0	0	14,268	0	228,285
March	0	0	0	15,000	0	240,000
April	0	0	0	13,781	0	220,501
May	0	0	0	13,732	0	219,711
June	0	0	0	15,000	0	240,000
July	0	0	0	15,000	0	240,000
August	0	0	0	15,000	0	240,000
September	0	0	0	15,000	0	240,000
October	0	0	0	14,650	0	234,394
November	0	0	0	14,351	0	229,618
December	0	0	0	15,000	0	240,000
Annual	0	0	0	15,000	0	2,812,509

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,715,638	0	5,715,638	0	685,877	0
February	4,677,284	0	4,677,284	0	561,274	0
March	5,041,829	0	5,041,829	0	605,019	0

	<b>Energy Purchased</b> <small>(kWh)</small>	<b>Energy Sold</b> <small>(kWh)</small>	<b>Net Purchases</b> <small>(kWh)</small>	<b>Peak Demand</b> <small>(kW)</small>	<b>Energy Charge</b> <small>(\$)</small>	<b>Demand Charge</b> <small>(\$)</small>
April	4,674,443	0	4,674,443	0	560,933	0
May	4,723,341	0	4,723,341	0	566,801	0
June	6,407,944	0	6,407,944	0	768,953	0
July	7,575,564	0	7,575,564	0	909,068	0
August	7,684,806	0	7,684,806	0	922,177	0
September	6,589,743	0	6,589,743	0	790,769	0
October	5,538,475	0	5,538,475	0	664,617	0
November	5,234,798	0	5,234,798	0	628,176	0
December	5,823,112	0	5,823,112	0	698,773	0
Annual	69,686,976	0	69,686,976	0	8,362,437	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	44823524	kg/yr
Carbon monoxide	3275	kg/yr
Unburned hydrocarbons	375	kg/yr
Particulate matter	94	kg/yr
Sulfur dioxide	192551	kg/yr
Nitrogen oxides	96655	kg/yr

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Converter	System Converter	10,000	kW
Grid	Grid	27,200	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



Cost Summary


Total net present cost	209074208	\$
Levelized cost of energy	0.170	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Grid	0	0	146,840,352	0	0	146,840,352
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	57,120,124	3,185,663	150,085,920	0	-1,317,567	209,074,140

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Grid	0	0	11,358,744	0	0	11,358,744
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,418,492	246,425	11,609,803	0	-101,920	16,172,800




## Electrical

Quantity	Value	Units
Excess electricity	2886962	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Wind Turbine	4,674,352	5
Grid Purchases	66,696,980	66
Total	100,570,864	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100

Category	Consumption(kWh/yr)	0	Fraction (%)	0
Total	95,052,456		100	



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW

Quantity	Value	Units
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Mean output	7579.50	kWh/d

Quantity	Value	2300	kW
Mean output	534	kW	
Capacity factor	23.20	%	
Total production	4674352	kWh/yr	
Minimum output	0.49	kW	
Maximum output	2312.70	kW	
Wind penetration	4.92	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.129	\$/kWh	

## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,703	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	27	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	26,312,666	0	kWh/yr
Energy out	23,681,260	0	kWh/yr
Losses	2,631,406	0	kWh/yr




## Grid

Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	16,288	0	260,605
February	0	0	0	15,654	0	250,459
March	0	0	0	17,043	0	272,688
April	0	0	0	14,366	0	229,856
May	0	0	0	13,700	0	219,202
June	0	0	0	20,004	0	320,060
July	0	0	0	23,778	0	380,443
August	0	0	0	22,183	0	354,921
September	0	0	0	18,548	0	296,765
October	0	0	0	16,023	0	256,374
November	0	0	0	15,239	0	243,828
December	0	0	0	16,870	0	269,913
Annual	0	0	0	23,778	0	3,355,113

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,374,291	0	5,374,291	0	644,915	0
February	4,338,702	0	4,338,702	0	520,644	0
March	4,682,773	0	4,682,773	0	561,933	0
April	4,374,337	0	4,374,337	0	524,920	0
May	4,326,311	0	4,326,311	0	519,157	0
June	6,124,817	0	6,124,817	0	734,978	0
July	7,604,342	0	7,604,342	0	912,521	0
August	7,819,220	0	7,819,220	0	938,306	0
September	6,429,440	0	6,429,440	0	771,533	0
October	5,262,241	0	5,262,241	0	631,469	0
November	4,884,078	0	4,884,078	0	586,089	0
December	5,476,427	0	5,476,427	0	657,171	0
Annual	66,696,980	0	66,696,980	0	8,003,638	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42152492	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	182750	kg/yr
Nitrogen oxides	89374	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Generator	Kohler 3250 Prime Power	5,600	kW
Converter	System Converter	10,000	kW
Grid	Grid	15,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	209445488	\$
Levelized cost of energy	0.170	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Kohler 3250 Prime Power	4,821,429	1,335,855	1,452,257	2,825,962	-1,024,108	9,411,395
Grid	0	0	137,800,256	0	0	137,800,256
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263

System Component	61,941,552	Replacement	1,521,518	O&M	142,498,032	Fuel	2,341,675	Salvage	Total
------------------	------------	-------------	-----------	-----	-------------	------	-----------	---------	-------

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Kohler 3250 Prime Power	372,959	103,334	112,338	218,601	-79,219	728,013
Grid	0	0	10,659,453	0	0	10,659,453
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,791,451	349,759	11,022,847	218,601	-181,139	16,201,519




## Electrical

Quantity	Value	Units
Excess electricity	2886962	kWh/yr
Unmet load	7555	kWh/yr
Capacity shortage	83283	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3
PV	1,788,429	2
Generator	1,112,217	1
Wind Turbine	4,674,352	5


Component	Production(kWh/yr)	Fraction (%)
Total	100,563,296	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,044,912	100
DC primary load	0	0
Total	95,044,912	100




### PV:SunPower PV

Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%

Quantity	Value	4386	hrs/yr
Levelized cost		0.009	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh



### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	668	hrs/yr
Number of starts	424	starts/yr
Operational life	22	yr
Fixed generation cost	511.50	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	1112217	kWh/yr
Mean electrical output	1665	kW
Min. electrical output	1400	kW
Max. electrical output	5600	kW
Fuel consumption	276710	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	2722823	kWh/yr
Mean electrical efficiency	41	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	10,000	9,000	kW
Mean output	2,703	0	kW
Minimum output	0	0	kW
Maximum output	10,000	0	kW
Capacity factor	27	0	%
Hours of operation	4,386	0	hrs/yr
Energy in	26,312,666	0	kWh/yr
Energy out	23,681,260	0	kWh/yr
Losses	2,631,406	0	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	14,888	0	238,205

	<b>Energy Purchased (kWh)</b>	<b>Energy Sold (kWh)</b>	<b>Net Purchases (kWh)</b>	<b>Peak Demand (kW)</b>	<b>Energy Charge (\$)</b>	<b>Demand Charge (\$)</b>
February	0	0	0	14,254	0	228,059
March	0	0	0	15,000	0	240,000
<b>Resources.ReportingService_GenerateInputsReport_Month</b>						
April	0	0	0	13,267	0	212,265
May	0	0	0	13,516	0	216,263
June	0	0	0	15,000	0	240,000
July	0	0	0	15,000	0	240,000
August	0	0	0	15,000	0	240,000
September	0	0	0	15,000	0	240,000
October	0	0	0	14,623	0	233,974
November	0	0	0	13,839	0	221,428
December	0	0	0	15,000	0	240,000
Annual	0	0	0	15,000	0	2,790,194

Rate: Rate 1

<b>Resources.ReportingService_GenerateInputsReport_Month</b>	<b>Energy Purchased (kWh)</b>	<b>Energy Sold (kWh)</b>	<b>Net Purchases (kWh)</b>	<b>Peak Demand (kW)</b>	<b>Energy Charge (\$)</b>	<b>Demand Charge (\$)</b>
January	5,337,892	0	5,337,892	0	640,547	0
February	4,320,502	0	4,320,502	0	518,460	0
March	4,676,530	0	4,676,530	0	561,184	0
April	4,367,337	0	4,367,337	0	524,080	0
May	4,323,511	0	4,323,511	0	518,821	0
June	6,005,034	0	6,005,034	0	720,604	0
July	7,253,835	0	7,253,835	0	870,460	0
August	7,440,888	0	7,440,888	0	892,907	0
September	6,284,002	0	6,284,002	0	754,080	0
October	5,251,041	0	5,251,041	0	630,125	0
November	4,867,278	0	4,867,278	0	584,073	0
December	5,449,358	0	5,449,358	0	653,923	0
Annual	65,577,200	0	65,577,200	0	7,869,265	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42171020	kg/yr
Carbon monoxide	3044	kg/yr
Unburned hydrocarbons	349	kg/yr
Particulate matter	87	kg/yr
Sulfur dioxide	181177	kg/yr
Nitrogen oxides	90917	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	1	
Generator	Kohler 3250 Prime Power	5,600	kW
Battery	GS200 flow	1	strings
Converter	System Converter	10,000	kW
Grid	Grid	15,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	209549552	\$
Levelized cost of energy	0.171	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	3,083,333	0	280,096	0	0	3,363,429
Siemens 2.3 MW - 108	6,000,000	1,912,842	969,563	0	-1,078,009	7,804,396
Kohler 3250 Prime Power	4,821,429	1,225,634	1,360,948	2,681,734	-1,104,959	8,984,786
Grid	0	0	137,969,088	0	0	137,969,088

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
GS200 flow	824,589	7,176	31,026	0	973	361,818
Converter	3,000,000	1,272,821	0	0	-239,558	4,033,263
System	62,266,140	4,418,472	142,606,624	2,681,734	-2,423,499	209,549,471

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	238,509	0	21,667	0	0	260,176
Siemens 2.3 MW - 108	464,126	147,967	75,000	0	-83,389	603,704
Kohler 3250 Prime Power	372,959	94,808	105,275	207,444	-85,473	695,013
Grid	0	0	10,672,513	0	0	10,672,513
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	232,063	98,458	0	0	-18,531	311,990
System	4,816,559	341,788	11,031,247	207,444	-187,468	16,209,570




## Electrical

Quantity	Value	Units
Excess electricity	2886873	kWh/yr
Unmet load	6236	kWh/yr
Capacity shortage	76596	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	24,644,568	25
PV	2,766,525	3


Component	Production(kWh/yr)	Fraction (%)
Generator	1,056,398	1
Wind Turbine	4,674,352	5
Grid Purchases	65,635,548	65
Total	100,565,824	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,046,216	100
DC primary load	0	0
Total	95,046,216	100




### PV:SunPower PV

Quantity	Value	Units
Rated capacity	13780	kW
Mean output	2813	kW
Mean output	67519.00	kWh/d
Capacity factor	20.42	%
Total production	24644568	kWh/yr
Minimum output	0.00	kW
Maximum output	13941.00	kW
PV penetration	25.93	%
Hours of operation	4386	hrs/yr
Levelized cost	0.111	\$/kWh



PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766525	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	204	kW
Mean output	4899.80	kWh/d
Capacity factor	20.42	%
Total production	1788429	kWh/yr
Minimum output	0.00	kW
Maximum output	1011.70	kW
PV penetration	1.88	%

Quantity	Value	4386	hrs/yr
Levelized cost		0.009	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	2300	kW
Mean output	534	kW
Capacity factor	23.20	%
Total production	4674352	kWh/yr
Minimum output	0.49	kW
Maximum output	2312.70	kW
Wind penetration	4.92	%
Hours of operation	8760	hrs/yr
Levelized cost	0.129	\$/kWh

### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	626	hrs/yr
Number of starts	410	starts/yr
Operational life	24	yr
Fixed generation cost	511.50	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	1056398	kWh/yr
Mean electrical output	1688	kW
Min. electrical output	1400	kW
Max. electrical output	5600	kW
Fuel consumption	262587	L/yr
Specific fuel consumption	0.25	L/kWh
Fuel energy input	2583860	kWh/yr
Mean electrical efficiency	41	%



### Battery:GS200 flow

Quantity	Value	Units
String size	1	
Strings in parallel	1	
Batteries	1	
Bus voltage	100	


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.285	\$/kWh
Energy in	2810	kWh/yr
Energy out	1967	kWh/yr
Storage depletion	0	kWh/yr
Losses	843	kWh/yr
Annual throughput	2351	kWh/yr
Expected life	25	yr



### Converter

Quantity	Inverter	Rectifier	Units

Capacity	Inverter	10,000	Rectifier	9,000	kW
Mean output		2,704		0	kW
Minimum output		0		0	kW
Maximum output		10,000		179	kW
Capacity factor		27		0	%
Hours of operation		4,388		18	hrs/yr
Energy in		26,313,838		2,263	kWh/yr
Energy out		23,682,316		1,924	kWh/yr
Losses		2,631,522		339	kWh/yr



## Grid


Rate: Rate 1 Demand

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	14,888	0	238,205
February	0	0	0	14,254	0	228,059
March	0	0	0	15,000	0	240,000
April	0	0	0	13,645	0	218,325
May	0	0	0	13,516	0	216,263
June	0	0	0	15,000	0	240,000
July	0	0	0	15,000	0	240,000
August	0	0	0	15,000	0	240,000
September	0	0	0	15,000	0	240,000

October	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
November	0	0	0	14,623	0	223,974
<b>Resources.ReportingService_GenerateInputsReport_Month</b>						
December	0	0	0	15,000	0	240,000

Rate: Rate 1

<b>Resources.ReportingService_GenerateInputsReport_Month</b>	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,340,240	0	5,340,240	0	640,829	0
February	4,323,302	0	4,323,302	0	518,796	0
March	4,677,930	0	4,677,930	0	561,352	0
April	4,368,737	0	4,368,737	0	524,248	0
May	4,323,511	0	4,323,511	0	518,821	0
June	6,009,234	0	6,009,234	0	721,108	0
July	7,273,435	0	7,273,435	0	872,812	0
August	7,452,088	0	7,452,088	0	894,251	0
September	6,295,202	0	6,295,202	0	755,424	0
October	5,253,841	0	5,253,841	0	630,461	0
November	4,867,278	0	4,867,278	0	584,073	0
December	5,450,758	0	5,450,758	0	654,091	0
<b>Annual</b>	<b>65,635,548</b>	<b>0</b>	<b>65,635,548</b>	<b>0</b>	<b>7,876,267</b>	<b>0</b>



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42170832	kg/yr
Carbon monoxide	2889	kg/yr
Unburned hydrocarbons	331	kg/yr
Particulate matter	83	kg/yr
Sulfur dioxide	181260	kg/yr
Nitrogen oxides	90840	kg/yr

Pollutant	Emissions	Units
-----------	-----------	-------


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
PV #3	Solar World 320W flat plate PV Copy	6,000	kW
Wind Turbine	Siemens 2.3 MW - 108	6	
Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	70	strings
Converter	System Converter	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	333824096	\$
Levelized cost of energy	0.272	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Solar World 320W flat plate PV Copy	17,666,668	0	818,742	0	0	18,485,410
Siemens 2.3 MW - 108	35,625,000	11,357,500	1,292,751	0	-6,400,678	41,874,573
Kohler 3250 Prime Power	14,821,428	34,618,928	28,073,770	118,660,264	-3,136,350	193,038,040

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
GS200 flow	22,721,244	501,733	2,171,822	0	-68,026	25,326,773
Converter	6,000,000	2,545,641	0	0	-479,115	8,066,526
System	141,871,136	49,023,804	34,352,980	118,660,264	-10,084,170	333,824,014

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Solar World 320W flat plate PV Copy	1,366,594	0	63,333	0	0	1,429,927
Siemens 2.3 MW - 108	2,755,750	878,552	100,000	0	-495,120	3,239,182
Kohler 3250 Prime Power	1,146,502	2,677,926	2,171,629	9,178,891	-242,610	14,932,338
GS200 flow	1,757,588	38,811	168,000	0	-5,262	1,959,137
Converter	464,126	196,916	0	0	-37,062	623,980
System	10,974,354	3,792,206	2,657,354	9,178,891	-780,055	25,822,750




## Electrical

Quantity	Value	Units
Excess electricity	8502696	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)

PV Component	Production(kWh/yr)	Fraction (%)
PV	2,766,526	2
PV	11,727,956	10
Generator	48,951,668	41
Wind Turbine	28,046,112	24
Total	118,427,440	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100



### PV:SunPower PV


Quantity	Value	Units
Rated capacity	13780	kW
Mean output	3075	kW
Mean output	73795.00	kWh/d
Capacity factor	22.31	%
Total production	26935180	kWh/yr
Minimum output	0.00	kW
Maximum output	14957.00	kW
PV penetration	28.34	%
Hours of operation	4386	hrs/yr

Quantity	cost	Value	0.078	Units
----------	------	-------	-------	-------



### PV:Remaining Generic flat plate PV


Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766526	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.009	\$/kWh



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	6000	kW
Mean output	1339	kW
Mean output	32131.00	kWh/d
Capacity factor	22.31	%

Quantity	Value	Units
Total production	11727956	kWh/yr
Minimum output	0.00	kW
Maximum output	6512.50	kW
PV penetration	12.34	%
Hours of operation	4386	hrs/yr
Levelized cost	0.035	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	13800	kW
Mean output	3202	kW
Capacity factor	23.20	%
Total production	28046112	kWh/yr
Minimum output	2.96	kW
Maximum output	13876.00	kW
Wind penetration	29.51	%
Hours of operation	8760	hrs/yr
Levelized cost	0.115	\$/kWh

### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	3070	hrs/yr
Number of starts	1604	starts/yr
Operational life	5	yr
Fixed generation cost	1761.20	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	48951668	kWh/yr

Quantity	Value	Units
Min. electrical output	4200	kW
Max. electrical output	16800	kW
Fuel consumption	11618855	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	114329544	kWh/yr
Mean electrical efficiency	43	%




## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	70
Batteries	70
Bus voltage	100



Quantity	Value	Units
Nominal capacity	42000	kWh
Usable nominal capacity	42000	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.184	\$/kWh
Energy in	26938554	kWh/yr
Energy out	18877262	kWh/yr
Storage depletion	24254	kWh/yr
Losses	8037038	kWh/yr
Annual throughput	22562632	kWh/yr

Quantity	Value	Units
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	20,000	18,000	kW
Mean output	4,263	1,722	kW
Minimum output	0	0	kW
Maximum output	18,041	12,550	kW
Capacity factor	21	9	%
Hours of operation	5,216	2,988	hrs/yr
Energy in	41,488,572	17,746,810	kWh/yr
Energy out	37,339,740	15,084,814	kWh/yr
Losses	4,148,832	2,661,996	kWh/yr



## Emissions

Pollutant	Emissions	Units

Permit	Emissions	30493862	Units
Carbon monoxide		127807	kg/yr
Unburned hydrocarbons		14640	kg/yr
Particulate matter		3660	kg/yr
Sulfur dioxide		62785	kg/yr
Nitrogen oxides		127807	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	SunPower PV	13,780	kW
PV #2	Remaining Generic flat plate PV	1,547	kW
Wind Turbine	Siemens 2.3 MW - 108	8	
Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	70	strings
Converter	System Converter	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	336949504	\$
Levelized cost of energy	0.274	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	40,358,332	0	1,656,876	0	0	42,015,208
Remaining Generic flat plate PV	4,678,459	0	339,013	0	0	5,017,472
Siemens 2.3 MW - 108	47,475,000	15,135,363	1,422,026	0	-8,529,745	55,502,644
Kohler 3250 Prime Power	14,821,428	35,779,392	29,482,028	122,823,920	-2,225,033	200,681,735
GS200 flow	22,721,244	501,733	2,171,822	0	-68,026	25,326,773
Converter	6,000,000	2,545,641	0	0	-479,115	8,066,526

System Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	\$136,054,464	\$53,962,128	\$5,071,768	\$122,823,920	\$11,301,920	\$366,610,360

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SunPower PV	3,121,894	0	128,167	0	0	3,250,061
Remaining Generic flat plate PV	361,899	0	26,224	0	0	388,123
Siemens 2.3 MW - 108	3,672,399	1,170,787	110,000	0	-659,813	4,293,373
Kohler 3250 Prime Power	1,146,502	2,767,693	2,280,564	9,500,968	-172,116	15,523,611
GS200 flow	1,757,588	38,811	168,000	0	-5,262	1,959,137
Converter	464,126	196,916	0	0	-37,062	623,980
System	10,524,409	4,174,207	2,712,955	9,500,968	-874,253	26,038,286




## Electrical

Quantity	Value	Units
Excess electricity	830,049.7	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	625	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	26,935,180	23
PV	2,766,526	2
Generator	50,652,748	43
Wind Turbine	37,394,812	32


Component Total	Production(kWh/yr)	Fraction (%)
	117,749,264	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	95,052,456	100
DC primary load	0	0
Total	95,052,456	100




## PV:SunPower PV

Quantity	Value	Units
Rated capacity	13780	kW
Mean output	3075	kW
Mean output	73795.00	kWh/d
Capacity factor	22.31	%
Total production	26935180	kWh/yr
Minimum output	0.00	kW
Maximum output	14957.00	kW
PV penetration	28.34	%
Hours of operation	4386	hrs/yr
Levelized cost	0.109	\$/kWh



### PV:Remaining Generic flat plate PV

Quantity	Value	Units
Rated capacity	1547	kW
Mean output	316	kW
Mean output	7579.50	kWh/d
Capacity factor	20.42	%
Total production	2766526	kWh/yr
Minimum output	0.00	kW
Maximum output	1565.00	kW
PV penetration	2.91	%
Hours of operation	4386	hrs/yr
Levelized cost	0.013	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	18400	kW
Mean output	4269	kW
Capacity factor	23.20	%
Total production	37394812	kWh/yr
Minimum output	3.95	kW
Maximum output	18502.00	kW

Quantity	Value	Units
Wind penetration	39.34	
Hours of operation	8760	hrs/yr
Levelized cost	0.115	\$/kWh

### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	3224	hrs/yr
Number of starts	1621	starts/yr
Operational life	5	yr
Fixed generation cost	1761.20	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	50652748	kWh/yr
Mean electrical output	15711	kW
Min. electrical output	4200	kW
Max. electrical output	16800	kW
Fuel consumption	12026548	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	118341248	kWh/yr
Mean electrical efficiency	43	%



### Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	70
Batteries	70
Bus voltage	100

Quantity	Value	Units
Nominal capacity	42000	kWh
Usable nominal capacity	42000	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.189	\$/kWh
Energy in	26827478	kWh/yr
Energy out	18808224	kWh/yr
Storage depletion	34694	kWh/yr
Losses	7984560	kWh/yr
Annual throughput	22480140	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	20,000	18,000	kW
Mean output	3,518	1,910	kW
Minimum output	0	0	kW
Maximum output	17,970	12,550	kW
Capacity factor	18	10	%
Hours of operation	4,697	3,337	hrs/yr
Energy in	34,241,788	19,685,400	kWh/yr
Energy out	30,817,560	16,732,604	kWh/yr
Losses	3,424,228	2,952,796	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	31563860	kg/yr
Carbon monoxide	132292	kg/yr
Unburned hydrocarbons	15153	kg/yr
Particulate matter	3788	kg/yr
Sulfur dioxide	64988	kg/yr
Nitrogen oxides	132292	kg/yr


## Appendix C – New London Scenarios

### System Report

#### System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

#### Cost summary



#### Cost Summary

Total net present cost	181204688	\$
Leveledized cost of energy	0.145	\$/kWh

#### Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	20,807	99,446	-178,750	866,503
Grid	0	0	149,859,664	0	0	149,859,664
System	23,425,000	7,173,158	154,728,304	99,446	-4,221,283	181,204,625

#### Annualized Costs


Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	1,610	7,693	-13,827	67,028
Grid	0	0	11,592,301	0	0	11,592,301
System	1,812,026	554,875	11,968,912	7,693	-326,535	14,016,971

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	181204688	\$
Levelized cost of energy	0.145	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	20,807	99,446	-178,750	866,503
Grid	0	0	149,859,664	0	0	149,859,664
System	23,425,000	7,173,158	154,728,304	99,446	-4,221,283	181,204,625

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	1,610	7,693	-13,827	67,028
Grid	0	0	11,592,301	0	0	11,592,301
System	1,812,026	554,875	11,968,912	7,693	-326,535	14,016,971




## Electrical

Quantity	Value	Units
Excess electricity	1742167	kWh/yr
Unmet load	8504	kWh/yr
Capacity shortage	80731	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	33,608	0
Wind Turbine	30,268,832	31
Grid Purchases	68,295,392	69
Total	98,597,832	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,648	100
DC primary load	0	0
Total	96,855,648	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power

Quantity	Value	Units
Hours of operation	116	hrs/yr
Number of starts	108	starts/yr
Operational life	129	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	33608	kWh/yr
Mean electrical output	290	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	9738	L/yr
Specific fuel consumption	0.29	L/kWh

Quantity	Value	Units
Fuel energy input	95817	kWh/yr
Mean electrical efficiency	35	%



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,890	0	254,236
October	0	0	0	13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,431	0	294,896
Annual	0	0	0	20,000	0	3,396,860

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,015,457	0	5,015,457	0	601,855	0
February	3,272,783	0	3,272,783	0	392,734	0
March	3,728,512	0	3,728,512	0	447,421	0
April	6,542,809	0	6,542,809	0	785,137	0
May	5,524,917	0	5,524,917	0	662,990	0

	<b>Energy Purchased</b> (kWh)	<b>Energy Sold</b> (kWh)	<b>Net Purchases</b> (kWh)	<b>Peak Demand</b> (kW)	<b>Energy Charge</b> (\$)	<b>Demand Charge</b> (\$)
June	8,873,156	0	8,873,156	0	\$0	0
July	8,739,009	0	8,739,009	0	(\$16,281)	0
August	8,498,816	0	8,498,816	0	1,019,858	0
September	5,395,241	0	5,395,241	0	647,429	0
October	4,744,924	0	4,744,924	0	569,391	0
November	3,750,403	0	3,750,403	0	450,048	0
December	5,479,366	0	5,479,366	0	657,524	0
Annual	68,295,392	0	68,295,392	0	8,195,448	0



## Emissions


<b>Pollutant</b>	<b>Emissions</b>	<b>Units</b>
Carbon dioxide	43188244	kg/yr
Carbon monoxide	107	kg/yr
Unburned hydrocarbons	12	kg/yr
Particulate matter	3	kg/yr
Sulfur dioxide	187182	kg/yr
Nitrogen oxides	91623	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	181403424	\$
Levelized cost of energy	0.145	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 750 Prime Power	690,000	0	15,387	139,257	-133,613	711,031
Grid	0	0	149,751,216	0	0	149,751,216
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	23,589,588	7,212,154	154,645,456	139,257	-4,183,109	181,403,346

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	11,583,912	0	0	11,583,912
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800
System	1,824,758	557,892	11,962,503	10,772	-323,582	14,032,343




## Electrical

Quantity	Value	Units
Excess electricity	1607580	kWh/yr
Unmet load	10486	kWh/yr
Capacity shortage	96779	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	46,728	0
Wind Turbine	30,268,832	31
Grid Purchases	68,217,656	69
Total	98,533,216	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,853,672	100
DC primary load	0	0
Total	96,853,672	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	115	hrs/yr
Number of starts	108	starts/yr
Operational life	130	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	46728	kWh/yr
Mean electrical output	406	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	13636	L/yr
Specific fuel consumption	0.29	L/kWh


Quantity	Value	Units
Annual energy input	134175	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.035	\$/kWh
Energy in	132507	kWh/yr
Energy out	93257	kWh/yr
Storage depletion	600	kWh/yr
Losses	38649	kWh/yr
Annual throughput	111464	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	10	15	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	4	6	%
Hours of operation	872	1,014	hrs/yr
Energy in	93,257	155,891	kWh/yr
Energy out	83,931	132,507	kWh/yr
Losses	9,326	23,384	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000

September	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
Resources.ReportingService_GenerateInputsReport_Month	0	0	0	15,890 13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,397,800

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,007,178	0	5,007,178	0	600,861	0
February	3,260,560	0	3,260,560	0	391,267	0
March	3,715,573	0	3,715,573	0	445,869	0
April	6,538,779	0	6,538,779	0	784,653	0
May	5,519,575	0	5,519,575	0	662,349	0
June	7,870,852	0	7,870,852	0	944,502	0
July	8,467,073	0	8,467,073	0	1,016,049	0
August	8,496,675	0	8,496,675	0	1,019,601	0
September	5,392,027	0	5,392,027	0	647,043	0
October	4,738,349	0	4,738,349	0	568,602	0
November	3,739,770	0	3,739,770	0	448,772	0
December	5,471,249	0	5,471,249	0	656,550	0
Annual	68,217,656	0	68,217,656	0	8,186,120	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	43149348	kg/yr
Carbon monoxide	150	kg/yr
Unburned hydrocarbons	17	kg/yr
Particulate matter	4	kg/yr

Bulletant	Emissions	186990	kg/yr
Nitrogen oxides		91562	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator #2	Kohler 750 Prime Power	1,380	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	181509216	\$
Levelized cost of energy	0.145	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 750 Prime Power	1,285,000	0	30,472	145,623	-248,317	1,212,778
Grid	0	0	149,817,920	0	0	149,817,920
System	23,785,000	7,173,158	154,696,192	145,623	-4,290,851	181,509,122

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 750 Prime Power	99,400	0	2,357	11,265	-19,208	93,814
Grid	0	0	11,589,072	0	0	11,589,072
System	1,839,874	554,875	11,966,428	11,265	-331,916	14,040,526




## Electrical

Quantity	Value	Units
Excess electricity	1742167	kWh/yr
Unmet load	5237	kWh/yr
Capacity shortage	55203	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	48,613	0
Wind Turbine	30,268,832	31
Grid Purchases	68,283,648	69
Total	98,601,096	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,858,912	100
DC primary load	0	0
Total	96,858,912	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	116	hrs/yr
Number of starts	108	starts/yr
Operational life	129	yr
Fixed generation cost	107.02	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	48613	kWh/yr
Mean electrical output	419	kW
Min. electrical output	345	kW
Max. electrical output	1380	kW
Fuel consumption	14259	L/yr
Specific fuel consumption	0.29	L/kWh

Quantity	Value	Units
Fuel energy input	140309	kWh/yr
Mean electrical efficiency	35	%



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,890	0	254,236
October	0	0	0	13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,317	0	293,076
Annual	0	0	0	20,000	0	3,395,040

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,015,457	0	5,015,457	0	601,855	0
February	3,272,783	0	3,272,783	0	392,734	0
March	3,728,512	0	3,728,512	0	447,421	0
April	6,541,557	0	6,541,557	0	784,987	0
May	5,524,917	0	5,524,917	0	662,990	0

	<b>Energy Purchased</b> (kWh)	<b>Energy Sold</b> (kWh)	<b>Net Purchases</b> (kWh)	<b>Peak Demand</b> (kW)	<b>Energy Charge</b> (\$/15,913)	<b>Demand Charge</b> (\$/0)
June	869,754	0	869,754	0	\$0	\$0
July	8,405,938	0	8,405,938	0	\$0	\$0
August	8,494,914	0	8,494,914	0	1,019,390	0
September	5,395,241	0	5,395,241	0	647,429	0
October	4,744,924	0	4,744,924	0	569,391	0
November	3,750,403	0	3,750,403	0	450,048	0
December	5,479,252	0	5,479,252	0	657,510	0
Annual	68,283,648	0	68,283,648	0	8,194,038	0



## Emissions


<b>Pollutant</b>	<b>Emissions</b>	<b>Units</b>
Carbon dioxide	43192688	kg/yr
Carbon monoxide	157	kg/yr
Unburned hydrocarbons	18	kg/yr
Particulate matter	4	kg/yr
Sulfur dioxide	187174	kg/yr
Nitrogen oxides	91657	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	181599280	\$
Levelized cost of energy	0.145	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	20,627	161,812	-179,119	928,320
Grid	0	0	149,729,776	0	0	149,729,776
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	23,824,588	7,212,154	154,629,264	161,812	-4,228,615	181,599,203

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	11,582,254	0	0	11,582,254
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800
System	1,842,936	557,892	11,961,251	12,517	-327,102	14,047,494




## Electrical

Quantity	Value	Units
Excess electricity	1607580	kWh/yr
Unmet load	8391	kWh/yr
Capacity shortage	80318	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	54,910	0
Wind Turbine	30,268,832	31
Grid Purchases	68,211,680	69
Total	98,535,424	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,760	100
DC primary load	0	0
Total	96,855,760	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power

Quantity	Value	Units
Hours of operation	115	hrs/yr
Number of starts	108	starts/yr
Operational life	130	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	54910	kWh/yr
Mean electrical output	477	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	15844	L/yr
Specific fuel consumption	0.29	L/kWh


Quantity	Value	Units
Annual energy input	155906	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.035	\$/kWh
Energy in	132703	kWh/yr
Energy out	93395	kWh/yr
Storage depletion	600	kWh/yr
Losses	38708	kWh/yr
Annual throughput	111628	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	10	15	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	4	6	%
Hours of operation	873	1,017	hrs/yr
Energy in	93,394	156,121	kWh/yr
Energy out	84,055	132,703	kWh/yr
Losses	9,340	23,419	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000

September	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
Resources.ReportingService_GenerateInputsReport_Month	0	0	0	15,890 13,843	0	254,236 221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,431	0	294,896
Annual	0	0	0	20,000	0	3,396,860

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,007,178	0	5,007,178	0	600,861	0
February	3,260,560	0	3,260,560	0	391,267	0
March	3,715,573	0	3,715,573	0	445,869	0
April	6,538,133	0	6,538,133	0	784,576	0
May	5,519,575	0	5,519,575	0	662,349	0
June	7,869,208	0	7,869,208	0	944,305	0
July	8,465,368	0	8,465,368	0	1,015,844	0
August	8,494,749	0	8,494,749	0	1,019,370	0
September	5,392,027	0	5,392,027	0	647,043	0
October	4,738,349	0	4,738,349	0	568,602	0
November	3,739,770	0	3,739,770	0	448,772	0
December	5,471,190	0	5,471,190	0	656,543	0
Annual	68,211,680	0	68,211,680	0	8,185,402	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	43151364	kg/yr
Carbon monoxide	174	kg/yr
Unburned hydrocarbons	20	kg/yr
Particulate matter	5	kg/yr

Bulletant	Emissions	186986	kg/yr
Nitrogen oxides		91578	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	181785888	\$
Levelized cost of energy	0.145	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	13,991	71,206	-192,784	817,413
Kohler 750 Prime Power	690,000	0	13,648	62,102	-137,195	628,555
Grid	0	0	149,861,392	0	0	149,861,392
System	24,115,000	7,173,158	154,736,864	133,307	-4,372,512	181,785,817

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	1,082	5,508	-14,913	63,230
Kohler 750 Prime Power	53,375	0	1,056	4,804	-10,613	48,622

Grid Component	Capital	0	Replacement	0	O&M	1,592,435	Fuel	0	Salvage	0	Total
System	1,865,401		554,875		11,969,574		10,312		-338,233		14,061,929




## Electrical

Quantity	Value	Units
Excess electricity	1742167	kWh/yr
Unmet load	4013	kWh/yr
Capacity shortage	44902	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	24,079	0
Generator	20,724	0
Wind Turbine	30,268,832	31
Grid Purchases	68,288,688	69
Total	98,602,328	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,860,144	100
DC primary load	0	0
Total	96,860,144	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	78	hrs/yr
Number of starts	73	starts/yr
Operational life	192	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	24079	kWh/yr
Mean electrical output	309	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	6972	L/yr
Specific fuel consumption	0.29	L/kWh

Quantity	Value	Units
Fuel energy input	68607	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	102	hrs/yr
Number of starts	95	starts/yr
Operational life	147	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	20724	kWh/yr
Mean electrical output	203	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	6081	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	59835	kWh/yr
Mean electrical efficiency	35	%



### Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
February	0	0	0	13,686	0	250,977
March	0	0	0	10,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,890	0	254,236
October	0	0	0	13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,397,800

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,015,457	0	5,015,457	0	601,855	0
February	3,272,783	0	3,272,783	0	392,734	0
March	3,728,512	0	3,728,512	0	447,421	0
April	6,542,009	0	6,542,009	0	785,041	0
May	5,524,917	0	5,524,917	0	662,990	0
June	7,870,936	0	7,870,936	0	944,512	0
July	8,466,915	0	8,466,915	0	1,016,030	0
August	8,497,167	0	8,497,167	0	1,019,660	0
September	5,395,241	0	5,395,241	0	647,429	0
October	4,744,924	0	4,744,924	0	569,391	0
November	3,750,403	0	3,750,403	0	450,048	0
December	5,479,425	0	5,479,425	0	657,531	0
Annual	68,288,688	0	68,288,688	0	8,194,643	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	43192712	kg/yr
Carbon monoxide	144	kg/yr
Unburned hydrocarbons	16	kg/yr
Particulate matter	4	kg/yr
Sulfur dioxide	187182	kg/yr
Nitrogen oxides	91650	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	182065680	\$
Levelized cost of energy	0.145	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Grid	0	0	151,587,152	0	0	151,587,152
System	22,500,000	7,173,158	156,434,976	0	-4,042,534	182,065,600

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Grid	0	0	11,725,930	0	0	11,725,930
System	1,740,474	554,875	12,100,930	0	-312,708	14,083,571




## Electrical

Quantity	Value	Units
Excess electricity	1742167	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	1840	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Wind Turbine	30,268,832	31
Grid Purchases	68,337,504	69
Total	98,606,336	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,413	0	326,604
May	0	0	0	17,784	0	284,539
June	0	0	0	21,607	0	345,713
July	0	0	0	23,804	0	380,861
August	0	0	0	21,981	0	351,699
September	0	0	0	15,890	0	254,236

October	0	Energy Purchased (kWh)	0	Energy Sold (kWh)	0	Net Purchases (kWh)	0	Peak Demand (kW)	13,843	Energy Charge (\$)	0	Demand Charge (\$)	221,494
November	Resources.ReportingService_GenerateInputsReport_Month								15,876				254,021
December			0		0		0	18,662		0		298,596	
Annual			0		0		0	23,804		0		3,525,437	

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,015,457	0	5,015,457	0	601,855	0
February	3,272,783	0	3,272,783	0	392,734	0
March	3,728,512	0	3,728,512	0	447,421	0
April	6,545,765	0	6,545,765	0	785,492	0
May	5,524,917	0	5,524,917	0	662,990	0
June	7,881,712	0	7,881,712	0	945,805	0
July	8,488,840	0	8,488,840	0	1,018,661	0
August	8,509,350	0	8,509,350	0	1,021,122	0
September	5,395,241	0	5,395,241	0	647,429	0
October	4,744,924	0	4,744,924	0	569,391	0
November	3,750,403	0	3,750,403	0	450,048	0
December	5,479,597	0	5,479,597	0	657,552	0
Annual	68,337,504	0	68,337,504	0	8,200,500	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	43189304	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	187245	kg/yr
Nitrogen oxides	91572	kg/yr

Pollutant	Emissions	Units
-----------	-----------	-------


HOMER Energy, LLC © 2016

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	182180144	\$
Levelized cost of energy	0.145	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	13,811	110,277	-193,153	855,935
Kohler 750 Prime Power	690,000	0	13,514	85,319	-137,470	651,363
Grid	0	0	149,731,712	0	0	149,731,712
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	24,514,588	7,212,154	154,637,856	195,597	-4,380,119	182,180,076

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	1,068	8,530	-14,941	66,211
Kohler 750 Prime Power	53,375	0	1,045	6,600	-10,634	50,386
Grid	0	0	11,582,404	0	0	11,582,404
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800
System	1,896,311	557,892	11,961,915	15,130	-338,821	14,092,427




## Electrical

Quantity	Value	Units
Excess electricity	1607580	kWh/yr
Unmet load	4013	kWh/yr
Capacity shortage	44676	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	37,426	0
Generator	28,561	0
Wind Turbine	30,268,832	31
Grid Purchases	68,205,056	69
Total	98,539,872	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,860,144	100
DC primary load	0	0

Total	Consumption(kWh/yr)	96,860,144	Fraction (%)	100
-------	---------------------	------------	--------------	-----




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	77	hrs/yr
Number of starts	73	starts/yr
Operational life	195	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	37426	kWh/yr
Mean electrical output	486	kW
Min. electrical output	231	kW
Max. electrical output	925	kW

Quantity	Value	10798	Units
Specific fuel consumption		0.29	L/kWh
Fuel energy input		106252	kWh/yr
Mean electrical efficiency		35	%



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	101	hrs/yr
Number of starts	95	starts/yr
Operational life	149	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	28561	kWh/yr
Mean electrical output	283	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	8354	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	82206	kWh/yr
Mean electrical efficiency	35	%




### Battery:GS200 flow

Quantity	Value
String size	1



String in parallel	Value	1
Batteries		1
Bus voltage		100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.036	\$/kWh
Energy in	132844	kWh/yr
Energy out	93493	kWh/yr
Storage depletion	600	kWh/yr
Losses	38751	kWh/yr
Annual throughput	111746	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	10	15	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	4	6	%
Hours of operation	874	1,016	hrs/yr
Energy in	93,493	156,288	kWh/yr
Energy out	84,144	132,844	kWh/yr
Losses	9,350	23,444	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,784	0	284,539
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,890	0	254,236
October	0	0	0	13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,397,800

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,007,178	0	5,007,178	0	600,861	0
February	3,260,560	0	3,260,560	0	391,267	0
March	3,715,573	0	3,715,573	0	445,869	0

	<b>Energy Purchased</b> (kWh)	<b>Energy Sold</b> (kWh)	<b>Net Purchases</b> (kWh)	<b>Peak Demand</b> (kW)	<b>Energy Charge</b> (\$)	<b>Demand Charge</b> (\$)
April	6,537,505 5,519,575	0	6,537,505 5,519,575	0	84,501 662,349	0
May						
June	7,866,983	0	7,866,983	0	944,038	0
July	8,463,189	0	8,463,189	0	1,015,583	0
August	8,493,100	0	8,493,100	0	1,019,172	0
September	5,392,027	0	5,392,027	0	647,043	0
October	4,738,349	0	4,738,349	0	568,602	0
November	3,739,770	0	3,739,770	0	448,772	0
December	5,471,249	0	5,471,249	0	656,550	0
Annual	68,205,056	0	68,205,056	0	8,184,608	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	43155860	kg/yr
Carbon monoxide	211	kg/yr
Unburned hydrocarbons	24	kg/yr
Particulate matter	6	kg/yr
Sulfur dioxide	186985	kg/yr
Nitrogen oxides	91605	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	5	
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	182415824	\$
Levelized cost of energy	0.146	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Grid	0	0	151,474,640	0	0	151,474,640
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	22,899,588	7,212,154	156,353,488	0	-4,049,496	182,415,734

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Grid	0	0	11,717,227	0	0	11,717,227
GS200 flow	25,108	555	2,400	0	-75	27,988

Component	Capital	5,802	Replacement	2,462	O&M	0	Fuel	0	Salvage	-463	Total	7,800
System		1,771,383		557,892		12,094,627		0	-313,246		14,110,656	




## Electrical

Quantity	Value	Units
Excess electricity	1607580	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	1840	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Wind Turbine	30,268,832	31
Grid Purchases	68,264,976	69
Total	98,533,808	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



### Wind Turbine:Siemens 2.3 MW - 108


Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh


Quantity	Value	Units
Energy in	114399	kWh/yr
Energy out	80582	kWh/yr
Storage depletion	600	kWh/yr
Losses	33217	kWh/yr
Annual throughput	96314	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	8	13	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	3	5	%
Hours of operation	777	917	hrs/yr
Energy in	80,582	134,588	kWh/yr
Energy out	72,523	114,399	kWh/yr
Losses	8,058	20,188	kWh/yr





## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	15,686	0	250,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,413	0	326,604
May	0	0	0	17,784	0	284,539
June	0	0	0	21,607	0	345,713
July	0	0	0	23,804	0	380,861
August	0	0	0	21,981	0	351,699
September	0	0	0	15,890	0	254,236
October	0	0	0	13,843	0	221,494
November	0	0	0	15,876	0	254,021
December	0	0	0	18,662	0	298,596
Annual	0	0	0	23,804	0	3,525,437

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	5,007,178	0	5,007,178	0	600,861	0
February	3,260,560	0	3,260,560	0	391,267	0
March	3,715,573	0	3,715,573	0	445,869	0
April	6,542,332	0	6,542,332	0	785,080	0
May	5,519,575	0	5,519,575	0	662,349	0
June	7,880,695	0	7,880,695	0	945,683	0
July	8,488,147	0	8,488,147	0	1,018,578	0
August	8,509,237	0	8,509,237	0	1,021,108	0

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
September	8,027	0	8,027	0	\$68,602	0
October	8,349	0	8,349	0	\$68,602	0
November	3,739,770	0	3,739,770	0	448,772	0
December	5,471,535	0	5,471,535	0	656,584	0
Annual	68,264,976	0	68,264,976	0	8,191,798	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	43143464	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	187046	kg/yr
Nitrogen oxides	91475	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator #2	Kohler 750 Prime Power	690	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	182618288	\$
Levelized cost of energy	0.146	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 750 Prime Power	690,000	0	13,648	67,521	-137,195	633,974
Grid	0	0	148,009,376	0	0	148,009,376
Converter	225,000	95,462	0	0	-17,967	302,495
System	26,415,000	7,268,619	153,064,752	67,521	-4,197,695	182,618,197

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	53,375	0	1,056	5,223	-10,613	49,041
Grid	0	0	11,449,173	0	0	11,449,173
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,043,316	562,260	11,840,229	5,223	-324,710	14,126,318




## Electrical

Quantity	Value	Units
Excess electricity	1907658	kWh/yr
Unmet load	9237	kWh/yr
Capacity shortage	87708	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	22,553	0
Wind Turbine	30,268,832	31
Grid Purchases	67,294,856	68
Total	98,874,912	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,854,920	100
DC primary load	0	0
Total	96,854,920	100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr

Quantity	Value	7.19	Units
Maximum output	11574.00	kW	
Wind penetration	31.25	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.078	\$/kWh	

### Generator:Kohler 750 Prime Power


Quantity	Value	Units
Hours of operation	102	hrs/yr
Number of starts	96	starts/yr
Operational life	147	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	22553	kWh/yr
Mean electrical output	221	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	6611	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	65056	kWh/yr
Mean electrical efficiency	35	%



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	115	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	15	0	%

Quantity	Inverter	3,902	Rectifier	0	Units
Energy in		1,123,182		0	kWh/yr
Energy out		1,010,865		0	kWh/yr
Losses		112,317		0	kWh/yr




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,373,798

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,952,182	0	4,952,182	0	594,262	0
February	3,207,647	0	3,207,647	0	384,918	0
March	3,646,840	0	3,646,840	0	437,621	0
April	6,450,498	0	6,450,498	0	774,060	0
May	5,429,449	0	5,429,449	0	651,534	0
June	7,766,616	0	7,766,616	0	931,994	0
July	8,362,597	0	8,362,597	0	1,003,512	0
August	8,391,706	0	8,391,706	0	1,007,005	0
September	5,297,231	0	5,297,231	0	635,668	0
October	4,667,008	0	4,667,008	0	560,041	0
November	3,703,306	0	3,703,306	0	444,397	0
December	5,419,775	0	5,419,775	0	650,373	0
Annual	67,294,856	0	67,294,856	0	8,075,382	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42547700	kg/yr
Carbon monoxide	73	kg/yr
Unburned hydrocarbons	8	kg/yr
Particulate matter	2	kg/yr
Sulfur dioxide	184424	kg/yr
Nitrogen oxides	90248	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	182811264	\$
Levelized cost of energy	0.146	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	18,296	87,939	-183,920	847,315
Grid	0	0	147,989,040	0	0	147,989,040
Converter	225,000	95,462	0	0	-17,967	302,495
System	26,650,000	7,268,619	153,049,056	87,939	-4,244,421	182,811,193

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	71,553	0	1,415	6,802	-14,227	65,544
Grid	0	0	11,447,600	0	0	11,447,600
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,061,494	562,260	11,839,015	6,802	-328,325	14,141,246




## Electrical

Quantity	Value	Units
Excess electricity	1907658	kWh/yr
Unmet load	7357	kWh/yr
Capacity shortage	73139	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	29,720	0
Wind Turbine	30,268,832	31
Grid Purchases	67,289,568	68
Total	98,876,792	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,856,792	100
DC primary load	0	0
Total	96,856,792	100



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr

Quantity	Value	7.19	Units
Maximum output	11574.00	kW	
Wind penetration	31.25	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.078	\$/kWh	

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	102	hrs/yr
Number of starts	96	starts/yr
Operational life	147	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	29720	kWh/yr
Mean electrical output	291	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	8611	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	84729	kWh/yr
Mean electrical efficiency	35	%



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	115	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	15	0	%

Quantity	Inverter	3,902	Rectifier	0	Units
Energy in		1,123,182		0	kWh/yr
Energy out		1,010,865		0	kWh/yr
Losses		112,317		0	kWh/yr




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,431	0	294,896
Annual	0	0	0	20,000	0	3,372,858

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,952,182	0	4,952,182	0	594,262	0
February	3,207,647	0	3,207,647	0	384,918	0
March	3,646,840	0	3,646,840	0	437,621	0
April	6,449,910	0	6,449,910	0	773,989	0
May	5,429,449	0	5,429,449	0	651,534	0
June	7,765,030	0	7,765,030	0	931,804	0
July	8,361,306	0	8,361,306	0	1,003,357	0
August	8,389,944	0	8,389,944	0	1,006,793	0
September	5,297,231	0	5,297,231	0	635,668	0
October	4,667,008	0	4,667,008	0	560,041	0
November	3,703,306	0	3,703,306	0	444,397	0
December	5,419,716	0	5,419,716	0	650,366	0
Annual	67,289,568	0	67,289,568	0	8,074,748	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42549608	kg/yr
Carbon monoxide	95	kg/yr
Unburned hydrocarbons	11	kg/yr
Particulate matter	3	kg/yr
Sulfur dioxide	184420	kg/yr
Nitrogen oxides	90263	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	182886224	\$
Levelized cost of energy	0.146	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 750 Prime Power	690,000	0	13,514	108,816	-137,470	674,860
Grid	0	0	147,874,608	0	0	147,874,608
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	26,739,588	7,275,795	152,960,896	108,816	-4,198,944	182,886,151

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 750 Prime Power	53,375	0	1,045	8,417	-10,634	52,204
Grid	0	0	11,438,748	0	0	11,438,748
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,068,424	562,815	11,832,195	8,417	-324,807	14,147,044




## Electrical

Quantity	Value	Units
Excess electricity	1772971	kWh/yr
Unmet load	9137	kWh/yr
Capacity shortage	87507	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	36,489	0
Wind Turbine	30,268,832	31
Grid Purchases	67,207,992	68
Total	98,801,984	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,016	100
DC primary load	0	0

Total	Consumption(kWh/yr)	96,855,016	Fraction (%)	100
-------	---------------------	------------	--------------	-----



#### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




#### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%

Quantity	Value	Unit
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 750 Prime Power


Quantity	Value	Units
Hours of operation	101	hrs/yr
Number of starts	96	starts/yr
Operational life	149	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	36489	kWh/yr
Mean electrical output	361	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	10655	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	104845	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.023	\$/kWh
Energy in	137578	kWh/yr
Energy out	96807	kWh/yr
Storage depletion	600	kWh/yr
Losses	40171	kWh/yr
Annual throughput	115706	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	125	8	kW
Minimum output	0	0	kW
Maximum output	750	179	kW
Capacity factor	17	1	%
Hours of operation	4,379	585	hrs/yr
Energy in	1,212,861	79,536	kWh/yr
Energy out	1,091,576	67,606	kWh/yr
Losses	121,286	11,930	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,373,798

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,942,838	0	4,942,838	0	593,141	0
February	3,194,187	0	3,194,187	0	383,302	0
March	3,633,528	0	3,633,528	0	436,023	0

	<b>Energy Purchased</b> (kWh)	<b>Energy Sold</b> (kWh)	<b>Net Purchases</b> (kWh)	<b>Peak Demand</b> (kW)	<b>Energy Charge</b> (\$)	<b>Demand Charge</b> (\$)
April	6,445,753	0	6,445,753	0	75,490	0
May	5,423,759	0	5,423,759	0	650,851	0
June	7,763,009	0	7,763,009	0	931,561	0
July	8,359,714	0	8,359,714	0	1,003,166	0
August	8,388,528	0	8,388,528	0	1,006,623	0
September	5,293,275	0	5,293,275	0	635,193	0
October	4,660,071	0	4,660,071	0	559,209	0
November	3,692,188	0	3,692,188	0	443,063	0
December	5,411,146	0	5,411,146	0	649,338	0
Annual	67,207,992	0	67,207,992	0	8,064,959	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42503416	kg/yr
Carbon monoxide	117	kg/yr
Unburned hydrocarbons	13	kg/yr
Particulate matter	3	kg/yr
Sulfur dioxide	184207	kg/yr
Nitrogen oxides	90176	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	183079984	\$
Levelized cost of energy	0.146	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	18,116	130,850	-184,290	889,676
Grid	0	0	147,853,584	0	0	147,853,584
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	26,974,588	7,275,795	152,944,432	130,850	-4,245,763	183,079,902

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	1,401	10,122	-14,256	68,820
Grid	0	0	11,437,122	0	0	11,437,122
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,086,603	562,815	11,830,922	10,122	-328,428	14,162,034




## Electrical

Quantity	Value	Units
Excess electricity	1772971	kWh/yr
Unmet load	7257	kWh/yr
Capacity shortage	72939	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	44,379	0
Wind Turbine	30,268,832	31
Grid Purchases	67,202,248	68
Total	98,804,128	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,856,896	100
DC primary load	0	0

Total	Consumption(kWh/yr)	96,856,896	Fraction (%)	100
-------	---------------------	------------	--------------	-----



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%

Quantity	Value	Unit
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	101	hrs/yr
Number of starts	96	starts/yr
Operational life	149	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	44379	kWh/yr
Mean electrical output	439	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	12812	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	126075	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.024	\$/kWh
Energy in	138406	kWh/yr
Energy out	97387	kWh/yr
Storage depletion	600	kWh/yr
Losses	40419	kWh/yr
Annual throughput	116400	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	125	8	kW
Minimum output	0	0	kW
Maximum output	750	179	kW
Capacity factor	17	1	%
Hours of operation	4,377	587	hrs/yr
Energy in	1,212,743	79,690	kWh/yr
Energy out	1,091,470	67,737	kWh/yr
Losses	121,274	11,953	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,000	0	320,000
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,431	0	294,896
Annual	0	0	0	20,000	0	3,372,858

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,942,838	0	4,942,838	0	593,141	0
February	3,194,187	0	3,194,187	0	383,302	0
March	3,633,528	0	3,633,528	0	436,023	0

	<b>Energy Purchased</b> (kWh)	<b>Energy Sold</b> (kWh)	<b>Net Purchases</b> (kWh)	<b>Peak Demand</b> (kW)	<b>Energy Charge</b> (\$)	<b>Demand Charge</b> (\$)
April	6,445,165 5,423,759	0	6,445,165 5,423,759	0	75,420 650,851	0
May						
June	7,761,369	0	7,761,369	0	931,364	0
July	8,358,215	0	8,358,215	0	1,002,986	0
August	8,386,565	0	8,386,565	0	1,006,388	0
September	5,293,275	0	5,293,275	0	635,193	0
October	4,660,071	0	4,660,071	0	559,209	0
November	3,692,188	0	3,692,188	0	443,063	0
December	5,411,088	0	5,411,088	0	649,331	0
Annual	67,202,248	0	67,202,248	0	8,064,269	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42505448	kg/yr
Carbon monoxide	141	kg/yr
Unburned hydrocarbons	16	kg/yr
Particulate matter	4	kg/yr
Sulfur dioxide	184203	kg/yr
Nitrogen oxides	90192	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	183377696	\$
Levelized cost of energy	0.146	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	11,838	61,768	-197,216	801,390
Kohler 750 Prime Power	690,000	0	12,577	56,875	-139,399	620,053
Grid	0	0	147,981,344	0	0	147,981,344
Converter	225,000	95,462	0	0	-17,967	302,495
System	27,340,000	7,268,619	153,047,488	118,642	-4,397,115	183,377,634

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	916	4,778	-15,256	61,991
Kohler 750 Prime Power	53,375	0	973	4,400	-10,783	47,964
Grid	0	0	11,447,005	0	0	11,447,005
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,114,869	562,260	11,838,893	9,178	-340,136	14,185,064




## Electrical

Quantity	Value	Units
Excess electricity	1907658	kWh/yr
Unmet load	3395	kWh/yr
Capacity shortage	39956	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	20,893	0
Generator	18,979	0
Wind Turbine	30,268,832	31
Grid Purchases	67,283,376	68
Total	98,880,752	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,860,760	100

Category	Consumption(kWh/yr)	0	Fraction (%)	0
Total	96,860,760			100



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW

Quantity	Value	Units
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	66	hrs/yr
Number of starts	62	starts/yr
Operational life	227	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	20893	kWh/yr
Mean electrical output	317	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	6048	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	59513	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power


Quantity	Value	Units
Hours of operation	94	hrs/yr
Number of starts	88	starts/yr
Operational life	160	yr


Quantity	Value	Units
Fixed generation cost	56.87	\$/kWh
Marginal generation cost	0.23	\$/kWh
Electrical production	18979	kWh/yr
Mean electrical output	202	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	5569	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	54799	kWh/yr
Mean electrical efficiency	35	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	115	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	15	0	%
Hours of operation	3,902	0	hrs/yr
Energy in	1,123,182	0	kWh/yr
Energy out	1,010,865	0	kWh/yr
Losses	112,317	0	kWh/yr





## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	19,950	0	319,208
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,373,005

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,952,182	0	4,952,182	0	594,262	0
February	3,207,647	0	3,207,647	0	384,918	0
March	3,646,840	0	3,646,840	0	437,621	0
April	6,449,524	0	6,449,524	0	773,943	0
May	5,429,449	0	5,429,449	0	651,534	0
June	7,763,387	0	7,763,387	0	931,606	0
July	8,359,129	0	8,359,129	0	1,003,095	0
August	8,387,901	0	8,387,901	0	1,006,548	0

September	5,297,231 Purchased (kWh)	0 Energy Sold (kWh)	5,297,231 Purchases (kWh)	0 Peak Demand (kW)	0 Energy Charge (\$)	635,668 560,041	Demand Charge (\$)
October	4,667,008	0	4,667,008	0	0	560,041	0
November	3,703,306	0	3,703,306	0	444,397	0	0
December	5,419,775	0	5,419,775	0	650,373	0	0
Annual	67,283,376	0	67,283,376	0	8,074,005	0	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	42553580	kg/yr
Carbon monoxide	128	kg/yr
Unburned hydrocarbons	15	kg/yr
Particulate matter	4	kg/yr
Sulfur dioxide	184419	kg/yr
Nitrogen oxides	90288	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Converter	System Converter	750	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	183534320	\$
Levelized cost of energy	0.147	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Grid	0	0	149,559,376	0	0	149,559,376
Converter	225,000	95,462	0	0	-17,967	302,495
System	25,725,000	7,268,619	154,601,104	0	-4,060,500	183,534,223

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Grid	0	0	11,569,073	0	0	11,569,073

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
System	17,405	7,384	0	0	1,390	23,400
	1,989,941	562,260	11,959,072	0	-314,097	14,197,176




## Electrical

Quantity	Value	Units
Excess electricity	1907658	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	1536	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Wind Turbine	30,268,832	31
Grid Purchases	67,326,648	68
Total	98,884,152	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr

Quantity	Value	7.19	Units
Maximum output	11574.00	kW	
Wind penetration	31.25	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.078	\$/kWh	

## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	115	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	15	0	%
Hours of operation	3,902	0	hrs/yr
Energy in	1,123,182	0	kWh/yr
Energy out	1,010,865	0	kWh/yr
Losses	112,317	0	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
March	0	0	0	16,699	0	267,178
April	Purchased	Sold	Purchases	Demand	Charge	Charge
Resources.ReportingService_GenerateInputsReport_Month	(kWh)	(kWh)	(kWh)	(kW)	(\$)	(\$)
May	0	0	0	17,572	0	281,151
June	0	0	0	21,452	0	343,228
July	0	0	0	23,398	0	374,367
August	0	0	0	21,879	0	350,064
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,662	0	298,596
Annual	0	0	0	23,398	0	3,489,884

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,952,182	0	4,952,182	0	594,262	0
February	3,207,647	0	3,207,647	0	384,918	0
March	3,646,840	0	3,646,840	0	437,621	0
April	6,452,577	0	6,452,577	0	774,309	0
May	5,429,449	0	5,429,449	0	651,534	0
June	7,772,968	0	7,772,968	0	932,756	0
July	8,378,485	0	8,378,485	0	1,005,418	0
August	8,399,006	0	8,399,006	0	1,007,881	0
September	5,297,231	0	5,297,231	0	635,668	0
October	4,667,008	0	4,667,008	0	560,041	0
November	3,703,306	0	3,703,306	0	444,397	0
December	5,419,948	0	5,419,948	0	650,394	0
Annual	67,326,648	0	67,326,648	0	8,079,197	0



**Emissions**

Pollutant	Emissions	Units
Carbon dioxide	42550440	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	184475	kg/yr
Nitrogen oxides	90218	kg/yr

---


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	183645824	\$
Levelized cost of energy	0.147	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Kohler 1000 Prime Power	925,000	0	11,838	88,287	-197,216	827,909
Kohler 750 Prime Power	690,000	0	12,443	72,292	-139,674	635,061
Grid	0	0	147,846,112	0	0	147,846,112
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495

System Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	27,664,588	7,275,705	152,943,152	160,578	4,398,363	183,645,750

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Siemens 2.3 MW - 108	1,740,474	554,875	375,000	0	-312,708	2,357,641
Kohler 1000 Prime Power	71,553	0	916	6,829	-15,256	64,042
Kohler 750 Prime Power	53,375	0	963	5,592	-10,804	49,126
Grid	0	0	11,436,544	0	0	11,436,544
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,139,977	562,815	11,830,823	12,421	-340,233	14,205,803




## Electrical

Quantity	Value	Units
Excess electricity	1772971	kWh/yr
Unmet load	3395	kWh/yr
Capacity shortage	39756	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	29,950	0
Generator	24,183	0
Wind Turbine	30,268,832	31
Grid Purchases	67,196,216	68

Total Component	Production(kWh/yr)	98,807,856	Fraction (%)	100
Load	Consumption(kWh/yr)		Fraction (%)	
AC primary load		96,860,760		100
DC primary load		0		0
Total		96,860,760		100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	66	hrs/yr
Number of starts	62	starts/yr
Operational life	227	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	29950	kWh/yr
Mean electrical output	454	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	8645	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	85064	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power

Quantity	Value	Units

Quantity	Value	Units
Number of starts	88	starts/yr
Operational life	161	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	24183	kWh/yr
Mean electrical output	260	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	7079	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	69653	kWh/yr
Mean electrical efficiency	35	%




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100



Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.023	\$/kWh
Energy in	138058	kWh/yr

Quantity	Value	Units
Storage depletion	600	kWh/yr
Losses	40315	kWh/yr
Annual throughput	116108	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity		750	kW
Mean output		125	kW
Minimum output		0	kW
Maximum output		750	kW
Capacity factor		17	%
Hours of operation		4,378	hrs/yr
Energy in		1,212,694	kWh/yr
Energy out		1,091,425	kWh/yr
Losses		121,269	kWh/yr




Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	19,950	0	319,208
May	0	0	0	17,572	0	281,151
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623
November	0	0	0	15,876	0	254,021
December	0	0	0	18,490	0	295,836
Annual	0	0	0	20,000	0	3,373,005

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,942,838	0	4,942,838	0	593,141	0
February	3,194,187	0	3,194,187	0	383,302	0
March	3,633,528	0	3,633,528	0	436,023	0
April	6,444,779	0	6,444,779	0	773,373	0
May	5,423,759	0	5,423,759	0	650,851	0
June	7,759,668	0	7,759,668	0	931,160	0
July	8,356,055	0	8,356,055	0	1,002,727	0
August	8,384,725	0	8,384,725	0	1,006,167	0
September	5,293,275	0	5,293,275	0	635,193	0
October	4,660,071	0	4,660,071	0	559,209	0
November	3,692,188	0	3,692,188	0	443,063	0
December	5,411,146	0	5,411,146	0	649,338	0
Annual	67,196,216	0	67,196,216	0	8,063,546	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42509272	kg/yr
Carbon monoxide	173	kg/yr
Unburned hydrocarbons	20	kg/yr
Particulate matter	5	kg/yr
Sulfur dioxide	184203	kg/yr
Nitrogen oxides	90216	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Wind Turbine	Siemens 2.3 MW - 108	5	
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	183774336	\$
Levelized cost of energy	0.147	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Siemens 2.3 MW - 108	22,500,000	7,173,158	4,847,816	0	-4,042,534	30,478,440
Grid	0	0	149,437,584	0	0	149,437,584
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	26,049,588	7,275,795	154,510,368	0	-4,061,473	183,774,278

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	1740,474	554,875	375,000	0	312,708	2,357,641
Grid	0	0	11,559,652	0	0	11,559,652
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	2,015,050	562,815	11,952,054	0	-314,173	14,215,746




## Electrical

Quantity	Value	Units
Excess electricity	1772971	kWh/yr
Unmet load	1	kWh/yr
Capacity shortage	1536	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Wind Turbine	30,268,832	31
Grid Purchases	67,248,128	68
Total	98,805,632	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



### PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



### Wind Turbine:Siemens 2.3 MW - 108


Quantity	Value	Units
Total rated capacity	11500	kW
Mean output	3455	kW
Capacity factor	30.05	%
Total production	30268832	kWh/yr

Quantity	Value	Units
Minimum output	7.19	kW
Maximum output	11574.00	kW
Wind penetration	31.25	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	123910	kWh/yr
Energy out	87240	kWh/yr
Storage depletion	600	kWh/yr
Losses	36070	kWh/yr
Annual throughput	104271	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW

Quantity	Inverter	124	Rectifier	7	kW Units
Minimum output		0		0	kW
Maximum output		750		179	kW
Capacity factor		17		1	%
Hours of operation		4,378		536	hrs/yr
Energy in		1,210,425		71,846	kWh/yr
Energy out		1,089,383		61,070	kWh/yr
Losses		121,042		10,777	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,095	0	289,519
February	0	0	0	14,936	0	238,977
March	0	0	0	16,699	0	267,178
April	0	0	0	20,354	0	325,668
May	0	0	0	17,572	0	281,151
June	0	0	0	21,452	0	343,228
July	0	0	0	23,398	0	374,367
August	0	0	0	21,879	0	350,064
September	0	0	0	15,468	0	247,493
October	0	0	0	13,726	0	219,623

November	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
December	0	0	0	15,876	0	254,021
<b>Resources.ReportingService_GenerateInputsReport_Month</b>						
Annual	0	0	0	23,398	0	3,489,884

Rate: Rate 1

<b>Resources.ReportingService_GenerateInputsReport_Month</b>	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	4,942,838	0	4,942,838	0	593,141	0
February	3,194,187	0	3,194,187	0	383,302	0
March	3,633,528	0	3,633,528	0	436,023	0
April	6,448,824	0	6,448,824	0	773,859	0
May	5,423,759	0	5,423,759	0	650,851	0
June	7,771,824	0	7,771,824	0	932,619	0
July	8,377,567	0	8,377,567	0	1,005,308	0
August	8,398,634	0	8,398,634	0	1,007,836	0
September	5,293,275	0	5,293,275	0	635,193	0
October	4,660,071	0	4,660,071	0	559,209	0
November	3,692,188	0	3,692,188	0	443,063	0
December	5,411,432	0	5,411,432	0	649,372	0
Annual	67,248,128	0	67,248,128	0	8,069,775	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	42500816	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	184260	kg/yr
Nitrogen oxides	90112	kg/yr




# System Report

## System architecture

Generator	Kohler 1000 Prime Power	1,850	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	197132240	\$
Levelized cost of energy	0.157	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	1,637,500	0	66,073	360,152	-268,055	1,795,670
Grid	0	0	195,336,464	0	0	195,336,464
System	1,637,500	0	195,402,544	360,152	-268,055	197,132,141

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	126,668	0	5,111	27,859	-20,735	138,903
Grid	0	0	15,110,131	0	0	15,110,131
System	126,668	0	15,115,242	27,859	-20,735	15,249,034




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	10032	kWh/yr
Capacity shortage	82792	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	121,836	0
Grid Purchases	96,732,328	100
Total	96,854,160	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,854,128	100
DC primary load	0	0
Total	96,854,128	100



### Generator:Kohler 1000 Prime Power

Quantity	Value	Units
Hours of operation	190	hrs/yr
Number of starts	170	starts/yr
Operational life	79	yr
Fixed generation cost	137.46	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	121836	kWh/yr
Mean electrical output	641	kW
Min. electrical output	463	kW
Max. electrical output	1850	kW
Fuel consumption	35265	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	347008	kWh/yr
Mean electrical efficiency	35	%



### Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,090	0	289,443
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,606	0	313,698
Annual	0	0	0	20,000	0	3,502,259

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,208,348	0	8,208,348	0	985,002	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,441,886	0	9,441,886	0	1,133,026	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,779,835	0	9,779,835	0	1,173,580	0
July	9,962,285	0	9,962,285	0	1,195,474	0
August	9,872,852	0	9,872,852	0	1,184,742	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,677,315	0	8,677,315	0	1,041,278	0
Annual	96,732,328	0	96,732,328	0	11,607,880	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	61227384	kg/yr
Carbon monoxide	388	kg/yr
Unburned hydrocarbons	44	kg/yr
Particulate matter	11	kg/yr
Sulfur dioxide	265237	kg/yr
Nitrogen oxides	130009	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Generator #2	Kohler 750 Prime Power	2,070	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	197277584	\$
Levelized cost of energy	0.158	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	1,802,500	0	73,638	395,627	-295,065	1,976,700
Grid	0	0	195,300,800	0	0	195,300,800
System	1,802,500	0	195,374,432	395,627	-295,065	197,277,494

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	139,431	0	5,696	30,604	-22,825	152,906
Grid	0	0	15,107,372	0	0	15,107,372
System	139,431	0	15,113,068	30,604	-22,825	15,260,278




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	7997	kWh/yr
Capacity shortage	68806	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	132,207	0
Grid Purchases	96,723,992	100
Total	96,856,200	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,856,160	100
DC primary load	0	0
Total	96,856,160	100



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	190	hrs/yr
Number of starts	170	starts/yr
Operational life	79	yr
Fixed generation cost	151.69	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	132207	kWh/yr
Mean electrical output	696	kW
Min. electrical output	518	kW
Max. electrical output	2070	kW
Fuel consumption	38739	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	381188	kWh/yr
Mean electrical efficiency	35	%



### Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,035	0	288,563
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,551	0	312,818
Annual	0	0	0	20,000	0	3,500,499

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,208,183	0	8,208,183	0	984,982	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,440,184	0	9,440,184	0	1,132,822	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,777,930	0	9,777,930	0	1,173,352	0
July	9,960,415	0	9,960,415	0	1,195,250	0
August	9,870,487	0	9,870,487	0	1,184,458	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,676,985	0	8,676,985	0	1,041,238	0
Annual	96,723,992	0	96,723,992	0	11,606,880	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	61231236	kg/yr
Carbon monoxide	426	kg/yr
Unburned hydrocarbons	49	kg/yr
Particulate matter	12	kg/yr
Sulfur dioxide	265233	kg/yr
Nitrogen oxides	130036	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	197556960	\$
Levelized cost of energy	0.158	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	925,000	0	22,421	159,833	-175,426	931,828
Kohler 750 Prime Power	690,000	0	21,007	119,719	-122,043	708,683
Grid	0	0	195,453,680	0	0	195,453,680
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	2,014,589	38,996	195,528,160	279,551	-304,430	197,556,866

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	71,553	0	1,734	12,364	-13,570	72,081
Kohler 750 Prime Power	53,375	0	1,625	9,261	-9,441	54,820

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	15,119,198	0	0	15,119,198
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800
System	155,837	3,017	15,124,959	21,625	-23,549	15,281,889




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	10816	kWh/yr
Capacity shortage	87614	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	54,204	0
Generator	40,041	0
Grid Purchases	96,761,408	100
Total	96,855,648	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,853,336	100
DC primary load	0	0
Total	96,853,336	100



### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	125	hrs/yr
Number of starts	113	starts/yr
Operational life	120	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	54204	kWh/yr
Mean electrical output	434	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	15650	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	153999	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	157	hrs/yr
Number of starts	143	starts/yr

Quantity	Value	Units
Operational life	96	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	40041	kWh/yr
Mean electrical output	255	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	11723	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	115350	kWh/yr
Mean electrical efficiency	35	%




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100



Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.361	\$/kWh
Energy in	4149	kWh/yr
Energy out	2905	kWh/yr
Storage depletion	0	kWh/yr

Quantity	Value	Units
Annual throughput	3472	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	0	0	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	0	0	%
Hours of operation	17	30	hrs/yr
Energy in	2,905	4,881	kWh/yr
Energy out	2,614	4,149	kWh/yr
Losses	290	732	kWh/yr




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,380	0	294,083
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,665	0	314,638
Annual	0	0	0	20,000	0	3,507,839

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,208,939	0	8,208,939	0	985,073	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,447,916	0	9,447,916	0	1,133,750	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,786,386	0	9,786,386	0	1,174,366	0
July	9,969,422	0	9,969,422	0	1,196,331	0
August	9,880,399	0	9,880,399	0	1,185,648	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,678,534	0	8,678,534	0	1,041,424	0
Annual	96,761,408	0	96,761,408	0	11,611,368	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	61225048	kg/yr
Carbon monoxide	301	kg/yr
Unburned hydrocarbons	34	kg/yr
Particulate matter	9	kg/yr
Sulfur dioxide	265274	kg/yr
Nitrogen oxides	129961	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	1,380	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	197574432	\$
Levelized cost of energy	0.158	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	925,000	0	28,520	168,299	-162,869	958,950
Kohler 750 Prime Power	1,285,000	0	31,260	162,939	-246,778	1,232,421
Grid	0	0	195,382,944	0	0	195,382,944
System	2,210,000	0	195,442,736	331,238	-409,647	197,574,327

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	71,553	0	2,206	13,019	-12,599	74,179
Kohler 750 Prime Power	99,400	0	2,418	12,604	-19,089	95,333
Grid	0	0	15,113,726	0	0	15,113,726
System	170,953	0	15,118,351	25,623	-31,688	15,283,239




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	6127	kWh/yr
Capacity shortage	57094	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	56,991	0
Generator	54,442	0
Grid Purchases	96,746,632	100
Total	96,858,064	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,858,024	100
DC primary load	0	0
Total	96,858,024	100



### Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	159	hrs/yr
Number of starts	144	starts/yr
Operational life	94	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	56991	kWh/yr
Mean electrical output	358	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	16479	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	162156	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	119	hrs/yr
Number of starts	107	starts/yr

Quantity	Value	Units
Operational life	126	yr
Fixed generation cost	107.02	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	54442	kWh/yr
Mean electrical output	458	kW
Min. electrical output	345	kW
Max. electrical output	1380	kW
Fuel consumption	15955	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	156993	kWh/yr
Mean electrical efficiency	35	%




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,321	0	293,143
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,492	0	311,878

Annual	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
Rate: Rate 1						
Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,209,042	0	8,209,042	0	985,085	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,444,701	0	9,444,701	0	1,133,364	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,782,846	0	9,782,846	0	1,173,942	0
July	9,966,205	0	9,966,205	0	1,195,945	0
August	9,875,789	0	9,875,789	0	1,185,095	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,678,243	0	8,678,243	0	1,041,389	0
Annual	96,746,632	0	96,746,632	0	11,609,597	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	61228996	kg/yr
Carbon monoxide	357	kg/yr
Unburned hydrocarbons	41	kg/yr
Particulate matter	10	kg/yr
Sulfur dioxide	265261	kg/yr
Nitrogen oxides	129997	kg/yr

# System Report

## System architecture

Generator	Kohler 1000 Prime Power	1,850	kW
Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	197614656	\$
Levelized cost of energy	0.158	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	1,637,500	0	61,204	352,161	-277,208	1,773,657
Grid	0	0	195,378,288	0	0	195,378,288
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	2,037,089	38,996	195,470,464	352,161	-284,170	197,614,540

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 1000 Prime Power	126,668	0	4,734	27,241	-21,443	137,200
Grid	0	0	15,113,366	0	0	15,113,366
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800

Component System	Capital	Replacement	O&M	Fuel	Salvage	Total
	157,578	3,017	15,120,496	27,241	-21,982	15,286,350




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	8432	kWh/yr
Capacity shortage	72100	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	119,192	0
Grid Purchases	96,738,344	100
Total	96,857,536	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,720	100
DC primary load	0	0
Total	96,855,720	100



### Generator:Kohler 1000 Prime Power

Quantity	Value	Units
Hours of operation	176	hrs/yr
Number of starts	157	starts/yr
Operational life	85	yr
Fixed generation cost	137.46	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	119192	kWh/yr
Mean electrical output	677	kW
Min. electrical output	463	kW
Max. electrical output	1850	kW
Fuel consumption	34483	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	339308	kWh/yr
Mean electrical efficiency	35	%




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1


Quantity	Value	Units
Batteries	1	
Bus voltage	100	

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.359	\$/kWh
Energy in	3257	kWh/yr
Energy out	2280	kWh/yr
Storage depletion	0	kWh/yr
Losses	977	kWh/yr
Annual throughput	2725	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	0	0	kW
Minimum output	0	0	kW
Maximum output	166	179	kW
Capacity factor	0	0	%
Hours of operation	14	24	hrs/yr
Energy in	2,280	3,832	kWh/yr
Energy out	2,052	3,257	kWh/yr
Losses	228	575	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,247	0	291,953
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,606	0	313,698
Annual	0	0	0	20,000	0	3,504,769

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,208,359	0	8,208,359	0	985,003	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
April	9,442,810	0	9,442,810	0	1,133,137	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,780,760	0	9,780,760	0	1,173,691	0
July	9,964,135	0	9,964,135	0	1,195,696	0
August	9,875,164	0	9,875,164	0	1,185,020	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,677,315	0	8,677,315	0	1,041,278	0
Annual	96,738,344	0	96,738,344	0	11,608,602	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	61229132	kg/yr
Carbon monoxide	379	kg/yr
Unburned hydrocarbons	43	kg/yr
Particulate matter	11	kg/yr
Sulfur dioxide	265249	kg/yr
Nitrogen oxides	130009	kg/yr

# System Report

## System architecture

Generator #2	Kohler 750 Prime Power	1,380	kW
Battery	GS200 flow	2	strings
Converter	System Converter	500	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	197753920	\$
Levelized cost of energy	0.158	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	1,285,000	0	41,505	292,709	-226,769	1,392,445
Grid	0	0	195,436,096	0	0	195,436,096
GS200 flow	649,178	14,343	62,052	0	-1,945	723,628
Converter	150,000	63,641	0	0	-11,978	201,663
System	2,084,178	77,984	195,539,664	292,709	-240,692	197,753,843

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	99,400	0	3,211	22,642	-17,542	107,711
Grid	0	0	15,117,838	0	0	15,117,838
GS200 flow	50,217	1,110	4,800	0	-150	55,976
Converter	11,603	4,923	0	0	-927	15,599

Component System	Capital	Replacement	O&M	Fuel	Salvage	Total
	161,220	6,032	15,125,849	22,642	-78,619	15,297,124




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	11701	kWh/yr
Capacity shortage	92542	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	98,052	0
Grid Purchases	96,759,968	100
Total	96,858,024	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,852,464	100
DC primary load	0	0
Total	96,852,464	100



### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	158	hrs/yr
Number of starts	143	starts/yr
Operational life	95	yr
Fixed generation cost	107.02	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	98052	kWh/yr
Mean electrical output	621	kW
Min. electrical output	345	kW
Max. electrical output	1380	kW
Fuel consumption	28661	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	282026	kWh/yr
Mean electrical efficiency	35	%




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	2


Quantity	Value	Units
Batteries	2	
Bus voltage	100	

Quantity	Value	Units
Nominal capacity	1200	kWh
Usable nominal capacity	1200	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.363	\$/kWh
Energy in	10100	kWh/yr
Energy out	7070	kWh/yr
Storage depletion	0	kWh/yr
Losses	3030	kWh/yr
Annual throughput	8451	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	500	450	kW
Mean output	1	1	kW
Minimum output	0	0	kW
Maximum output	331	359	kW
Capacity factor	0	0	%
Hours of operation	23	38	hrs/yr
Energy in	7,070	11,883	kWh/yr
Energy out	6,363	10,100	kWh/yr
Losses	707	1,782	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,247	0	291,953
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	20,000	0	320,000
May	0	0	0	17,869	0	285,902
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	19,724	0	315,578
Annual	0	0	0	20,000	0	3,506,649

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,208,142	0	8,208,142	0	984,977	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
May	9,447,481	0	9,447,481	0	936,706	0
Resources.ReportingService_GenerateInputsReport_Month	7,805,883	0	7,805,883	0		
June	9,785,834	0	9,785,834	0	1,174,300	0
July	9,968,291	0	9,968,291	0	1,196,195	0
August	9,882,045	0	9,882,045	0	1,185,845	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,678,365	0	8,678,365	0	1,041,404	0
Annual	96,759,968	0	96,759,968	0	11,611,196	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	61227520	kg/yr
Carbon monoxide	315	kg/yr
Unburned hydrocarbons	36	kg/yr
Particulate matter	9	kg/yr
Sulfur dioxide	265277	kg/yr
Nitrogen oxides	129974	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	198261296	\$
Levelized cost of energy	0.158	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 1000 Prime Power	925,000	0	22,242	141,871	-175,795	913,318
Kohler 750 Prime Power	690,000	0	21,408	108,781	-121,216	698,973
Grid	0	0	193,152,480	0	0	193,152,480
Converter	225,000	95,462	0	0	-17,967	302,495
System	4,840,000	95,462	193,390,064	250,652	-314,978	198,261,200

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 1000 Prime Power	71,553	0	1,721	10,974	-13,599	70,649

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 750 Prime Power	53,375	0	1,656	8,415	-9,377	54,069
Grid	0	0	14,941,190	0	0	14,941,190
Converter	17,405	7,384	0	0	-1,390	23,400
System	374,395	7,384	14,959,568	19,389	-24,365	15,336,371




## Electrical

Quantity	Value	Units
Excess electricity	5225	kWh/yr
Unmet load	10040	kWh/yr
Capacity shortage	88587	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	48,072	0
Generator	36,344	0
Grid Purchases	95,614,640	99
Total	96,987,728	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,854,112	100
DC primary load	0	0
Total	96,854,112	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	124	hrs/yr
Number of starts	114	starts/yr
Operational life	121	yr
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh

Quantity	Value	Units
Electrical production	48072	kWh/yr
Mean electrical output	388	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	13892	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	136693	kWh/yr
Mean electrical efficiency	35	%





### Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	160	hrs/yr
Number of starts	144	starts/yr
Operational life	94	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	36344	kWh/yr
Mean electrical output	227	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	10652	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	104811	kWh/yr
Mean electrical efficiency	35	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	18	0	%
Hours of operation	4,377	0	hrs/yr
Energy in	1,283,450	0	kWh/yr
Energy out	1,155,104	0	kWh/yr
Losses	128,346	0	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,380	0	294,083
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,488	0	311,800
Annual	0	0	0	20,000	0	3,467,443

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,131,761	0	8,131,761	0	975,811	0
February	6,023,890	0	6,023,890	0	722,867	0
March	6,708,956	0	6,708,956	0	805,075	0
April	9,347,045	0	9,347,045	0	1,121,645	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,679,243	0	9,679,243	0	1,161,509	0
July	9,859,910	0	9,859,910	0	1,183,189	0
August	9,771,679	0	9,771,679	0	1,172,602	0
September	6,837,491	0	6,837,491	0	820,499	0
October	6,699,125	0	6,699,125	0	803,895	0
November	6,249,541	0	6,249,541	0	749,945	0
December	8,608,863	0	8,608,863	0	1,033,064	0
Annual	95,614,640	0	95,614,640	0	11,473,756	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	60492868	kg/yr
Carbon monoxide	270	kg/yr
Unburned hydrocarbons	31	kg/yr
Particulate matter	8	kg/yr
Sulfur dioxide	262117	kg/yr
Nitrogen oxides	128394	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 1000 Prime Power	1,850	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	198,295,184	\$
Levelized cost of energy	0.158	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 1000 Prime Power	1,637,500	0	62,943	331,191	-273,939	1,757,695
Grid	0	0	193,040,976	0	0	193,040,976
Converter	225,000	95,462	0	0	-17,967	302,495
System	4,862,500	95,462	193,297,856	331,191	-291,906	198,295,103

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 1000 Prime Power	126,668	0	4,869	25,619	-21,190	135,966
Grid	0	0	14,932,565	0	0	14,932,565
Converter	17,405	7,384	0	0	-1,390	23,400

Component System	Capital	Replacement	O&M	Fuel	Salvage	Total
	376,136	7,384	14,952,436	25,619	-22,580	15,338,995




## Electrical

Quantity	Value	Units
Excess electricity	5225	kWh/yr
Unmet load	7831	kWh/yr
Capacity shortage	73016	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	112,000	0
Grid Purchases	95,589,264	99
Total	96,989,936	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,856,328	100
DC primary load	0	0
Total	96,856,328	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	181	hrs/yr
Number of starts	162	starts/yr
Operational life	83	yr
Fixed generation cost	137.46	\$/hr
Marginal generation cost	0.23	\$/kWh


Quantity	Value	Units
Electrical production	112000	kWh/yr
Mean electrical output	619	kW
Min. electrical output	463	kW
Max. electrical output	1850	kW
Fuel consumption	32429	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	319103	kWh/yr
Mean electrical efficiency	35	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	18	0	%
Hours of operation	4,377	0	hrs/yr
Energy in	1,283,450	0	kWh/yr
Energy out	1,155,104	0	kWh/yr
Losses	128,346	0	kWh/yr





## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,090	0	289,443
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,429	0	310,860
Annual	0	0	0	20,000	0	3,461,863

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,130,891	0	8,130,891	0	975,707	0
February	6,023,890	0	6,023,890	0	722,867	0
March	6,708,956	0	6,708,956	0	805,075	0
April	9,341,935	0	9,341,935	0	1,121,032	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,673,265	0	9,673,265	0	1,160,792	0
July	9,853,874	0	9,853,874	0	1,182,465	0
August	9,765,519	0	9,765,519	0	1,171,862	0

September	6,837,491 Purchased (kWh)	0 Sold (kWh)	6,837,491 Purchases (kWh)	0 Demand (kW)	820,499 Energy Charge (\$)	Demand Charge (\$)
October Resources.ReportingService_GenerateInputsReport_Month	6,699,125 (kWh)	0 (kWh)	6,699,125 (kWh)	0 (kW)	803,895 Energy Charge (\$)	0 (\$)
November	6,249,541	0	6,249,541	0	749,945	0
December	8,607,644	0	8,607,644	0	1,032,917	0
Annual	95,589,264	0	95,589,264	0	11,470,711	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	60497528	kg/yr
Carbon monoxide	357	kg/yr
Unburned hydrocarbons	41	kg/yr
Particulate matter	10	kg/yr
Sulfur dioxide	262090	kg/yr
Nitrogen oxides	128446	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator #2	Kohler 750 Prime Power	1,380	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	198358448	\$
Levelized cost of energy	0.158	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 750 Prime Power	1,285,000	0	42,555	266,901	-224,717	1,369,739
Grid	0	0	193,130,400	0	0	193,130,400
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	4,834,589	102,637	193,397,920	266,901	-243,657	198,358,390

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 750 Prime Power	99,400	0	3,292	20,646	-17,383	105,955

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	14,939,482	0	0	14,939,482
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	373,977	7,939	14,960,176	20,646	-18,848	15,343,890




## Electrical

Quantity	Value	Units
Excess electricity	2745	kWh/yr
Unmet load	10858	kWh/yr
Capacity shortage	93644	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	89,327	0
Grid Purchases	95,610,304	99
Total	96,988,304	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,853,304	100
DC primary load	0	0
Total	96,853,304	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 750 Prime Power

Quantity	Value	Units
Hours of operation	162	hrs/yr
Number of starts	146	starts/yr
Operational life	93	yr
Fixed generation cost	107.02	\$/hr
Marginal generation cost	0.23	\$/kWh


Quantity	Value	Units
Electrical production	89327	kWh/yr
Mean electrical output	551	kW
Min. electrical output	345	kW
Max. electrical output	1380	kW
Fuel consumption	26134	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	257160	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow



Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.184	\$/kWh
Energy in	9945	kWh/yr
Energy out	6961	kWh/yr
Storage depletion	0	kWh/yr
Losses	2983	kWh/yr
Annual throughput	8320	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	179	kW
Capacity factor	18	0	%
Hours of operation	4,390	29	hrs/yr
Energy in	1,286,347	4,001	kWh/yr
Energy out	1,157,711	3,401	kWh/yr
Losses	128,636	600	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,247	0	291,953
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,546	0	312,740
Annual	0	0	0	20,000	0	3,466,253

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,130,624	0	8,130,624	0	975,675	0
February	6,023,001	0	6,023,001	0	722,760	0
March	6,708,603	0	6,708,603	0	805,032	0
April	9,346,668	0	9,346,668	0	1,121,600	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,679,151	0	9,679,151	0	1,161,498	0
July	9,859,018	0	9,859,018	0	1,183,082	0
August	9,771,599	0	9,771,599	0	1,172,592	0
September	6,837,491	0	6,837,491	0	820,499	0
October	6,699,125	0	6,699,125	0	803,895	0
November	6,249,541	0	6,249,541	0	749,945	0
December	8,608,349	0	8,608,349	0	1,033,002	0
Annual	95,610,304	0	95,610,304	0	11,473,236	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	60494300	kg/yr
Carbon monoxide	287	kg/yr
Unburned hydrocarbons	33	kg/yr
Particulate matter	8	kg/yr
Sulfur dioxide	262113	kg/yr
Nitrogen oxides	128405	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator #2	Kohler 750 Prime Power	2,070	kW
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	198437776	\$
Levelized cost of energy	0.158	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 750 Prime Power	1,802,500	0	70,150	364,555	-301,542	1,935,663
Grid	0	0	193,005,632	0	0	193,005,632
Converter	225,000	95,462	0	0	-17,967	302,495
System	5,027,500	95,462	193,269,680	364,555	-319,509	198,437,688

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 750 Prime Power	139,431	0	5,426	28,200	-23,326	149,731
Grid	0	0	14,929,831	0	0	14,929,831
Converter	17,405	7,384	0	0	-1,390	23,400

Component System	Capital 388,899	Replacement 7,384	O&M 14,950,256	Fuel 28,200	Salvage -24,715	Total 15,350,024
------------------	-----------------	-------------------	----------------	-------------	-----------------	------------------




## Electrical

Quantity	Value	Units
Excess electricity	5225	kWh/yr
Unmet load	6192	kWh/yr
Capacity shortage	60344	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	121,784	0
Grid Purchases	95,581,120	99
Total	96,991,576	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,857,960	100
DC primary load	0	0
Total	96,857,960	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 750 Prime Power


Quantity	Value	Units
Hours of operation	181	hrs/yr
Number of starts	162	starts/yr
Operational life	83	yr
Fixed generation cost	151.69	\$/hr
Marginal generation cost	0.23	\$/kWh


Quantity	Value	Units
Electrical production	121784	kWh/yr
Mean electrical output	673	kW
Min. electrical output	518	kW
Max. electrical output	2070	kW
Fuel consumption	35696	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	351250	kWh/yr
Mean electrical efficiency	35	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	18	0	%
Hours of operation	4,377	0	hrs/yr
Energy in	1,283,450	0	kWh/yr
Energy out	1,155,104	0	kWh/yr
Losses	128,346	0	kWh/yr





## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,035	0	288,563
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,374	0	309,980
Annual	0	0	0	20,000	0	3,460,103

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,130,726	0	8,130,726	0	975,687	0
February	6,023,890	0	6,023,890	0	722,867	0
March	6,708,956	0	6,708,956	0	805,075	0
April	9,340,340	0	9,340,340	0	1,120,841	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,671,285	0	9,671,285	0	1,160,554	0
July	9,852,042	0	9,852,042	0	1,182,245	0
August	9,763,277	0	9,763,277	0	1,171,593	0

September	6,837,491	Energy Purchased (kWh)	0	6,837,491	Net Purchases (kWh)	0	820,499	Demand Charge (\$)
October	6,699,125	Sold (kWh)	0	6,699,125	Purchases (kWh)	0	803,895	Charge (\$)
November	6,249,541		0	6,249,541		0	749,945	0
December	8,607,314		0	8,607,314		0	1,032,878	0
Annual	95,581,120		0	95,581,120		0	11,469,734	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	60500952	kg/yr
Carbon monoxide	393	kg/yr
Unburned hydrocarbons	45	kg/yr
Particulate matter	11	kg/yr
Sulfur dioxide	262085	kg/yr
Nitrogen oxides	128471	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 1000 Prime Power	925	kW
Generator #2	Kohler 750 Prime Power	690	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	198614768	\$
Levelized cost of energy	0.159	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 1000 Prime Power	925,000	0	19,910	140,672	-180,596	904,986
Kohler 750 Prime Power	690,000	0	19,802	109,855	-124,522	695,135
Grid	0	0	193,156,336	0	0	193,156,336
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	5,164,589	102,637	193,420,960	250,527	-324,058	198,614,655

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 1000 Prime Power	71,553	0	1,540	10,882	-13,970	70,005
Kohler 750 Prime Power	53,375	0	1,532	8,498	-9,632	53,772
Grid	0	0	14,941,488	0	0	14,941,488
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	399,504	7,939	14,961,958	19,379	-25,067	15,363,713




## Electrical

Quantity	Value	Units
Excess electricity	2745	kWh/yr
Unmet load	8389	kWh/yr
Capacity shortage	77683	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	47,703	0
Generator	36,734	0
Grid Purchases	95,617,096	99
Total	96,990,208	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,776	100
DC primary load	0	0

Total	Consumption(kWh/yr)	96,855,776	Fraction (%)	100
-------	---------------------	------------	--------------	-----



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 1000 Prime Power


Quantity	Value	Units
Hours of operation	111	hrs/yr
Number of starts	102	starts/yr
Operational life	135	yr

Quantity	Value	Units
Fixed generation cost	76.24	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	47703	kWh/yr
Mean electrical output	430	kW
Min. electrical output	231	kW
Max. electrical output	925	kW
Fuel consumption	13774	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	135538	kWh/yr
Mean electrical efficiency	35	%



### Generator:Kohler 750 Prime Power


Quantity	Value	Units
Hours of operation	148	hrs/yr
Number of starts	134	starts/yr
Operational life	101	yr
Fixed generation cost	56.87	\$/hr
Marginal generation cost	0.23	\$/kWh
Electrical production	36734	kWh/yr
Mean electrical output	248	kW
Min. electrical output	173	kW
Max. electrical output	690	kW
Fuel consumption	10757	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	105846	kWh/yr
Mean electrical efficiency	35	%



### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.176	\$/kWh
Energy in	8596	kWh/yr
Energy out	6017	kWh/yr
Storage depletion	0	kWh/yr
Losses	2579	kWh/yr
Annual throughput	7192	kWh/yr
Expected life	25	yr



### Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW

Quantity	Inverter	132	Rectifier	0	kW	Units
Minimum output		0		0	kW	
Maximum output		750		179	kW	
Capacity factor		18		0	%	
Hours of operation		4,389		26	hrs/yr	
Energy in		1,286,067		3,196	kWh/yr	
Energy out		1,157,460		2,716	kWh/yr	
Losses		128,608		479	kWh/yr	



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,380	0	294,083
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286

December	Energy Purchased (kWh)	0	Energy Sold (kWh)	0	Net Purchases (kWh)	0	Peak Demand (kW)	19,488	Energy Charge (\$)	0	Demand Charge (\$)	311,800
<b>Resources.ReportingService_GenerateInputsReport_Month Annual</b>												

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,130,969	0	8,130,969	0	975,716	0
February	6,023,001	0	6,023,001	0	722,760	0
March	6,708,603	0	6,708,603	0	805,032	0
April	9,347,970	0	9,347,970	0	1,121,756	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,680,682	0	9,680,682	0	1,161,682	0
July	9,860,954	0	9,860,954	0	1,183,315	0
August	9,772,604	0	9,772,604	0	1,172,713	0
September	6,837,491	0	6,837,491	0	820,499	0
October	6,699,125	0	6,699,125	0	803,895	0
November	6,249,541	0	6,249,541	0	749,945	0
December	8,609,035	0	8,609,035	0	1,033,084	0
<b>Annual</b>	<b>95,617,096</b>	<b>0</b>	<b>95,617,096</b>	<b>0</b>	<b>11,474,052</b>	<b>0</b>



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	60494388	kg/yr
Carbon monoxide	270	kg/yr
Unburned hydrocarbons	31	kg/yr
Particulate matter	8	kg/yr
Sulfur dioxide	262123	kg/yr
Nitrogen oxides	128397	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Generator	Kohler 1000 Prime Power	1,850	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	20,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	198667040	\$
Levelized cost of energy	0.159	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Kohler 1000 Prime Power	1,637,500	0	56,336	318,225	-286,361	1,725,700
Grid	0	0	193,083,040	0	0	193,083,040
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	5,187,089	102,637	193,364,304	318,225	-305,301	198,666,954

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Kohler 1000 Prime Power	126,668	0	4,358	24,616	-22,151	133,491

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	14,935,819	0	0	14,935,819
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400
System	401,244	7,939	14,957,576	24,616	-23,616	15,367,759




## Electrical

Quantity	Value	Units
Excess electricity	2745	kWh/yr
Unmet load	6573	kWh/yr
Capacity shortage	63347	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Generator	107,688	0
Grid Purchases	95,595,440	99
Total	96,991,800	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,857,576	100
DC primary load	0	0
Total	96,857,576	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 1000 Prime Power

Quantity	Value	Units
Hours of operation	162	hrs/yr
Number of starts	146	starts/yr
Operational life	93	yr
Fixed generation cost	137.46	\$/hr
Marginal generation cost	0.23	\$/kWh


Quantity	Value	Units
Electrical production	107688	kWh/yr
Mean electrical output	665	kW
Min. electrical output	463	kW
Max. electrical output	1850	kW
Fuel consumption	31160	L/yr
Specific fuel consumption	0.29	L/kWh
Fuel energy input	306611	kWh/yr
Mean electrical efficiency	35	%



## Battery:GS200 flow



Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.172	\$/kWh
Energy in	7974	kWh/yr
Energy out	5582	kWh/yr
Storage depletion	0	kWh/yr
Losses	2392	kWh/yr
Annual throughput	6671	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	179	kW
Capacity factor	18	0	%
Hours of operation	4,390	22	hrs/yr
Energy in	1,286,038	2,942	kWh/yr
Energy out	1,157,434	2,501	kWh/yr
Losses	128,605	441	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,247	0	291,953
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
April	0	0	0	20,000	0	320,000
May	0	0	0	17,657	0	282,514
June	0	0	0	20,000	0	320,000
July	0	0	0	20,000	0	320,000
August	0	0	0	20,000	0	320,000
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,429	0	310,860
Annual	0	0	0	20,000	0	3,464,373

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,130,389	0	8,130,389	0	975,647	0
February	6,023,001	0	6,023,001	0	722,760	0
March	6,708,603	0	6,708,603	0	805,032	0
April	9,343,847	0	9,343,847	0	1,121,262	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,675,577	0	9,675,577	0	1,161,069	0
July	9,855,724	0	9,855,724	0	1,182,687	0
August	9,767,369	0	9,767,369	0	1,172,084	0
September	6,837,491	0	6,837,491	0	820,499	0
October	6,699,125	0	6,699,125	0	803,895	0
November	6,249,541	0	6,249,541	0	749,945	0
December	8,607,644	0	8,607,644	0	1,032,917	0
Annual	95,595,440	0	95,595,440	0	11,471,452	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	60498100	kg/yr
Carbon monoxide	343	kg/yr
Unburned hydrocarbons	39	kg/yr
Particulate matter	10	kg/yr
Sulfur dioxide	262100	kg/yr
Nitrogen oxides	128441	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	1987766640	\$
Levelized cost of energy	0.159	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	198,776,528	0	0	198,776,528
System	0	0	198,776,528	0	0	198,776,528

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	15,376,235	0	0	15,376,235
System	0	0	15,376,235	0	0	15,376,235




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	4252	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Grid Purchases	96,864,192	100
Total	96,864,192	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,553	0	296,843
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	23,104	0	369,666
May	0	0	0	17,869	0	285,902
June	0	0	0	24,046	0	384,739
July	0	0	0	24,897	0	398,345
August	0	0	0	22,671	0	362,729
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	20,069	0	321,098
Annual	0	0	0	24,897	0	3,752,539

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,209,736	0	8,209,736	0	985,168	0
February	6,110,456	0	6,110,456	0	733,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,462,522	0	9,462,522	0	1,135,503	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,816,466	0	9,816,466	0	1,177,976	0
July	10,003,713	0	10,003,713	0	1,200,446	0
August	9,901,865	0	9,901,865	0	1,188,224	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,680,090	0	8,680,090	0	1,041,611	0
Annual	96,864,192	0	96,864,192	0	11,623,705	0



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	61218168	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	265408	kg/yr
Nitrogen oxides	129798	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

Battery	GS200 flow	1	strings
Converter	System Converter	250	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	199238592	\$
Levelized cost of energy	0.159	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	198,775,856	0	0	198,775,856
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	75,000	31,821	0	0	-5,989	100,832
System	399,589	38,996	198,806,896	0	-6,962	199,238,519

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Grid	0	0	15,376,183	0	0	15,376,183
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	5,802	2,462	0	0	-463	7,800
System	30,910	3,017	15,378,584	0	-539	15,411,972




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	4252	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Grid Purchases	96,863,744	100
Total	96,863,744	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100


Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	0	kWh/yr
Energy out	502	kWh/yr
Storage depletion	600	kWh/yr
Losses	-1102	kWh/yr
Annual throughput	600	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	250	225	kW
Mean output	0	0	kW
Minimum output	0	0	kW
Maximum output	166	0	kW
Capacity factor	0	0	%
Hours of operation	3	0	hrs/yr
Energy in	502	0	kWh/yr

Quantity	Inverter	452	Rectifier	0	Units
Losses		50		0	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,553	0	296,843
February	0	0	0	17,561	0	280,978
March	0	0	0	17,425	0	278,807
April	0	0	0	23,104	0	369,666
May	0	0	0	17,869	0	285,902
June	0	0	0	24,046	0	384,739
July	0	0	0	24,897	0	398,345
August	0	0	0	22,671	0	362,729
September	0	0	0	16,926	0	270,820
October	0	0	0	14,895	0	238,325
November	0	0	0	16,518	0	264,286
December	0	0	0	20,069	0	321,098
Annual	0	0	0	24,897	0	3,752,539

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,209,284	0	8,209,284	0	985,114	0
February	6,110,456	0	6,110,456	0	723,255	0
March	6,816,916	0	6,816,916	0	818,030	0
April	9,462,522	0	9,462,522	0	1,135,503	0
May	7,805,883	0	7,805,883	0	936,706	0
June	9,816,466	0	9,816,466	0	1,177,976	0
July	10,003,713	0	10,003,713	0	1,200,446	0
August	9,901,865	0	9,901,865	0	1,188,224	0
September	6,943,139	0	6,943,139	0	833,177	0
October	6,792,313	0	6,792,313	0	815,078	0
November	6,321,105	0	6,321,105	0	758,533	0
December	8,680,090	0	8,680,090	0	1,041,611	0
Annual	96,863,744	0	96,863,744	0	11,623,651	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	61217888	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	265407	kg/yr
Nitrogen oxides	129797	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Converter	System Converter	750	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	199704592	\$
Levelized cost of energy	0.159	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Grid	0	0	196,208,096	0	0	196,208,096
Converter	225,000	95,462	0	0	-17,967	302,495
System	3,225,000	95,462	196,401,968	0	-17,967	199,704,463

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Grid	0	0	15,177,555	0	0	15,177,555
Converter	17,405	7,384	0	0	-1,390	23,400
System	249,468	7,384	15,192,552	0	-1,390	15,448,015




## Electrical

Quantity	Value	Units
Excess electricity	5225	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	3418	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Grid Purchases	95,709,088	99
Total	96,997,760	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	18	0	%

Quantity		Inverter	4,377	Rectifier	0	Units
					hrs/yr	
Energy in			1,283,450		0	kWh/yr
Energy out			1,155,104		0	kWh/yr
Losses			128,346		0	kWh/yr




## Grid

Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,553	0	296,843
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062
April	0	0	0	22,535	0	360,567
May	0	0	0	17,657	0	282,514
June	0	0	0	23,894	0	382,297
July	0	0	0	24,491	0	391,852
August	0	0	0	22,568	0	361,094
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,891	0	318,260
Annual	0	0	0	24,491	0	3,692,473

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,132,278	0	8,132,278	0	975,873	0
February	6,023,890	0	6,023,890	0	722,867	0
March	6,708,956	0	6,708,956	0	805,075	0
April	9,361,015	0	9,361,015	0	1,123,322	0
May	7,697,129	0	7,697,129	0	923,655	0
June	9,706,376	0	9,706,376	0	1,164,765	0
July	9,891,672	0	9,891,672	0	1,187,001	0
August	9,791,200	0	9,791,200	0	1,174,944	0
September	6,837,491	0	6,837,491	0	820,499	0
October	6,699,125	0	6,699,125	0	803,895	0
November	6,249,541	0	6,249,541	0	749,945	0
December	8,610,419	0	8,610,419	0	1,033,250	0
Annual	95,709,088	0	95,709,088	0	11,485,090	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	60488144	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	262243	kg/yr
Nitrogen oxides	128250	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	1,000	kW
Battery	GS200 flow	1	strings
Converter	System Converter	750	kW
Grid	Grid	25,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	200060624	\$
Levelized cost of energy	0.160	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	3,000,000	0	193,913	0	0	3,193,913
Grid	0	0	196,202,320	0	0	196,202,320
GS200 flow	324,589	7,176	31,026	0	-973	361,818
Converter	225,000	95,462	0	0	-17,967	302,495
System	3,549,589	102,637	196,427,248	0	-18,940	200,060,534

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	232,063	0	15,000	0	0	247,063
Grid	0	0	15,177,109	0	0	15,177,109
GS200 flow	25,108	555	2,400	0	-75	27,988
Converter	17,405	7,384	0	0	-1,390	23,400

Component	System	Capital	Replacement	O&M	Fuel	Salvage	Total
		274,576	7,939	15,194,508	0	-1,465	15,475,558




## Electrical

Quantity	Value	Units
Excess electricity	10	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	3418	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	1,288,675	1
Grid Purchases	95,705,352	99
Total	96,994,024	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	1000	kW
Mean output	147	kW
Mean output	3530.60	kWh/d
Capacity factor	14.71	%
Total production	1288675	kWh/yr
Minimum output	0.00	kW
Maximum output	1022.50	kW
PV penetration	1.33	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Battery:GS200 flow


Quantity	Value
String size	1
Strings in parallel	1
Batteries	1
Bus voltage	100

Quantity	Value	Units
Nominal capacity	600	kWh
Usable nominal capacity	600	kWh
Autonomy	0	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.000	\$/kWh
Energy in	5215	kWh/yr
Energy out	4152	kWh/yr
Storage depletion	600	kWh/yr
Losses	462	kWh/yr
Annual throughput	4963	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	750	675	kW
Mean output	132	0	kW
Minimum output	0	0	kW
Maximum output	750	0	kW
Capacity factor	18	0	%
Hours of operation	4,463	0	hrs/yr
Energy in	1,287,602	0	kWh/yr
Energy out	1,158,841	0	kWh/yr
Losses	128,761	0	kWh/yr



## Grid


Rate: Demand 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	0	0	0	18,553	0	296,843
February	0	0	0	16,811	0	268,978
March	0	0	0	16,941	0	271,062
April	0	0	0	22,535	0	360,567
May	0	0	0	17,657	0	282,514
June	0	0	0	23,894	0	382,297
July	0	0	0	24,491	0	391,852
August	0	0	0	22,568	0	361,094
September	0	0	0	16,176	0	258,820
October	0	0	0	14,744	0	235,900
November	0	0	0	16,518	0	264,286
December	0	0	0	19,891	0	318,260
Annual	0	0	0	24,491	0	3,692,473

Rate: Rate 1

Resources.ReportingService_GenerateInputsReport_Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
January	8,131,427	0	8,131,427	0	975,771	0
February	6,023,114	0	6,023,114	0	722,774	0
March	6,708,603	0	6,708,603	0	805,032	0

Month	Energy Purchased (kWh)	Energy Sold (kWh)	Net Purchases (kWh)	Peak Demand (kW)	Energy Charge (\$)	Demand Charge (\$)
May	9,361,015	0	9,361,015	0	923,652	0
Resources.ReportingService_GenerateInputsReport_Month	7,697,097	0	7,697,097	0		
June	9,706,373	0	9,706,373	0	1,164,765	0
July	9,891,607	0	9,891,607	0	1,186,993	0
August	9,791,049	0	9,791,049	0	1,174,926	0
September	6,836,924	0	6,836,924	0	820,431	0
October	6,698,983	0	6,698,983	0	803,878	0
November	6,248,778	0	6,248,778	0	749,853	0
December	8,610,384	0	8,610,384	0	1,033,246	0
Annual	95,705,352	0	95,705,352	0	11,484,642	0



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	60485784	kg/yr
Carbon monoxide	0	kg/yr
Unburned hydrocarbons	0	kg/yr
Particulate matter	0	kg/yr
Sulfur dioxide	262233	kg/yr
Nitrogen oxides	128245	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	15	
Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	60	strings
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	329803680	\$
Levelized cost of energy	0.263	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	67,500,000	21,519,472	14,543,448	0	-12,127,600	91,435,320
Kohler 3250 Prime Power	14,821,428	42,092,420	33,130,706	120,349,664	-3,414,479	206,979,739
GS200 flow	19,475,352	430,058	1,861,562	0	-58,308	21,708,664
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	108,996,776	67,096,720	49,535,724	120,349,664	-16,175,325	329,803,559

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	5,221,421	1,664,625	1,124,999	0	-938,123	7,072,922

Component	Prime Power	Capital	Replacement	O&M	Fuel	Salvage	Total
GS200 flow	1,506,504	33,267	144,000	0	-4,510	1,679,261	
Converter	556,952	236,300	0	0	-44,474	748,778	
System	8,431,378	5,190,225	3,831,805	9,309,574	-1,251,232	25,511,750	




## Electrical

Quantity	Value	Units
Excess electricity	35579732	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	2329	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	50,113,132	36
Wind Turbine	90,806,648	64
Total	140,919,776	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100
DC primary load	0	0
Total	96,864,160	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	34500	kW
Mean output	10366	kW
Capacity factor	30.05	%
Total production	90806648	kWh/yr
Minimum output	21.57	kW
Maximum output	34723.00	kW
Wind penetration	93.75	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	3623	hrs/yr
Number of starts	1209	starts/yr
Operational life	4	yr
Fixed generation cost	1728.30	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	50113132	kWh/yr
Mean electrical output	13832	kW
Min. electrical output	4200	kW


Quantity	Value	Units
Fuel consumption	11784276	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	115957288	kWh/yr
Mean electrical efficiency	43	%



### Battery:GS200 flow



Quantity	Value
String size	1
Strings in parallel	60
Batteries	60
Bus voltage	100

Quantity	Value	Units
Nominal capacity	36000	kWh
Usable nominal capacity	36000	kWh
Autonomy	3	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.202	\$/kWh
Energy in	15509890	kWh/yr
Energy out	10856936	kWh/yr
Storage depletion	0	kWh/yr
Losses	4652954	kWh/yr
Annual throughput	12976515	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW
Mean output	1,115	1,771	kW
Minimum output	0	0	kW
Maximum output	8,983	10,757	kW
Capacity factor	5	7	%
Hours of operation	2,201	2,998	hrs/yr
Energy in	10,856,936	18,246,954	kWh/yr
Energy out	9,771,234	15,509,890	kWh/yr
Losses	1,085,702	2,737,064	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	30928012	kg/yr
Carbon monoxide	129627	kg/yr

Pollutant	Emissions	Units
Unburned hydrocarbons	14848	kg/yr
Particulate matter	3712	kg/yr
Sulfur dioxide	63679	kg/yr
Nitrogen oxides	129627	kg/yr

---


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	5,000	kW
Wind Turbine	Siemens 2.3 MW - 108	15	
Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	60	strings
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	331481728	\$
Levelized cost of energy	0.265	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	15,000,000	0	969,563	0	0	15,969,563
Siemens 2.3 MW - 108	67,500,000	21,519,472	14,543,448	0	-12,127,600	91,435,320
Kohler 3250 Prime Power	14,821,428	36,898,980	30,917,726	111,346,072	-1,295,964	192,688,242
GS200 flow	19,475,352	430,058	1,861,562	0	-58,308	21,708,664
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	123,996,776	61,903,280	48,292,304	111,346,072	-14,056,811	331,481,621

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	1,160,316	0	75,000	0	0	1,235,316
Siemens 2.3 MW - 108	5,221,421	1,664,625	1,124,999	0	-938,123	7,072,922
Kohler 3250 Prime Power	1,146,502	2,854,298	2,391,622	8,613,106	-100,249	14,905,279
GS200 flow	1,506,504	33,267	144,000	0	-4,510	1,679,261
Converter	556,952	236,300	0	0	-44,474	748,778
System	9,591,694	4,788,490	3,735,621	8,613,106	-1,087,356	25,641,555




## Electrical

Quantity	Value	Units
Excess electricity	38246392	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	2329	kWh/yr
Renewable fraction	1	

Component	Production(kWh/yr)	Fraction (%)
PV	6,443,367	4
Generator	46,359,196	32
Wind Turbine	90,806,648	63
Total	143,609,216	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,864,160	100

Load	primary load	Consumption(kWh/yr)	0	Fraction (%)	0
Total		96,864,160			100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	5000	kW
Mean output	736	kW
Mean output	17653.00	kWh/d
Capacity factor	14.71	%
Total production	6443367	kWh/yr
Minimum output	0.00	kW
Maximum output	5112.50	kW
PV penetration	6.65	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




## Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	34500	kW
Mean output	10366	kW
Capacity factor	30.05	%
Total production	90806648	kWh/yr
Minimum output	21.57	kW
Maximum output	34723.00	kW
Wind penetration	93.75	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

---

## Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	3381	hrs/yr
Number of starts	1209	starts/yr
Operational life	4	yr
Fixed generation cost	1728.30	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	46359196	kWh/yr
Mean electrical output	13712	kW
Min. electrical output	4200	kW
Max. electrical output	16800	kW
Fuel consumption	10902671	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	107282296	kWh/yr
Mean electrical efficiency	43	%



## Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	60
Batteries	60
Bus voltage	100



Quantity	Value	Units
Nominal capacity	36000	kWh
Usable nominal capacity	36000	kWh
Autonomy	3	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.193	\$/kWh
Energy in	15720101	kWh/yr
Energy out	11004080	kWh/yr
Storage depletion	0	kWh/yr
Losses	4716021	kWh/yr
Annual throughput	13152383	kWh/yr
Expected life	25	yr



Convector

## CONVERTER

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW
Mean output	1,381	1,577	kW
Minimum output	0	0	kW
Maximum output	11,091	10,757	kW
Capacity factor	6	7	%
Hours of operation	3,031	2,856	hrs/yr
Energy in	13,443,823	16,254,018	kWh/yr
Energy out	12,099,451	13,815,923	kWh/yr
Losses	1,344,372	2,438,095	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	28614226	kg/yr
Carbon monoxide	119929	kg/yr
Unburned hydrocarbons	13737	kg/yr
Particulate matter	3434	kg/yr
Sulfur dioxide	58915	kg/yr
Nitrogen oxides	119929	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	30,000	kW
Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	80	strings
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	427814592	\$
Levelized cost of energy	0.342	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	90,000,000	0	5,817,379	0	0	95,817,379
Kohler 3250 Prime Power	14,821,428	52,738,052	42,092,368	184,886,256	-1,165,772	293,372,332
GS200 flow	25,967,136	573,408	2,482,082	0	-77,744	28,944,882
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	137,988,560	56,366,228	50,391,828	184,886,256	-1,818,454	427,814,418

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	6,961,894	0	450,000	0	0	7,411,894

Component	Prime Power	Capital	Replacement	OpEx	Fuel	Salvage	Total
GS200 flow	2,008,672	44,356	192,000	0	-6,014	2,239,014	
Converter	556,952	236,300	0	0	-44,474	748,778	
System	10,674,019	4,360,175	3,898,029	14,301,762	-140,665	33,093,320	
							193,634




## Electrical

Quantity	Value	Units
Excess electricity	155,0152	kWh/yr
Unmet load	4993	kWh/yr
Capacity shortage	27529	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	38,660,180	33
Generator	77,155,992	67
Total	115,816,176	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,859,168	100
DC primary load	0	0
Total	96,859,168	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	30000	kW
Mean output	4413	kW
Mean output	105918.00	kWh/d
Capacity factor	14.71	%
Total production	38660180	kWh/yr
Minimum output	0.00	kW
Maximum output	30675.00	kW
PV penetration	39.91	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	4603	hrs/yr
Number of starts	1922	starts/yr

Quantity	Value	3	Units
Fixed generation cost	1728.30		\$/hr
Marginal generation cost	0.18		\$/kWh
Electrical production	77155992		kWh/yr
Mean electrical output	16762		kW
Min. electrical output	4200		kW
Max. electrical output	16800		kW
Fuel consumption	18103504		L/yr
Specific fuel consumption	0.23		L/kWh
Fuel energy input	178138496		kWh/yr
Mean electrical efficiency	43		%




## Battery:GS200 flow

Quantity	Value	
String size		1
Strings in parallel		80
Batteries		80
Bus voltage		100


Quantity	Value	Units
Nominal capacity	48000	kWh
Usable nominal capacity	48000	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.227	\$/kWh
Energy in	30960144	kWh/yr


Quantity	Value	Units
Energy out	21708802	kWh/yr
Storage depletion	43801	kWh/yr
Losses	9207541	kWh/yr
Annual throughput	25946942	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW
Mean output	4,858	2,217	kW
Minimum output	0	0	kW
Maximum output	20,756	11,474	kW
Capacity factor	20	9	%
Hours of operation	4,498	4,255	hrs/yr
Energy in	47,280,436	22,849,226	kWh/yr
Energy out	42,552,432	19,421,814	kWh/yr
Losses	4,728,004	3,427,412	kWh/yr





## Emissions

Pollutant	Emissions	Units
Carbon dioxide	47512924	kg/yr
Carbon monoxide	199139	kg/yr
Unburned hydrocarbons	22810	kg/yr
Particulate matter	5703	kg/yr
Sulfur dioxide	97826	kg/yr
Nitrogen oxides	199139	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	5,000	kW
Wind Turbine	Siemens 2.3 MW - 108	15	
Generator	Kohler 3250 Prime Power	19,600	kW
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	442710560	\$
Levelized cost of energy	0.354	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	15,000,000	0	969,563	0	0	15,969,563
Siemens 2.3 MW - 108	67,500,000	21,519,472	14,543,448	0	-12,127,600	91,435,320
Kohler 3250 Prime Power	17,321,428	99,201,744	77,298,968	132,495,112	-691,588	325,625,664
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	107,021,424	123,775,984	92,811,984	132,495,112	-13,394,126	442,710,378

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
SolarWorld 320W flat plate PV Copy	\$160,316	\$0	\$75,000	\$0	\$0	\$1,235,316
Siemens 2.3 MW - 108	5,221,421	1,664,625	1,124,999	0	-938,123	7,072,922
Kohler 3250 Prime Power	1,339,888	7,673,690	5,979,414	10,249,077	-53,497	25,188,572
Converter	556,952	236,300	0	0	-44,474	748,778
System	8,278,576	9,574,614	7,179,414	10,249,077	-1,036,094	34,245,587




## Electrical

Quantity	Value	Units
Excess electricity	54552108	kWh/yr
Unmet load	7857	kWh/yr
Capacity shortage	95673	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	6,443,367	4
Generator	54,402,400	36
Wind Turbine	90,806,648	60
Total	151,652,416	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,856,296	100
DC primary load	0	0
Total	96,856,296	100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	5000	kW
Mean output	736	kW
Mean output	17653.00	kWh/d
Capacity factor	14.71	%
Total production	6443367	kWh/yr
Minimum output	0.00	kW
Maximum output	5112.50	kW
PV penetration	6.65	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh




Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	34500	kW
Mean output	10366	kW

Quantity	Value	30.05	Units
Total production	90806648	kWh/yr	
Minimum output	21.57	kW	
Maximum output	34723.00	kW	
Wind penetration	93.75	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.078	\$/kWh	

## Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	7100	hrs/yr
Number of starts	512	starts/yr
Operational life	2	yr
Fixed generation cost	2035.30	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	54402400	kWh/yr
Mean electrical output	7662	kW
Min. electrical output	4900	kW
Max. electrical output	19600	kW
Fuel consumption	12973523	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	127659480	kWh/yr
Mean electrical efficiency	43	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW

Meaning	Inverter	251	Rectifier	0	kW Units
Minimum output		0		0	kW
Maximum output		4,348		0	kW
Capacity factor		1		0	%
Hours of operation		1,972		0	hrs/yr
Energy in		2,439,241		0	kWh/yr
Energy out		2,195,318		0	kWh/yr
Losses		243,924		0	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	34049208	kg/yr
Carbon monoxide	142709	kg/yr
Unburned hydrocarbons	16347	kg/yr
Particulate matter	4087	kg/yr
Sulfur dioxide	70105	kg/yr
Nitrogen oxides	142709	kg/yr

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	30	
Generator	Kohler 3250 Prime Power	19,600	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	453,894,880	\$
Levelized cost of energy	0.363	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	135,000,000	43,038,944	29,086,896	0	-24,255,200	182,870,640
Kohler 3250 Prime Power	17,321,428	80,646,536	64,027,496	109,851,592	-822,981	271,024,071
System	152,321,424	123,685,480	93,114,384	109,851,592	-25,078,182	453,894,698

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	10,442,841	3,329,251	2,249,999	0	-1,876,246	14,145,845
Kohler 3250 Prime Power	1,339,888	6,238,363	4,952,807	8,497,502	-63,661	20,964,899
System	11,782,729	9,567,613	7,202,806	8,497,502	-1,939,907	35,110,743




## Electrical

Quantity	Value	Units
Excess electricity	129863544	kWh/yr
Unmet load	8264	kWh/yr
Capacity shortage	94180	kWh/yr
Renewable fraction	1	

Component	Production(kWh/yr)	Fraction (%)
Generator	45,106,168	20
Wind Turbine	181,613,296	80
Total	226,719,456	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,855,888	100
DC primary load	0	0
Total	96,855,888	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	69000	kW
Mean output	20732	kW
Capacity factor	30.05	%
Total production	181613296	kWh/yr
Minimum output	43.13	kW
Maximum output	69447.00	kW
Wind penetration	187.49	%
Hours of operation	8760	hrs/yr
Levelized cost	0.078	\$/kWh

### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	5881	hrs/yr
Number of starts	643	starts/yr
Operational life	3	yr
Fixed generation cost	2035.30	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	45106168	kWh/yr
Mean electrical output	7670	kW
Min. electrical output	4900	kW

Quantity	Value	Units
Fuel consumption	10756336	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	105842360	kWh/yr
Mean electrical efficiency	43	%



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	28230168	kg/yr
Carbon monoxide	118320	kg/yr
Unburned hydrocarbons	13553	kg/yr
Particulate matter	3388	kg/yr
Sulfur dioxide	58124	kg/yr
Nitrogen oxides	118320	kg/yr

# System Report

## System architecture

Generator	Kohler 3250 Prime Power	16,800	kW
Battery	GS200 flow	80	strings
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	462819808	\$
Levelized cost of energy	0.370	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	14,821,428	81,992,984	61,259,348	269,085,888	-2,964,737	424,194,911
GS200 flow	25,967,136	573,408	2,482,082	0	-77,744	28,944,882
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	47,988,564	85,621,160	63,741,424	269,085,888	-3,617,419	462,819,617

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	1,146,502	6,342,517	4,738,679	20,814,972	-229,335	32,813,335
GS200 flow	2,008,672	44,356	192,000	0	-6,014	2,239,014
Converter	556,952	236,300	0	0	-44,474	748,778

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
	\$1,126	\$1,72	\$30,679	\$14,972	\$23	\$1,801,126




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	42667	kWh/yr
Capacity shortage	95013	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	112,291,864	100
Total	112,291,864	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,821,488	100
DC primary load	0	0
Total	96,821,488	100



### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	6699	hrs/yr
Number of starts	1948	starts/yr
Operational life	2	yr
Fixed generation cost	1728.30	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	112291864	kWh/yr
Mean electrical output	16762	kW
Min. electrical output	4200	kW
Max. electrical output	16800	kW
Fuel consumption	26348078	L/yr
Specific fuel consumption	0.23	L/kWh
Fuel energy input	259265120	kWh/yr
Mean electrical efficiency	43	%



### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	80
Batteries	80
Bus voltage	100



Quantity	Value	Units
Nominal capacity	48000	kWh
Usable nominal capacity	48000	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.308	\$/kWh
Energy in	28359858	kWh/yr
Energy out	19882438	kWh/yr
Storage depletion	36487	kWh/yr
Losses	8440933	kWh/yr
Annual throughput	23764098	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW
Mean output	2,043	3,237	kW
Minimum output	0	0	kW
Maximum output	10,874	12,988	kW
Capacity factor	9	13	%

Quantity	Inverter	Rectifier	Units
Hours of operation	2,471	6,211	hrs/yr
Energy in	19,882,438	33,364,564	kWh/yr
Energy out	17,894,204	28,359,858	kWh/yr
Losses	1,988,234	5,004,706	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	69150936	kg/yr
Carbon monoxide	289829	kg/yr
Unburned hydrocarbons	33199	kg/yr
Particulate matter	8300	kg/yr
Sulfur dioxide	142377	kg/yr
Nitrogen oxides	289829	kg/yr

# System Report

## System architecture

Generator	Kohler 3250 Prime Power	22,400	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary


Total net present cost	507364928	\$
Levelized cost of energy	0.405	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	19,821,428	143,797,872	110,637,144	235,007,568	-1,899,339	507,364,673
System	19,821,428	143,797,872	110,637,144	235,007,568	-1,899,339	507,364,673

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	1,533,274	11,123,395	8,558,268	18,178,864	-146,922	39,246,879
System	1,533,274	11,123,395	8,558,268	18,178,864	-146,922	39,246,879




## Electrical

Quantity	Value	Units
Excess electricity	174601	kWh/yr
Unmet load	5507	kWh/yr
Capacity shortage	52841	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	97,033,256	100
Total	97,033,256	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,858,648	100
DC primary load	0	0
Total	96,858,648	100



### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	8760	hrs/yr
Number of starts	1	starts/yr
Operational life	2	yr
Fixed generation cost	2342.20	\$/hr
Marginal generation cost	0.18	\$/kWh
Electrical production	97033256	kWh/yr
Mean electrical output	11077	kW
Min. electrical output	5600	kW
Max. electrical output	22400	kW
Fuel consumption	23011234	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	226430576	kWh/yr
Mean electrical efficiency	43	%



### Emissions

Pollutant	Emissions	Units
Carbon dioxide	60393336	kg/yr
Carbon monoxide	253124	kg/yr
Unburned hydrocarbons	28994	kg/yr
Particulate matter	7249	kg/yr
Sulfur dioxide	124345	kg/yr
Nitrogen oxides	253124	kg/yr

---


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	5,000	kW
Generator	Kohler 3250 Prime Power	22,400	kW
Converter	System Converter	24,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	520071488	\$
Levelized cost of energy	0.415	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	15,000,000	0	969,563	0	0	15,969,563
Kohler 3250 Prime Power	19,821,428	143,797,872	110,637,144	222,064,784	-1,899,339	494,421,889
Converter	7,200,000	3,054,769	0	0	-574,938	9,679,831
System	42,021,428	146,852,640	111,606,664	222,064,784	-2,474,277	520,071,239

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	1,160,316	0	75,000	0	0	1,235,316
Kohler 3250 Prime Power	1,533,274	11,123,395	8,558,268	17,177,684	-146,922	38,245,699
Converter	556,952	236,300	0	0	-44,474	748,778

Component	Capital	Replacement	Operating	Capital	Fuel	Salvage	Total
	542	3,015	3,264		77,684	26	29,789




## Electrical

Quantity	Value	Units
Excess electricity	547357	kWh/yr
Unmet load	1351	kWh/yr
Capacity shortage	28736	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	6,443,367	7
Generator	91,574,000	93
Total	98,017,368	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	96,862,808	100
DC primary load	0	0
Total	96,862,808	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	5000	kW
Mean output	736	kW
Mean output	17653.00	kWh/d
Capacity factor	14.71	%
Total production	6443367	kWh/yr
Minimum output	0.00	kW
Maximum output	5112.50	kW
PV penetration	6.65	%
Hours of operation	4377	hrs/yr
Levelized cost	0.192	\$/kWh



Generator:Kohler 3250 Prime Power



Quantity	Value	Units
Hours of operation	8760	hrs/yr
Number of starts	1	starts/yr

Quantity	Value	2	Units
Fixed generation cost	2342.20		\$/hr
Marginal generation cost	0.18		\$/kWh
Electrical production	91574000		kWh/yr
Mean electrical output	10454		kW
Min. electrical output	5600		kW
Max. electrical output	22400		kW
Fuel consumption	21743916		L/yr
Specific fuel consumption	0.24		L/kWh
Fuel energy input	213960160		kWh/yr
Mean electrical efficiency	43		%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	24,000	21,600	kW
Mean output	624	0	kW
Minimum output	0	0	kW
Maximum output	4,601	0	kW
Capacity factor	3	0	%
Hours of operation	4,311	0	hrs/yr
Energy in	6,070,614	0	kWh/yr
Energy out	5,463,549	0	kWh/yr
Losses	607,065	0	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	57067240	kg/yr
Carbon monoxide	239183	kg/yr
Unburned hydrocarbons	27397	kg/yr
Particulate matter	6849	kg/yr
Sulfur dioxide	117497	kg/yr
Nitrogen oxides	239183	kg/yr


## Appendix D – AUTEC Scenarios

### System Report

#### System architecture

Wind Turbine	Siemens 2.3 MW - 108	2	
Generator	Kohler 3250 Prime Power	3,250	kW
Battery	GS200 flow	12	strings
Converter	System Converter	2,000	kW
Dispatch Strategy	Cycle Charging		

#### Cost summary



#### Cost Summary

Total net present cost	47442712	\$
Levelized cost of energy	0.261	\$/kWh

#### Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	9,000,000	2,869,263	1,939,126	0	-1,617,013	12,191,376
Kohler 3250 Prime Power	2,346,591	5,707,372	426,261	21,940,282	-317,611	30,102,895
GS200 flow	3,895,070	86,018	372,312	0	-11,663	4,341,737
Converter	600,000	254,564	0	0	-47,912	806,652
System	15,841,661	8,917,217	2,737,699	21,940,282	-1,994,198	47,442,661

#### Annualized Costs


Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	696,189	221,950	150,000	0	-125,083	943,056

# System Report

## System architecture

Wind Turbine	Siemens 2.3 MW - 108	2	
Generator	Kohler 3250 Prime Power	3,250	kW
Battery	GS200 flow	12	strings
Converter	System Converter	2,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	47442712	\$
Levelized cost of energy	0.261	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	9,000,000	2,869,263	1,939,126	0	-1,617,013	12,191,376
Kohler 3250 Prime Power	2,346,591	5,707,372	426,261	21,940,282	-317,611	30,102,895
GS200 flow	3,895,070	86,018	372,312	0	-11,663	4,341,737
Converter	600,000	254,564	0	0	-47,912	806,652
System	15,841,661	8,917,217	2,737,699	21,940,282	-1,994,198	47,442,661

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Siemens 2.3 MW - 108	696,189	221,950	150,000	0	-125,083	943,056

Component	Prime Power	Capital	Replacement	O&M	Fuel	Salvage	Total
GS200 flow		301,301	6,654	28,800	0	-902	335,853
Converter		46,413	19,692	0	0	-3,706	62,399
System		1,225,422	689,786	211,773	1,697,177	-154,260	3,669,898




## Electrical

Quantity	Value	Units
Excess electricity	4217891	kWh/yr
Unmet load	488	kWh/yr
Capacity shortage	3675	kWh/yr
Renewable fraction	0	

Component	Production(kWh/yr)	Fraction (%)
Generator	7,356,061	36
Wind Turbine	13,081,490	64
Total	20,437,550	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,060,971	100
DC primary load	0	0
Total	14,060,971	100




### Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	4600	kW
Mean output	1493	kW
Capacity factor	32.46	%
Total production	13081490	kWh/yr
Minimum output	3.12	kW
Maximum output	4629.60	kW
Wind penetration	93.03	%
Hours of operation	8760	hrs/yr
Levelized cost	0.072	\$/kWh

### Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	3261	hrs/yr
Number of starts	911	starts/yr
Operational life	5	yr
Fixed generation cost	235.85	\$/hr
Marginal generation cost	0.20	\$/kWh
Electrical production	7356061	kWh/yr
Mean electrical output	2256	kW
Min. electrical output	813	kW


Quantity	Value	Units
Fuel consumption	1697178	L/yr
Specific fuel consumption	0.23	L/kWh
Fuel energy input	16700232	kWh/yr
Mean electrical efficiency	44	%



### Battery:GS200 flow



Quantity	Value
String size	1
Strings in parallel	12
Batteries	12
Bus voltage	100

Quantity	Value	Units
Nominal capacity	7200	kWh
Usable nominal capacity	7200	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.159	\$/kWh
Energy in	3953248	kWh/yr
Energy out	2769061	kWh/yr
Storage depletion	2134	kWh/yr
Losses	1182053	kWh/yr
Annual throughput	3309657	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	2,000	1,800	kW
Mean output	284	451	kW
Minimum output	0	0	kW
Maximum output	1,988	2,000	kW
Capacity factor	14	23	%
Hours of operation	3,651	3,335	hrs/yr
Energy in	2,769,061	4,650,904	kWh/yr
Energy out	2,492,151	3,953,248	kWh/yr
Losses	276,910	697,656	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	4454270	kg/yr
Carbon monoxide	18669	kg/yr

Pollutant	Emissions	Units
Unburned hydrocarbons	2138	kg/yr
Particulate matter	535	kg/yr
Sulfur dioxide	9171	kg/yr
Nitrogen oxides	18669	kg/yr

---


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	2,000	kW
Wind Turbine	Siemens 2.3 MW - 108	2	
Generator	Kohler 3250 Prime Power	3,250	kW
Battery	GS200 flow	15	strings
Converter	System Converter	3,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary


Total net present cost	48557108	\$
Levelized cost of energy	0.267	\$/kWh

## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	6,000,000	0	387,825	0	0	6,387,825
Siemens 2.3 MW - 108	9,000,000	2,869,263	1,939,126	0	-1,617,013	12,191,376
Kohler 3250 Prime Power	2,346,591	4,600,629	362,995	16,239,458	-208,930	23,340,743
GS200 flow	4,868,838	107,521	465,390	0	-14,578	5,427,171
Converter	900,000	381,846	0	0	-71,867	1,209,979
System	23,115,428	7,959,259	3,155,337	16,239,458	-1,912,389	48,557,093

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	464,126	0	30,000	0	0	494,126
Siemens 2.3 MW - 108	696,189	221,950	150,000	0	-125,083	943,056
Kohler 3250 Prime Power	181,519	355,879	28,079	1,256,193	-16,162	1,805,508
GS200 flow	376,626	8,317	36,000	0	-1,128	419,816
Converter	69,619	29,537	0	0	-5,559	93,597
System	1,788,080	615,684	244,079	1,256,193	-147,932	3,756,104




## Electrical

Quantity	Value	Units
Excess electricity	5480098	kWh/yr
Unmet load	157	kWh/yr
Capacity shortage	2506	kWh/yr
Renewable fraction	1	

Component	Production(kWh/yr)	Fraction (%)
PV	3,250,128	15
Generator	5,318,757	25
Wind Turbine	13,081,490	60
Total	21,650,376	100


Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,061,302	100
DC primary load	0	0

Load	Consumption(kWh/yr)	Fraction (%)
Total	14,061,302	100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	2000	kW
Mean output	371	kW
Mean output	8904.50	kWh/d
Capacity factor	18.55	%
Total production	3250128	kWh/yr
Minimum output	0.00	kW
Maximum output	1996.60	kW
PV penetration	23.11	%
Hours of operation	4370	hrs/yr
Levelized cost	0.152	\$/kWh




Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units

Quantity	Value	Units
Total rated capacity	4600	kW
Mean output	1493	kW
Capacity factor	32.46	%
Total production	13081490	kWh/yr
Minimum output	3.12	kW
Maximum output	4629.60	kW
Wind penetration	93.03	%
Hours of operation	8760	hrs/yr
Levelized cost	0.072	\$/kWh

### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	2777	hrs/yr
Number of starts	532	starts/yr
Operational life	5	yr
Fixed generation cost	235.85	\$/hr
Marginal generation cost	0.20	\$/kWh
Electrical production	5318757	kWh/yr
Mean electrical output	1915	kW
Min. electrical output	813	kW
Max. electrical output	3250	kW
Fuel consumption	1256194	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	12360949	kWh/yr
Mean electrical efficiency	43	%



### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	15
Batteries	15
Bus voltage	100



Quantity	Value	Units
Nominal capacity	9000	kWh
Usable nominal capacity	9000	kWh
Autonomy	6	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.111	\$/kWh
Energy in	4010070	kWh/yr
Energy out	2808839	kWh/yr
Storage depletion	2134	kWh/yr
Losses	1199097	kWh/yr
Annual throughput	3357196	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	3,000	2,700	kW
Mean output	408	330	kW
Minimum output	0	0	kW
Maximum output	2,691	2,689	kW
Capacity factor	14	11	%

Quantity	Inverter	Rectifier	Units
Hours of operation	4,446	2,426	Hrs/yr
Energy in	3,975,608	3,401,441	kWh/yr
Energy out	3,578,049	2,891,229	kWh/yr
Losses	397,560	510,212	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	3296900	kg/yr
Carbon monoxide	13818	kg/yr
Unburned hydrocarbons	1583	kg/yr
Particulate matter	396	kg/yr
Sulfur dioxide	6788	kg/yr
Nitrogen oxides	13818	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	4,000	kW
Generator	Kohler 3250 Prime Power	3,250	kW
Battery	GS200 flow	10	strings
Converter	System Converter	3,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	58783660	\$
Levelized cost of energy	0.323	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	12,000,000	0	775,651	0	0	12,775,651
Kohler 3250 Prime Power	2,346,591	7,159,266	529,525	31,284,102	-139,599	41,179,885
GS200 flow	3,245,892	71,683	310,260	0	-9,719	3,618,116
Converter	900,000	381,846	0	0	-71,867	1,209,979
System	18,492,482	7,612,796	1,615,436	31,284,102	-221,185	58,783,631

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	928,253	0	60,000	0	0	988,253

Component	Prime Power	Capital	Replacement	O&M	Fuel	Salvage	Total
GS200 flow		251,084	5,545	24,000	0	-752	279,877
Converter		69,619	29,537	0	0	-5,559	93,597
System		1,430,475	588,883	124,961	2,419,962	-17,110	4,547,171




## Electrical

Quantity	Value	Units
Excess electricity	604374	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	6,500,257	38
Generator	10,696,306	62
Total	17,196,562	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,061,459	100
DC primary load	0	0
Total	14,061,459	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	4000	kW
Mean output	742	kW
Mean output	17809.00	kWh/d
Capacity factor	18.55	%
Total production	6500257	kWh/yr
Minimum output	0.00	kW
Maximum output	3993.10	kW
PV penetration	46.23	%
Hours of operation	4370	hrs/yr
Levelized cost	0.152	\$/kWh



Generator:Kohler 3250 Prime Power

Quantity	Value	Units
Hours of operation	4051	hrs/yr
Number of starts	1758	starts/yr

Quantity	Value	4	Units
Fixed generation cost	235.85	\$/hr	
Marginal generation cost	0.20	\$/kWh	
Electrical production	10696306	kWh/yr	
Mean electrical output	2640	kW	
Min. electrical output	813	kW	
Max. electrical output	3250	kW	
Fuel consumption	2419964	L/yr	
Specific fuel consumption	0.23	L/kWh	
Fuel energy input	23812448	kWh/yr	
Mean electrical efficiency	45	%	




### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	10
Batteries	10
Bus voltage	100


Quantity	Value	Units
Nominal capacity	6000	kWh
Usable nominal capacity	6000	kWh
Autonomy	4	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.241	\$/kWh
Energy in	4366512	kWh/yr


Quantity	Value	Units
Energy out	3060535	kWh/yr
Storage depletion	4746	kWh/yr
Losses	1301230	kWh/yr
Annual throughput	3658050	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	3,000	2,700	kW
Mean output	756	316	kW
Minimum output	0	0	kW
Maximum output	2,754	1,793	kW
Capacity factor	25	11	%
Hours of operation	5,168	2,482	hrs/yr
Energy in	7,359,752	3,258,656	kWh/yr
Energy out	6,623,762	2,769,838	kWh/yr
Losses	735,990	488,819	kWh/yr





## Emissions

Pollutant	Emissions	Units
Carbon dioxide	6351233	kg/yr
Carbon monoxide	26620	kg/yr
Unburned hydrocarbons	3049	kg/yr
Particulate matter	762	kg/yr
Sulfur dioxide	13077	kg/yr
Nitrogen oxides	26620	kg/yr


HOMER Energy, LLC © 2016

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	2,000	kW
Wind Turbine	Siemens 2.3 MW - 108	2	
Generator	Kohler 3250 Prime Power	3,250	kW
Converter	System Converter	1,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	60113544	\$
Levelized cost of energy	0.331	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	6,000,000	0	387,825	0	0	6,387,825
Siemens 2.3 MW - 108	9,000,000	2,869,263	1,939,126	0	-1,617,013	12,191,376
Kohler 3250 Prime Power	2,346,591	12,285,225	860,757	25,652,476	-14,054	41,130,995
Converter	300,000	127,282	0	0	-23,956	403,326
System	17,646,590	15,281,769	3,187,708	25,652,476	-1,655,023	60,113,520

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	464,126	0	30,000	0	0	494,126

Component	MW - 108	Capital	Replacement	OpEx	Fuel	Salvage	Total
Kohler 3250 Prime Power		181,519	950,316	66,583	1,984,331	-1,087	3,181,662
Converter		23,206	9,846	0	0	-1,853	31,199
System		1,365,041	1,182,112	246,583	1,984,331	-128,023	4,650,044




## Electrical

Quantity	Value	Units
Excess electricity	9828963	kWh/yr
Unmet load	716	kWh/yr
Capacity shortage	6247	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	3,250,128	14
Generator	7,640,236	32
Wind Turbine	13,081,490	55
Total	23,971,854	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,060,743	100
DC primary load	0	0
Total	14,060,743	100



PV:Solar World 320W flat plate PV Copy

Quantity	Value	Units
Rated capacity	2000	kW
Mean output	371	kW
Mean output	8904.50	kWh/d
Capacity factor	18.55	%
Total production	3250128	kWh/yr
Minimum output	0.00	kW
Maximum output	1996.60	kW
PV penetration	23.11	%
Hours of operation	4370	hrs/yr
Levelized cost	0.152	\$/kWh




Wind Turbine:Siemens 2.3 MW - 108

Quantity	Value	Units
Total rated capacity	4600	kW
Mean output	1493	kW

Quantity	Value	32.46	Units
Total production	13081490	kWh/yr	
Minimum output	3.12	kW	
Maximum output	4629.60	kW	
Wind penetration	93.03	%	
Hours of operation	8760	hrs/yr	
Levelized cost	0.072	\$/kWh	

## Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	6585	hrs/yr
Number of starts	550	starts/yr
Operational life	2	yr
Fixed generation cost	235.85	\$/hr
Marginal generation cost	0.20	\$/kWh
Electrical production	7640236	kWh/yr
Mean electrical output	1160	kW
Min. electrical output	813	kW
Max. electrical output	3250	kW
Fuel consumption	1984332	L/yr
Specific fuel consumption	0.26	L/kWh
Fuel energy input	19525830	kWh/yr
Mean electrical efficiency	39	%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	1,000	900	kW

Meaning	Inverter	84	Rectifier	0	kW Units
Minimum output		0		0	kW
Maximum output		1,000		0	kW
Capacity factor		8		0	%
Hours of operation		1,813		0	hrs/yr
Energy in		821,853		0	kWh/yr
Energy out		739,666		0	kWh/yr
Losses		82,186		0	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	5207910	kg/yr
Carbon monoxide	21828	kg/yr
Unburned hydrocarbons	2500	kg/yr
Particulate matter	625	kg/yr
Sulfur dioxide	10723	kg/yr
Nitrogen oxides	21828	kg/yr

# System Report

## System architecture

Generator	Kohler 3250 Prime Power	3,250	kW
Battery	GS200 flow	6	strings
Converter	System Converter	1,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



### Cost Summary

Total net present cost	65802344	\$
Levelized cost of energy	0.362	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	2,346,591	15,398,611	1,024,020	44,989,192	-530,288	63,228,126
GS200 flow	1,947,535	43,013	186,156	0	-5,832	2,170,872
Converter	300,000	127,282	0	0	-23,956	403,326
System	4,594,126	15,568,906	1,210,175	44,989,192	-560,076	65,802,323

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Kohler 3250 Prime Power	181,519	1,191,150	79,212	3,480,111	-41,020	4,890,972
GS200 flow	150,650	3,327	14,400	0	-451	167,926
Converter	23,206	9,846	0	0	-1,853	31,199

Component	Capital	Replacement	Operating	Fuel	Salvage	Total
	376	323	612	1,480,111	824	1090,098




## Electrical

Quantity	Value	Units
Excess electricity	0	kWh/yr
Unmet load	0	kWh/yr
Capacity shortage	0	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
Generator	14,686,122	100
Total	14,686,122	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,061,459	100
DC primary load	0	0
Total	14,061,459	100



### Generator:Kohler 3250 Prime Power


Quantity	Value	Units
Hours of operation	7834	hrs/yr
Number of starts	694	starts/yr
Operational life	2	yr
Fixed generation cost	235.85	\$/hr
Marginal generation cost	0.20	\$/kWh
Electrical production	14686122	kWh/yr
Mean electrical output	1875	kW
Min. electrical output	813	kW
Max. electrical output	3250	kW
Fuel consumption	3480113	L/yr
Specific fuel consumption	0.24	L/kWh
Fuel energy input	34244312	kWh/yr
Mean electrical efficiency	43	%



### Battery:GS200 flow

Quantity	Value
String size	1
Strings in parallel	6
Batteries	6
Bus voltage	100



Quantity	Value	Units
Nominal capacity	3600	kWh
Usable nominal capacity	3600	kWh
Autonomy	2	hr
Lifetime throughput	0	
Battery wear cost	0.000	\$/kWh
Average energy cost	0.334	\$/kWh
Energy in	1143102	kWh/yr
Energy out	800171	kWh/yr
Storage depletion	0	kWh/yr
Losses	342931	kWh/yr
Annual throughput	956387	kWh/yr
Expected life	25	yr



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	1,000	900	kW
Mean output	82	130	kW
Minimum output	0	0	kW
Maximum output	904	1,000	kW
Capacity factor	8	13	%

Quantity	Hours of operation	Inverter	971	Rectifier	1,411	Units
Energy in			800,171		1,344,841	kWh/yr
Energy out			720,153		1,143,102	kWh/yr
Losses			80,017		201,739	kWh/yr



## Emissions


Pollutant	Emissions	Units
Carbon dioxide	9133608	kg/yr
Carbon monoxide	38281	kg/yr
Unburned hydrocarbons	4385	kg/yr
Particulate matter	1096	kg/yr
Sulfur dioxide	18805	kg/yr
Nitrogen oxides	38281	kg/yr

# System Report

## System architecture

PV	Solar World 320W flat plate PV Copy	3,000	kW
Generator	Kohler 3250 Prime Power	3,250	kW
Converter	System Converter	2,000	kW
Dispatch Strategy	Cycle Charging		

## Cost summary



## Cost Summary

Total net present cost	65865580	\$
Levelized cost of energy	0.362	\$/kWh


## Net Present Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	9,000,000	0	581,738	0	0	9,581,738
Kohler 3250 Prime Power	2,346,591	15,872,167	1,077,743	36,325,876	-145,221	55,477,156
Converter	600,000	254,564	0	0	-47,912	806,652
System	11,946,591	16,126,731	1,659,481	36,325,876	-193,132	65,865,547

## Annualized Costs

Component	Capital	Replacement	O&M	Fuel	Salvage	Total
Solar World 320W flat plate PV Copy	696,189	0	45,000	0	0	741,189
Kohler 3250 Prime Power	181,519	1,227,782	83,368	2,809,966	-11,233	4,291,402
Converter	46,413	19,692	0	0	-3,706	62,399

Component	Capital	Replacement	Operating	Fuel	Salvage	Total
	21	173	368	109,966	104	104,988




## Electrical

Quantity	Value	Units
Excess electricity	168,3896	kWh/yr
Unmet load	1122	kWh/yr
Capacity shortage	11288	kWh/yr
Renewable fraction	0	


Component	Production(kWh/yr)	Fraction (%)
PV	4,875,192	30
Generator	11,192,983	70
Total	16,068,174	100

Load	Consumption(kWh/yr)	Fraction (%)
AC primary load	14,060,337	100
DC primary load	0	0
Total	14,060,337	100



PV:Solar World 320W flat plate PV Copy


Quantity	Value	Units
Rated capacity	3000	kW
Mean output	557	kW
Mean output	13357.00	kWh/d
Capacity factor	18.55	%
Total production	4875192	kWh/yr
Minimum output	0.00	kW
Maximum output	2994.80	kW
PV penetration	34.67	%
Hours of operation	4370	hrs/yr
Levelized cost	0.152	\$/kWh



Generator:Kohler 3250 Prime Power



Quantity	Value	Units
Hours of operation	8245	hrs/yr
Number of starts	191	starts/yr

Quantity	Value	2	Units
Fixed generation cost	235.85		\$/hr
Marginal generation cost	0.20		\$/kWh
Electrical production	11192983		kWh/yr
Mean electrical output	1358		kW
Min. electrical output	813		kW
Max. electrical output	3250		kW
Fuel consumption	2809968		L/yr
Specific fuel consumption	0.25		L/kWh
Fuel energy input	27650084		kWh/yr
Mean electrical efficiency	40		%



## Converter

Quantity	Inverter	Rectifier	Units
Capacity	2,000	1,800	kW
Mean output	333	0	kW
Minimum output	0	0	kW
Maximum output	2,000	0	kW
Capacity factor	17	0	%
Hours of operation	4,247	0	hrs/yr
Energy in	3,241,253	0	kWh/yr
Energy out	2,917,129	0	kWh/yr
Losses	324,124	0	kWh/yr



## Emissions

Pollutant	Emissions	Units
Carbon dioxide	7374803	kg/yr
Carbon monoxide	30910	kg/yr
Unburned hydrocarbons	3541	kg/yr
Particulate matter	885	kg/yr
Sulfur dioxide	15184	kg/yr
Nitrogen oxides	30910	kg/yr