



# Dynamic Approach to Dependency Analysis in Human Reliability Analysis: Application in a Stream Generator Tube Rupture Scenario

July 2022

*Changing the World's Energy Future*

Jeeyea Ahn, Yunyeong Heo , Seung Jun Lee, Jooyoung Park, Ronald Laurids  
Boring PhD



*INL is a U.S. Department of Energy National Laboratory operated by Battelle Energy Alliance, LLC*

#### **DISCLAIMER**

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

# **Dynamic Approach to Dependency Analysis in Human Reliability Analysis: Application in a Stream Generator Tube Rupture Scenario**

**Jeeyea Ahn, Yunyeong Heo , Seung Jun Lee, Jooyoung Park, Ronald Laurids  
Boring PhD**

**July 2022**

**Idaho National Laboratory  
Idaho Falls, Idaho 83415**

**<http://www.inl.gov>**

**Prepared for the  
U.S. Department of Energy  
Under DOE Idaho Operations Office  
Contract DE-AC07-05ID14517**

# **Dynamic Approach to Dependency Analysis in Human Reliability Analysis: Application in a Stream Generator Tube Rupture Scenario**

*Jeeyea Ahn<sup>1</sup>, Yunyeong Heo<sup>1</sup>, Seung Jun Lee<sup>1</sup>,  
Ronald L. Boring<sup>2</sup>, Jooyoung Park<sup>2\*</sup>*

*<sup>1</sup> Ulsan National Institute of Science and Technology  
Ulsan, 44919, Republic of Korea*

*<sup>2</sup> Idaho National Laboratory  
Idaho Falls, ID 83415, USA*

*\* Corresponding Author*

## ABSTRACT

Dependency analysis in human reliability analysis (HRA) is a method of adjusting the failure probability of a given action by considering the impact of the action preceding it. It plays a role in reasonably accounting for human actions in the context of probabilistic safety assessments (PSAs), preventing PSA results from being estimated too optimistically based on the HRA results. Nevertheless, the existing dependency methods present a couple of challenges in that the quantification approaches rarely explain the adjustment of human error probabilities (HEPs). For this reason, the authors' previous research has pointed out challenges of the existing dependency approaches and conceptually, theoretically proposed a performance shaping factor (PSF)-based dynamic dependency analysis method for HRA in order to complement the existing dependency methods. The current paper explores the latest version of the method and guidance for applying it to a steam generator tube rupture (SGTR) scenario.

**Keywords:** dependency assessment, human reliability analysis, human failure event, performance shaping factor, probabilistic safety assessment

## INTRODUCTION

This paper is follow-up research to conceptually, theoretically propose a performance shaping factor (PSF)-based dynamic dependency analysis method for human reliability analysis (HRA) to complement the existing dependency methods (Park & Boring, 2021). A PSF refers to any factor that influences human performance in HRA (Swain & Guttman, 1983). PSFs have been used to highlight human error contributors and adjust human error probabilities (HEPs) within HRA. This paper explores the latest version of the method along with the steps for applying it to an example steam generator tube rupture (SGTR) scenario. A set of procedures for mitigating SGTR scenarios, an SGTR event tree, and the relevant HRA information—all of which were assumed based on practical experience—were used to implement the method.

## PSF-BASED DYNAMIC DEPENDENCY ANALYSIS METHOD

The PSF-based dependency method suggested in this study defines dependence differently from existing dependency methods. In this study, the dependence effect is defined as the PSFs for a given human action affecting PSFs for subsequent human actions and indirectly contributing to the failure of those actions. A human action may promote the failure of subsequent human actions, regardless of if whether the initial

human action is successful. In other words, this method accounts for every possible relationship among the human actions modeled for a given scenario. Further details on this definition, along with the analytical process behind this method are thoroughly explored in the authors’ previous work (Park & Boring, 2021).

The method consists of three steps: (1) identification of the human failure event (HFE) sequence in light of the initiating event, (2) screening analysis for dependency candidates, and (3) application of mathematical models.

### Step #1: Identification of the HFE Sequence in Light of the Initiating Event

In this step, HFE sequences are identified via event trees and procedures. Event trees are used to determine where HFEs occur in the model, and to visually identify HFE sequences, which are in turn verified by the procedures. In addition, this step additionally finds HFE combinations that are missed by existing dependency methods that focus solely on human failure combinations from cut-sets.

### Step #2: Screening Analysis for Dependency Candidates

In this step, five dependency elements are used to determine whether dependencies between a given pair of HFEs should be evaluated. Table 1 shows the evaluation criteria for each of the five elements. If at least two elements in the table generate a “Yes” response, we assume the existence of a dependency between the HFEs.

Table 1. Dependency elements and their evaluation criteria

Dependency elements	Evaluation criteria
Crew	Is the crew for a given human action the same as that of the other human action? (Yes/No)
Cognitive	Are the cues for the given human action the same as those of the other human action? (Yes/No)
Cue demand	Are the cues for both human actions included in the same procedure steps? (Yes/No)
Timing	Does the time gap between the two human actions (e.g., the end of the previous action and the beginning of the next) range from a few seconds to a few minutes? (Yes/No)
Location	Is the location of the given human action the same as that of the other human action? (Yes/No)

### Step #3: Application of Mathematical Models

This step entails the application of mathematical models developed for the Human Unimodel for Nuclear Technology to Enhance Reliability (HUNTER) software (R. Boring et al., 2021). In the HUNTER project, the PSF concept was extended from static to dynamic HRA, based on the eight PSFs used in the Standardized Plant

Analysis Risk-HRA (SPAR-H) method (Gertman, Blackman, Marble, Byers, & Smith, 2005). Figure 1 shows how to conceptually extend the PSF concept from static to dynamic HRA. In static HRA, PSFs have been used for quantifying a task only. On the other hand, in extending them to dynamic HRA, it is assumed that PSFs for a given task affect those in other tasks performed after the task (e.g., subsequent tasks). Two influences are suggested in the concept, the PSF's influence on that same PSF in subsequent tasks, and the PSF's influence on different PSFs in subsequent tasks. An example of the first type of influence is that the stress PSF in Task #1 affects the stress PSF in Task #2, whereas the second type of influence is exemplified by the fact that the complexity PSF in Task #1 influences the available time PSF in Task #2. The current study mainly focuses on the first type of influence. Yet, the second one is not much investigated in this study.




Figure 1. Extension of the PSF concept from static to dynamic HRA

Two of the eight SPAR-H PSFs (i.e., stress/stressors and fitness-for-duty) are applicable to the first type of influence featured in the extended PSF concept, whereas the other PSFs are dominant in each task. For example, the stress PSF for a given task influences that for the next task, while task complexity is totally different depending on the tasks. Therefore, this study only includes mathematical models for the aforementioned stress/stressors and fitness-for-duty SPAR-H PSFs, while the existing static approach is employed for the remaining six PSFs.

Stress is defined as the undesirable conditions and circumstances that impede operators from easily completing a task, and can include mental stress, excessive workload, or physical stress (e.g., that imposed by various environmental factors). For modeling the PSF of stress/stressors, PSF lag and linger models (Park, Boring, &

Kim, 2019) were used. PSF lag indicates that the PSF's effect on performance does not immediately materialize in a psychological or physical fashion, whereas PSF linger means that the influence of PSFs for an initial human action continue to residually affect subsequent actions. The authors' previous research conceptually suggested PSF lag and linger effects as an option for treating dependencies between operator actions in a dynamic context (Boring, 2015), thus entailing the development of mathematical models for PSF lag and linger effects (Park et al., 2019), based on experimental results in the field of biology.

Fitness-for-duty PSF refers to whether or not the individual performing a given task is physically and mentally fit to perform said task at that particular moment. Factors that may affect fitness include fatigue, sickness, drug use, overconfidence, personal problems, distractions, etc. This study developed an equation representing the relative fatigue values (Spencer, Robertson, & Folkard, 2006). Figure 2 shows the relative fatigue index over the number of hours on duty, with the curve-fitted equation given in cubic form. The R-square value of the equation (i.e., 0.69) is statistically adequate. This study employs this equation to imitate the trend of the multiplier value for the fitness-for-duty PSF over time. If a shift is changed, the multiplier value is reset to the value at x=0, while the maximum value is assumed to be 5, in accordance with the existing SPAR-H method.




Figure 2. Relative fatigue index over number of hours on duty



# APPLICATION IN A STEAM GENERATOR TUBE RUPTURE SCENARIO

## Step #1: Identification of the HFE Sequence in Light of the Initiating Event




Figure 3. General event tree for steam generator tube rupture accident

Since the analyzed reference event (i.e., a SGTR scenario) occur during stop cooling (April 5, 2002, at Hanul Unit 4 in South Korea) instead of during normal operation, it was assumed that the heading related to the reactor trip was left unconsidered (unconditional success). Figure 3 shows the HFE considered for each heading. The HFE combinations in each event tree (ET) scenario are shown in Table 2.

Table 2. HFE combinations for each heading in the event tree

Scenario #	End state	Successful HFEs	Failed HFEs	HEP quantification candidates
1	OK	-	-	
2	CD	a, b, c, d, e	H	$P(H   abcde)$
3	OK	-	-	
4	CD	a, b, c, d	E, G	$P(E   abcd), P(G   abcdE)$
5	OK	-	-	
6	CD	a, b, c	D, G	$P(D   abc), P(G   abcdD)$
7	OK	-	-	
8	CD	a, b	C, G	$P(C   ab), P(G   abC)$
9	OK	-	-	
10	CD	a, c, d	B, H	$P(B   acd), P(H   aBcd)$
11	CD	a, c	B, D	$P(B   ac), P(D   aBc)$
12	CD	a	B, C	$P(B   a), P(C   aB)$
13	OK	-	-	
14	CD	b, c	A, F	$P(A   bc), P(F   Abc)$
15	CD	b	A, C	$P(A   b), P(C   Ab)$
16	CD	-	A, B	$P(A), P(B   A)$

## Step #2: Screening Analysis for Dependency Candidates

Candidates for HEP analysis were screened by identifying the dependency relationships between HFEs included among the HEP quantification candidates. For example, with respect to  $P(H | abcde)$  in scenario #1, the dependencies of H-a, H-b, H-c, H-d, and H-e are checked. If all these HFEs pertain to the same crew and occur in the same place,  $P(H | abcde)$  becomes the final calculation target by satisfying the criteria imposed by the dependency elements Crew and Location. However, if the time interval between a~e and H exceeds the time of the shift, the evaluation criteria will not be satisfied, thus the dependency need not be considered. That is, in this case, only  $P(H)$  must be obtained in scenario #1. If no information exists on the dependency elements between HFEs, the existence of dependency is simply assumed in order to make the calculation conservative.

## Step #3: Application of Mathematical Models

In the case of the dynamic approach to dependency analysis, since the timing data of each HFE are required, we referred to an SGTR event that occurred in a domestic nuclear power plant in order to employ the timing information to our mathematical models. (KINS, 2002) Also, to assume the missing data in this incident investigation report, a SGTR simulation experiment was referred to and utilized as action time data (Jung, et al., 2007). The event sequence, related HFEs, and timing information of the reference event are shown in Figure 4.




Figure 4. Event sequence, HFEs, and timing information of the reference event

As seen in Figure 4, a total of five HFEs appear in this reference event. For the pilot application of this methodology, those HEPs applied the dynamic dependency approach was calculated for each HFE. Due to the lack of information on the dependency element between each pair of HFEs, dependencies between all the HFEs are assumed to exist. As per the SPAR-H methodology, the basic HEP for the actions involve in each HFE is 1-E3. The basic HEP for diagnoses is 1-E2. The final HEP was calculated by implementing the PSF correction factor. The multipliers for the dynamically considered stress/stressor and fitness-for-duty PSFs were calculated separately from other PSF. Table 3 gives the HEPs for the other six PSFs.

Table 3. HEPs considering PSFs except dynamic elements

Type	HFE #1	HFE #2	HFE #3	HFE #4	HFE #5
Diagnosis	0.0004	0.00002	0.0004	0.008	0.004
Action	0.000025	0.000025	0.000025	0.0005	0.00025

### PSF calculation for dynamic elements

Application of the dynamic approach necessitates, timing information and time required data for each HFE (Table 4). T is the time at which the corresponding HFE begins, and M is the time at which the HFE ends, that is, it can be calculated as T + time required. Q is the time at which the lag effect of the corresponding HFE reaches its maximum, and R is the time at which the linger effect ends. For the time required for HFE #1 and #2, data from the reference literature (Jung et al., 2007) were utilized, and for the time required for HFE #3, the time indicated in the reference event was applied. The times required for HFE #4 and #5 were assumed to be 35 and 50 minutes, respectively, referring to the general amount of time required for the decision-making and action portions of the relevant task. The T of each HFE utilized the event sequence of the reference event.

Table 4. Timing information for the selected HFEs

HFEs	Timing Information				
	Time Required [sec]	T [sec]	M [sec]	Q [sec]	R [sec]
#1	576	960	1536	4560	12336
#2	1188	780	1968	4380	12768
#3	3540	1620	5160	5220	15960
#4	2100	1140	3240	4740	14040
#5	3000	36300	39300	39900	50100

Since  $M < Q$  for all selected HFEs, the second formula for the lag and linger model developed during the authors' prior research (Park et al., 2019) was applied (see Figure 5). Table 5 shows the parameters for calculating the stress/stressor PSF. The dynamic stress/stressor PSF calculated over time is shown in Figure 6, and the dynamic fitness-for-duty PSF is shown in Figure 7.

Table 5. Parameters for stress/stressor PSF calculation

Parameter	HFE #1	HFE #2	HFE #3	HFE #4	HFE #5
T	960	780	1620	1140	36300
M	1536	1968	5160	3240	39300
Q	4560	4380	5220	4740	39900
R	12336	12768	15960	14040	50100
K	2	2	2	2	2
f(M)	1.77639126	1.86468391	1.99794816	1.93420438	1.97774249




Figure 5. Equations for the second PSF lag and linger model (Park et al., 2019)




Figure 6. Dynamic multiplier for the stress/stressor PSF




Figure 7. Dynamic multiplier for the fitness-for-duty PSF




Figure 8. Dynamic HFEs in light of indirect dependencies between HFEs

Figure 8 shows the final HFEs in light of all the dynamic elements (i.e., dynamic stress/stressor and fitness-for-duty PSFs). For HFE #4, the utilizable PSF rating data were insufficient, and the positive PSF was relatively less well reflected, so the calculated HEP value was relatively high. HFE #5 occurred after the PSF linger effect was terminated due to a long period of time with HFE #1 to 4, so it is not affected by the residual effect of stress/stressor PSF.

## CONCLUSIONS

In this paper, an approach for dynamically considering dependencies between HFEs over time in HRA was applied to a SGTR event that occurred in a domestic nuclear power plant. The fact that shared elements such as shared PSFs generate indirect dependency between HFEs unlocks a new way of considering such dependency. In this study, the stress/stressor and fitness-for-duty PSFs were considered the shared dynamic factors, and changes the these dynamic PSFs with respect to the reference event were calculated. Although this application is limited to a specific scenario, HRA of a more explanatory nature is expected to be made possible if the proposed method becomes widely used in future research.

## ACKNOWLEDGMENTS

This work was partially supported by the Risk-Informed System Analysis (RISA) Pathway of the U.S. Department of Energy's Light Water Reactor Sustainability Program and by the Nuclear Safety Research Program through the Korea Foundation of Nuclear Safety (KoFONS) using a financial resource granted by the Nuclear Safety and Security Commission (NSSC) of the Republic of Korea (No. 2003011).

## REFERENCES

- Boring, R., Ulrich, T., Park, J., Mortenson, T., Ahn, J., & Lew, R. (2021). An Adaptable Toolkit for Dynamic Human Reliability Analysis: Progress Toward HUNTER 2. Retrieved from
- Boring, R. L. (2015). A dynamic approach to modeling dependence between human failure events. Retrieved from
- Gertman, D., Blackman, H., Marble, J., Byers, J., & Smith, C. (2005). The SPAR-H human reliability analysis method. US Nuclear Regulatory Commission, 230, 35.
- Jung, W., et al. (2007) "Analysis of an operators' performance time and its application to a human reliability analysis in nuclear power plants." IEEE transactions on nuclear science 54.5: 1801-1811.
- KINS, (2002) Incident Investigation Report from the operational performance information system for nuclear power plant (OPIS) managed by the Korea Institute of Nuclear Safety (KINS), April 2002 Steam Generator Heat Tube Leakage during Shutdown at Hanul Unit 4.
- Park, J., & Boring, R. L. (2021). Identification of Performance Shaping Factors Affecting Subsequent Human Actions for Dependence Assessment in Human Reliability Analysis. Paper presented at the International Conference on Applied Human Factors and Ergonomics.

- Park, J., Boring, R. L., & Kim, J. (2019). An Identification of PSF Lag and Linger Effects for Dynamic Human Reliability Analysis: Application of Experimental Data. Paper presented at the 2019 12th International Conference on Human System Interaction (HSI).
- Spencer, M., Robertson, K., & Folkard, S. (2006). The development of a fatigue/risk index for shiftworkers. Health and safety executive report, 446.
- Swain, A. D., & Guttman, H. E. (1983). Handbook of human-reliability analysis with emphasis on nuclear power plant applications. Final report. Retrieved from