



Assembly and Functional Test of NRAD Heated Instrumentation Rig

October 2021

Changing the World's Energy Future

Joe Palmer



DISCLAIMER

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

Assembly and Functional Test of NRAD Heated Instrumentation Rig

Joe Palmer

October 2021

**Idaho National Laboratory
Idaho Falls, Idaho 83415**

<http://www.inl.gov>

**Prepared for the
U.S. Department of Energy
Under DOE Idaho Operations Office
Contract DE-AC07-05ID14517**

Assembly and Functional Test of NRAD Heated Instrumentation Rig

1. Effective Date	10/11/2021	Professional Engineer's Stamp Not required per LWP-10010, Sec.4.1, para. cc
2. Does this TEV involve a Safety SSC?	No	
3. Safety SSC Determination Document ID	NA	
4. SSC ID	NA	
5. Project No.	----	
6. Engineering Job (EJ) No.	NA	
7. Building	TRA-1626	
8. Site Area	ATR Complex	
9. Objective / Purpose <p>The purpose of this TEV is to document assembly and functional testing of a device which is designed to allow advanced sensors to be temporarily placed at the periphery of the NRAD reactor. While in this location, the operational characteristics of the sensors can be evaluated while they are exposed to a neutron flux. This device (or "rig") consists of a cartridge heater surrounded by six guide tubes, which are in turn surrounded by insulation and an aluminum dry tube. The heater allows for the sensors to be tested while at elevated temperature.</p> <p>The assembly and functional testing was performed in building TRA-1626, the Test Train Assembly Facility (TTAF).</p>		
10. If revision, please state the reason and list sections and/or page being affected. <p>Rev. 1 a. Added missing sheets to Appendix B showing measured depths of guide tubes and corresponding locations of sensors (page B4 and B5). b. Added Appendix G, which shows the as-run location of the sensors (for irradiation conducted 8/25/2021).</p>		
11. Conclusion <p>The testing documented herein was to verify the test rig functions as intended, prior to transferring it to the NRAD reactor. The functional testing performed at TTAF confirmed the following attributes:</p> <ol style="list-style-type: none"> 1. The dry tube does not leak. 2. The central heater in the test rig can raise the temperature in the sensor guide tubes to at least 800°C. 3. The sensors being tested have a sensitive region of 90 mm or less. The temperature variation along this 90 mm length was less than 25°C with the center of this region at 800°C. 4. The surface temperature of the dry tube at the elevation corresponding to core mid-plane was less than 10°C above the bulk water temperature during the test period. 		

CONTENTS

PROJECT ROLES AND RESPONSIBILITIES	3
SCOPE AND BRIEF DESCRIPTION	4
TEST RESULTS AND OBSERVATIONS.....	4
ASSUMPTIONS.....	5

APPENDIXES

Appendix A Test Log	A1
Appendix B Assembly Log	B1
Appendix C Quantities of Elements in Core Region	C1
Appendix D Documentation of Materials Used in Core Region	D1
Appendix E Dry Tube Assembly Sketches	E1
Appendix F Heater Power Supply	F1
Appendix G Sensors and Cabling Summary (As-Run 8/25/2021)	G1

PROJECT ROLES AND RESPONSIBILITIES

Project Role	Name	Organization	Pages Covered (if applicable)
Performer	Joe Palmer	C660	-----
Checker ^a	Troy Unruh	C670	-----
Independent Reviewer ^b	NA	-----	-----
CUI Reviewer ^c	Nate Oldham	C660	-----
Manager ^d	Bryce Kelly	C660	-----
Requestor ^e	Patrick Calderoni	C670	-----
Nuclear Safety ^f	NA	-----	-----
Document Owner	Patrick Calderoni	C670	-----
Reviewer	NA	-----	-----

Responsibilities:

- a. Confirmation of completeness, mathematical accuracy, and correctness of data and appropriateness of assumptions.
- b. Concurrence of method or approach. See definition, LWP-10106.
- c. Concurrence with the document’s markings in accordance with LWP-11202.
- d. Concurrence of procedure compliance. Concurrence with method/approach and conclusion.
- e. Authorizes the commencement of work of the engineering deliverable. See Appendix A.
- f. Concurrence with the document’s assumptions and input information. See definition of Acceptance, LWP-10200.

NOTE: *Delete or mark “N/A” for project roles not engaged. Include ALL personnel and their roles listed above in the eCR system. The list of the roles above is not all inclusive. If needed, the list can be extended or reduced.*

SCOPE AND BRIEF DESCRIPTION

The instruments to be tested in NRAD are primarily Self Powered Neutron Detectors (SPNDs) and miniature fission chambers. While these sensors can be configured to detect both fast and thermal neutrons, the testing in NRAD is expected to focus on thermal neutron flux measurements. SPNDs and fission chambers have been used extensively in commercial power plants, but their application in Material Test Reactors (MTRs) has been much more limited. New SPNDs and fission chambers are being designed specifically for use in MTR tests and for use in advanced reactor designs. One challenge of these new applications for neutron sensors is much higher operating temperatures compared to commercial light water reactors. The vast majority of SPNDs and fission chamber designs are for operating temperatures of 400°C and less, while MTR tests and advanced reactor designs need sensors capable of working reliably at 800°C or higher.

The testing documented herein was to verify the test rig functions as intended, prior to transferring it to the NRAD reactor. The objectives of the functional testing were as follows:

1. Verify the dry tube does not leak.
2. Verify the central heater in the test rig can raise the temperature in the sensor guide tubes to at least 800°C.
3. The sensors being tested have a sensitive region of 90 mm or less. Verify that the temperature variation along this 90 mm length is no more than 25°C with the center of this region at 800°C.
4. Record the surface temperature of the dry tube at the elevation corresponding to core mid-plane and verify that it rises no more than 10°C above the water temperature during the test period. This is to ensure that there is no chance of boiling NRAD coolant during operation.

Appendices to this TEV document configuration and assembly details of the test rig.

TEST RESULTS AND OBSERVATIONS

The results of the test objectives are presented in Table 1 below.

Table 1. Test Results

No.	Objective	Result	Re.
1	Tube doesn't leak	This was listed as a specific step WR 21-128 (which fabricated the dry tube) with QA verification. And the step was signed as "Sat".	WR 21-128
2	Temperature of 800°C can be achieved	In final test run (Test #4), a temperature of 800°C was achieved and maintained for >30 minutes	App. A, Test #4
3	Temperature variation <25°C	While at 800°C the ΔT was 17°C	App. A, Test #4
4	ΔT between surface of dry tube and water	The ΔT was 0.9°C	App. A, Test #4

Other observations were as follows:

5. For the first run, a temperature of 900°C was achieved, however after about 10 minutes of operation the heater failed open.
6. A digital temperature control unit was integrated into the system and during runs 2 and 3 the GFI breaker tripped after heating the test above 500°C. It was determined that the abrupt on-off nature of the digital controller, coupled with reduced coil to sheath resistance due to elevated temperature, induced a brief leakage of current to ground, which tripped the GFI. When the heater was powered directly from a Variac (with manual voltage adjustments to achieve target temperature), a steady temperature of 800°C was achievable.
7. The coil resistance of the heater was measured as 14.9 ohm. The voltage required to maintain a temperature of 800°C was 53 V. Therefore the max heater output was $(53V)^2/14.9 \text{ ohm} = 189 \text{ W}$.

ASSUMPTIONS

None.





Appendix A

Test Logs

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

ROLES AND RESPONSIBILITIES

Role	Name (Typed)	Organization	Signature
PR/PI	A. J. Palmer	C660	
Checker	T. C. Unruh	C670	
Doc Owner Approval	P. Calderoni	C670	Patrick Calderoni
Line Manger Approval	B. D. Kelly	C660	
Performer	R. N. Paulsen	C660/5442	 RNP

TEST #4

Test #4 was the final test and the only test that wasn't terminated early.

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

Procedure for Assembly and Out of Pile Testing

Project	NRAD Heated Instrumentation Tests	ID: Out of Pile-X (number tests sequentially)		
Item	Description	Comment	Sign-off	Date
10	Assemble test rig in accordance with Fig. 1, Fig. 2, and directions of PI. Attach additional sheets as necessary to document details of construction.		<i>Rv Rv</i>	7-26-21
15	Record Cal ID of scale and record weight of test rig assembly (this weight will be used to verify rig won't float when installed in NRAD)		<i>Rv Rv</i>	7-26-21
20	Record Cal IDs of TCs-1, 2, 3, 4, 5, 6 as identified in Fig. 1	<i>350°C RMP 7-29-21</i>	<i>Rv Rv</i>	7-29-21
30	Gradually increase voltage applied to heater to achieve a temperature of 300°C on TC-2. Record all TC readings, voltage and current		<i>Rv Rv</i>	7-29-21
40	Increase heater voltage to achieve temperatures of 400°C to 1000°C in 100°C increments (note PI may elect to stop temperature increases at any point). Record all TC readings, voltage and current. Monitor water bath temperature during this process. If it exceeds 45°C, terminate test.	<i>see changes Per PI</i>	<i>Rv Rv</i>	7-29-21
50	After reaching peak temperature, turn heater power off, and allow test rig to cool	<i>800°C max</i>	<i>Rv Rv</i>	7-29-21
60	If test is satisfactory, remove test rig from water tank, disassemble and store all materials. If not, repeat test using next sequential test number.	<i>Prep for ship and send Testing</i>	<i>Rv Rv</i>	7-29-21

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

		Record Data from Steps 20, 30, and 40									
			350°C	500°C	650°C	800°C					
	Cal ID and Date	Description	(300C on TC-2)	(400C)	(500C)	(600C)	(700C)	(800C)	(900C)	(1000C)	
TC-1	737177 7-10-22	Bottom TC of multipoint in one of the guide tubes	346.5	493.4	644	792	/				
TC-2	737177 7-10-22	Middle TC of multipoint in one of the guide tubes	350.9	501.8	650	801					
TC-3	737177 7-10-22	Top TC of multipoint in one of the guide tubes	355.5	506.1	655	809					
TC-4	737176 6-29-22	Strapped to dry tube at heater mid-plane. To measure dry tube surface temperature	20.2	20.9	22.6	23.6				NA	
TC-5	737174 6-29-22	Strapped to bottom of dry tube. To measure surf. temp. at this location	19.4	19.8	20.9	21.5				RNP 7-29-21	
TC-6	737175 6-29-22	Temperature of water in tank	20.0	20.4	22.0	22.7					
TC-A	NA info only	Center line of heater temperature	370.4	528.6	686	848					
W	720096 1-23-22	Weight of test rig assembly 14.0 lbs	←—————→								
V	NA info only	Heater voltage 57VAC max	30v	42v	48v	57v					
A	NA info only	Heater current NA single wire not available									

Comments: 10:17am → 11:51am for temp 1 to adjust and settle.
 11:51am → 12:57pm for temp 2 to adjust and settle.
 12:57pm → 3:48pm temp 3 adjust and settle. (got distracted) actual time may differ, lower.
 3:50pm → 4:21pm temp 4 came right in.
 Heater ran well without issue.

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation




Figure 1. General Layout and Thermocouple Locations








Figure 2. Test Rig Elevations and Details

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

ROLES AND RESPONSIBILITIES

Role	Name (Typed)	Organization	Signature
PR/PI	A. J. Palmer	C660	
Checker	T. C. Unruh	C670	
Doc Owner Approval	P. Calderoni	C670	
Line Manger Approval	B. D. Kelly	C660	

TEST #3

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

Procedure for Assembly and Out of Pile Testing

Project	NRAD Heated Instrumentation Tests	ID: Out of Pile-X (number tests sequentially)		
Item	Description	Comment	Sign-off	Date
				#3
10	Assemble test rig in accordance with Fig. 1, Fig. 2, and directions of PI. Attach additional sheets as necessary to document details of construction.		AJP	7.26.21
15	Record Cal ID of scale and record weight of test rig assembly (this weight will be used to verify rig won't float when installed in NRAD)		AJP	7.26.21
20	Record Cal IDs of TCs-1, 2, 3, 4, 5, 6 as identified in Fig. 1	350°C AJP 7.26.21	AJP	7.26.21
30	Gradually increase voltage applied to heater to achieve a temperature of 300°C on TC-2. Record all TC readings, voltage and current	See new temperature sched p. 3. AJP 7.26.21	AJP	
40	Increase heater voltage to achieve temperatures of 400°C to 1000°C in 100°C increments (note PI may elect to stop temperature increases at any point). Record all TC readings, voltage and current. Monitor water bath temperature during this process. If it exceeds 45°C, terminate test.		Terminated	
50	After reaching peak temperature, turn heater power off, and allow test rig to cool			
60	If test is satisfactory, remove test rig from water tank, disassemble and store all materials. If not, repeat test using next sequential test number.			

Test
AJP
8.2.21

250°C to 350°C took 8 minutes. Soaked @ 350°C for 12 minutes & recorded temp

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

		Record Data from Steps 20, 30, and 40								
Cal ID and Date	Description	350°C (300C on TC-2)	500°C (400C)	650°C (500C)	800°C (600C)	(700C)	(800C)	(900C)	(1000C)	
TC-1 737177 7.10.22	Bottom TC of multipoint in one of the guide tubes	345.6	492.0	Terminated ASP 8.2.21	NA	ASP 7.26.2021				
TC-2 737177 7.10.22	Middle TC of multipoint in one of the guide tubes	350	500							
TC-3 737177 7.10.22	Top TC of multipoint in one of the guide tubes	354.4	507.3							
TC-4 737176 6.29.22	Strapped to dry tube at heater mid-plane. To measure dry tube surface temperature	23.0	23.7							
TC-5 737174 6.29.22	Strapped to bottom of dry tube. To measure surf. temp. at this location	22.2	22.5							
TC-6 737175 6.29.22	Temperature of water in tank	21.9	22.2							
TC-A	NA info only	Center line of heater temperature	~360	520.7						
W	720096 1.23.22	Weight of test rig assembly	14.0 lbs							
V	NA info only	Heater voltage	65V	65V	65V					
A	NA info only	Heater current	NA - Current is chopped							
<p>Comments: 250°C to 350°C took 8 minutes. Soaked @ 350°C for 12 minutes & recorded temperature 350°C to 500°C took 10 minutes. Soaked @ 500°C for 10 minutes & recorded temps. Tripped GFI Breaker @ 15:05pm during heating to 650°C</p>										

Room temperature heater resistance was 14.9 Ω 727677 Exp 3.30.2022 Fluke Multimeter

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation




Figure 1. General Layout and Thermocouple Locations








Figure 2. Test Rig Elevations and Details

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

ROLES AND RESPONSIBILITIES

Role	Name (Typed)	Organization	Signature
PR/PI	A. J. Palmer	C660	
Checker	T. C. Unruh	C670	
Doc Owner Approval	P. Calderoni	C670	
Line Manger Approval	B. D. Kelly	C660	

TEST #2

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

Record Data from Steps 20, 30, and 40										
Cal ID and Date	Description	350°C (300°C on TC-2)	500°C (400°C)	650°C (500°C)	800°C (600°C)	(700C)	(800C)	(900C)	(1000C)	
TC-1 737177 7.10.22	Bottom TC of multipoint in one of the guide tubes	346.1								
TC-2 737177 7.10.22	Middle TC of multipoint in one of the guide tubes	350.0								
TC-3 737177 7.10.22	Top TC of multipoint in one of the guide tubes	352.8								
TC-4 737176 6.29.22	Strapped to dry tube at heater mid-plane. To measure dry tube surface temperature	22.5					N/A			
TC-5 737174 6.29.22	Strapped to bottom of dry tube. To measure surf. temp. at this location	21.7								
TC-6 737175 6.29.22	Temperature of water in tank	21.3								
TC-A	NA info only Center line of heater temperature	364.5								
W	720096 1.23.22 Weight of test rig assembly	14.016								
V	NA info only Heater voltage	67V								
A	NA info only Heater current	NA chipped								

Comments: 250°C to 350°C took 7 minutes. Soaked @ 350°C for 10 min & recorded temp. Tripped GFI breaker during ramp to 500°C. Terminated test.

Multipoint was in guide tube #6. ASP 7.22.21

Assembly and Functional Test of NRAD Heated Instrumentation Rig

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation




Figure 1. General Layout and Thermocouple Locations








Figure 2. Test Rig Elevations and Details

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

ROLES AND RESPONSIBILITIES

Role	Name (Typed)	Organization	Signature
PR/PI	A. J. Palmer	C660	
Checker	T. C. Unruh	C670	
Doc Owner Approval	P. Calderoni	C670	
Line Manger Approval	B. D. Kelly	C660	

TEST #1

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

Procedure for Assembly and Out of Pile Testing

Project	NRAD Heated Instrumentation Tests	ID: Out of Pile-X (number tests sequentially)		
Item	Description	Comment	Sign-off	Date
10	Assemble test rig in accordance with Fig. 1, Fig. 2, and directions of PI. Attach additional sheets as necessary to document details of construction.		AG/Plm	7/13/2021
15	Record Cal ID of scale and record weight of test rig assembly (this weight will be used to verify rig won't float when installed in NRAD)	See #1 Below	AG/Plm	7/15/2021
20	Record Cal IDs of TCs-1, 2, 3, 4, 5, 6 as identified in Fig. 1		AG/Plm	7/13/2021
30	Gradually increase voltage applied to heater to achieve a temperature of 300°C on TC-2. Record all TC readings, voltage and current		AG/Plm	7/13/2021
40	Increase heater voltage to achieve temperatures of 400°C to 1000°C in 100°C increments (note PI may elect to stop temperature increases at any point). Record all TC readings, voltage and current. Monitor water bath temperature during this process. If it exceeds 45°C, terminate test.		AG/Plm	7/13/2021
50	After reaching peak temperature, turn heater power off, and allow test rig to cool		AG/Plm	7/13/2021
60	If test is satisfactory, remove test rig from water tank, disassemble and store all materials. If not, repeat test using next sequential test number.	Unsat *	AG/Plm	7/13/2021

* Heater failed open

#1 Cal ID of scale is actually Cal ID of certified weights used to ck scale prior to weighing test rig.

Assembly and Functional Test of NRAD Heated Instrumentation Rig

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation

Record Data from Steps 20, 30, and 40										
	Cal ID and Date	Description	(300C on TC-2)	(400C)	(500C)	(600C)	(700C)	(800C)	(900C)	(1000C)
	737177 ^{7.10.22}	Bottom TC of multipoint in one of the guide tubes	290.1	389.2	485.9	585.4	683	783	883	Not Done RSP 7/17/21
	737177 ^{7.10.22}	Middle TC of multipoint in one of the guide tubes	300.0	400	500	600	700	800	900	
	737177 ^{7.10.22}	Top TC of multipoint in one of the guide tubes	299.9	398.6	498.7	597.5	695	793	891	
#1	737176	Strapped to dry tube at heater mid-plane. To measure dry tube surface temperature	19.7	20.6	20.7	21.2	21.8	22.5	23.2	
#2	737174	Strapped to bottom of dry tube. To measure surf. temp. at this location	19.0	19.3	19.7	20.1	20.4	20.9	21.2	
#3	737175	Temperature of water in tank	19.0	19.2	19.3	19.7	19.9	20.2	20.6	
	NA info only	Center line of heater temperature	316.7	425.5	528.9	633	738	842	947	
W	720096 ^{1.23.22}	Weight of test rig assembly 14.0 lbs								
V	NA info only	Heater voltage 90V*								
A	NA info only	Heater current - Not available								
<p>Comments: ~10 min to achieve 300c, ~8 min ⇒ 400c, 7 min ⇒ 500c, 7 min ⇒ 600c, 7 min 30 sec ⇒ 700c, ~9 min ⇒ 800c Going from 700c to 800c heater peak temp of 870c (voltage still 90V) * Reduced heater voltage to 80V for last step 800c ⇒ 900c. Max temp of heater = 955c. Elapsed time 800c-900c was 11 minutes. After about 5 min @ temperature the heater failed open.</p>										

Assembly and Functional Test of NRAD Heated Instrumentation Rig

TEST PROCEDURE

Performance Evaluation of Heated NRAD Instrumentation Test Rig Prior to Installation




Figure 1. General Layout and Thermocouple Locations




Figure 2. Test Rig Elevations and Details

Appendix B

Assembly Log

Assembly Log


Date	Initial complete	Assembly Step	Comments																		
7-26-21	RNP	Cut four pieces of Microtherm insulation blanket (1/4" thk) to a diameter of 1 3/4"	These four disks of insulation will be stacked at the bottom of the dry tube and minimize axial heat transfer out the bottom.																		
7-26-21	RNP	Cut six 1/4 x .016 sst tubes at 109 inches long																			
7-26-21	RNP	Cut a seventh 1/4 x .016 sst tube at 77.75 inches long																			
7-26-21	RNP	Cut a .75 OD disk out of 1/16" thick stock to serve as the floor of the guide tube bundle																			
7-26-21	RNP	<p>Cut six "prop" tubes from 3/16 x .016" sst tube with the following lengths:</p> <table style="display: inline-table; border: none;"> <tr> <td>#1</td> <td>7.8 inch</td> <td>7.68</td> </tr> <tr> <td>#2</td> <td>7.3 inch</td> <td>7.18</td> </tr> <tr> <td>#3</td> <td>8.5 inch</td> <td>8.38</td> </tr> <tr> <td>#4</td> <td>7.0 inch</td> <td>6.88</td> </tr> <tr> <td>#5</td> <td>7.0 inch</td> <td>6.88</td> </tr> <tr> <td>#6</td> <td>7.0 inch</td> <td>6.88</td> </tr> </table> <p style="margin-left: 150px;">} ASP 8.2.21</p>	#1	7.8 inch	7.68	#2	7.3 inch	7.18	#3	8.5 inch	8.38	#4	7.0 inch	6.88	#5	7.0 inch	6.88	#6	7.0 inch	6.88	<p>These were later shortened 1/8"</p> <p>New lengths shown at left</p> <p>ASP 8.2.21</p>
#1	7.8 inch	7.68																			
#2	7.3 inch	7.18																			
#3	8.5 inch	8.38																			
#4	7.0 inch	6.88																			
#5	7.0 inch	6.88																			
#6	7.0 inch	6.88																			
7-26-21	RNP	Slide the 1/4" x 77.75" tube over the heater leads																			
7-26-21	RNP	Arrange the six 1/4" x 109" tubes around the heater and tie wire everything together into a solid entity (sst tie wire). In conjunction with this, apply T-99 compound between the heater and six tubes (lower 24" is sufficient)	See Fig. 1																		
7-26-21	RNP	After tie-wiring everything together, apply T-99 compound over the lower 24" of the completed assembly. The 3/4" dia x 1/16"																			

7-26-20	RND	thick sst disk should be attached to the bottom of the bundle with tie-wire.	See Fig. 2
7-26-21	RND	Cure the T-99 compound per manufacturer's directions	
7-28-21	RND	Fabricate an aluminum cylinder 1.77 OD x .83 ID x 6 inch long	
7-26-21	RND	Wrap insulation around the tube bundle. The top of the insulation should be roughly 83 inches from the top of the tube bundle (and about 27 inches from the bottom of the ceramic spacer at the bottom of the assembly). Tire wire insulation in place	See Fig. 3
7-26-21	RND	Slide aluminum cylinder over the tube bundle down to the insulation.	See Fig. 3
7-26-21	RND	Slide foam insulation over tube bundle to within 7" of the top end of the tube bundle. Cap off with the black silicone insulation, terminating it about 1/2" from the top of the tube bundle.	See Fig. 4
7-26-21	RND	Mark guide tube #2 by cutting a slot at the top of the tube. This slot will face due East when the assembly is in the reactor. Insert prop tubes into their appropriate guide tubes.	See Fig. 5
7-26-21	RND	Place the four 1 3/4" diameter microtherm disks at the bottom of the dry tube	
7-26-21	RND	Slide the heater/tube assembly just finished into the dry tube noting the azimuthal orientation as shown in the figure below.	"Figure below" refers to 'Assembly Orientation Figure' See Figs. 6 and 7 for completed assembly
7-26-21	RND	Weigh completed assembly and record calibration information	calibrated weights - 7200 96 14 lbs 1-23-2022

Assembly and Functional Test of NRAD Heated Instrumentation Rig

8.2.21	AJP	Measure overall length of dry tube. Measure depth of guide tubes (this confirms where the sensors will reside relative to core mid-plane).	
8.2.21	AJP	Overall length of dry tube	110 $\frac{5}{8}$ "
8.2.21	AJP	Depth of guide tube #1 (see orientation figure in "Test Procedure" for guide tube numbering)	101 $\frac{3}{8}$ "
8.2.21	AJP	Depth of guide tube #2	101 $\frac{7}{8}$ "
8.2.21	AJP	Depth of guide tube #3	101 $\frac{21}{32}$ "
8.2.21	AJP	Depth of guide tube #4	102 $\frac{7}{32}$ "
8.2.21	AJP	Depth of guide tube #5	102 $\frac{7}{32}$ "
8.2.21	AJP	Depth of guide tube #6	102 $\frac{7}{32}$ "

Assembly and Functional Test of NRAD Heated Instrumentation Rig



Assembly orientation figure



Figure 1. Tubes wired together prior to application of T-99 cement



Figure 2. Guide tubes floor plate tie-wired to bottom of assembly




Figure 3. Insulation over tubes forming a "sausage"




Figure 4. Light-weight foam insulation taped in place




Figure 5. Guide tube facing east is marked with a cut at its top




Figure 6. Completed assembly



Figure 7. Completed assembly in testing tank

Buoyancy Evaluation

	OD	ID	Submerged Length	Density of water (lbm/in ³)	mass of water displaced (lbm)
	2.000	0.000	104.000	0.0359	11.73
	OD (in)	ID (in)	Length (in)	Density (lbm/cu-in)	Mass (lbm)
Mass of various objects making up assembly					
Aluminum tube	2	1.81	108	0.098	6.02
Heater shell	0.27	0.234	30	0.29	0.12
Heater insulation fill	0.234	0	30	0.085	0.11
Guide tubes	0.25	0.218	624	0.28	2.06
quilted insulation	1.75	0.85	26	0.07	3.34
Aluminum chill slug	1.75	0.83	6	0.098	1.10
Upper insulation (foam)	1.75	0.77	70	0.005	0.68
Total					13.43
Since mass of assembly (13.43 lbm) is greater than mass of water displaced (11.72 lbs), the test rig will not float					

conservatively took
66% of density of
silica

As discussed above, the test rig was also weighed and found to be 14.0 lbs +/-0.5 lbs.


Appendix C

Quantities of Elements in Core Region

See supplementary information attached to this TEV on EDMS.

Appendix D

Documentation of Materials Used in Core Region

W.O./Purchase Order No.	Revision No.	Receipt No.	Quality Level
21-128	0	N/A	1 2 (3)
Line Item No.	Quantity Inspected	Catalog I.D. No.	QA/UTC No.
N/A	1	N/A	21-128
Item Description			
Adapter to connect ASI Dry Tube to NRAD Cluster Fitting			
Specification/Drawing	Rev.	Heat No.	Serial No.
SKETCH: AJP-02-2021	1	N/A	Unit 1
Facility/Area/System	Inspector Signature	S No.	Date
NHL		118875	4/29/21

Note that this green-tag should have specified sketch AJP-03-2021 which was for the entire assembly.



Idaho Laboratories Corporation

2101 Hemmert Ave.
Idaho Falls, ID 83401
Phone (208) 522-0055
Fax (800) 524-4522

CERTIFICATE OF CONFORMANCE

WE HEREBY CERTIFY THAT THE MATERIALS AND SERVICES SUPPLIED ARE IN CONFORMANCE WITH CUSTOMER PURCHASE ORDER REQUIREMENTS. THE REQUIRED TEST AND/OR INSPECTION RECORDS ARE ON FILE AND AVAILABLE FOR REVIEW BY THE CUSTOMER AT ANY TIME WITHIN THE RECORD RETENTION PERIOD.

CUSTOMER SUPPLIED TO: BATTELLE ENERGY ALLIANCE, LLC

SPECIFICATION/DWG#: N/A

CUSTOMER PURCHASE ORDER: 00248131

ILC PART NUMBER: 270-KJ/24/2NI-1600-H-GND-22"/8"

ILC SALES ORDER NUMBER: 243463

ILC HEAT NUMBER: 42049

ILC SPECIFICATION: S210226-01-GNH

DESCRIPTION OF MATERIAL: 3 PIECES

NOTES: AS PER CUSTOMER PURCHASE ORDER AGREEMENT.


Note that this page and the following six are for the heater used in the assembly.

RESISTANCE OF HEATER AT ROOM TEMPERATURE.

1- 14.50 OHMS/LOOP

2- 14.60 OHMS/LOOP

3- 14.48 OHMS/LOOP


ILC
O.A. #6
Final
SIGNATURE

QA Manager
TITLE

04/22/2021
DATE


ILC
O.A. #6
Final
SIGNATURE

Document Control
TITLE

Assembly and Functional Test of NRAD Heated Instrumentation Rig







Idaho Laboratories Corporation


2101 Hemmert Ave.
Idaho Falls, ID 83401
Phone (208) 522-0055
Fax (800) 524-4522

Customer: BATTELLE ENERGY ALLIANCE, LLC.
Customer PO: 00248131
ILC Sales Order Number: 243463
Date: 04/22/2021

The following pieces were PMI tested by Idaho Laboratories Corporation. The results of the tests are as follows:


NICHROME WIRE	NICKEL WIRE
 Test #8558 08:43, 4/22/2021 Ni_NichromeV ₉₉ X200-00506	 Test #8559 08:43, 4/22/2021 Ni_Ni 200 ₁₀₀ X200-00506
Cr 18.85% ±0.49%	Mn 0.10% ±0.05%
Fe 0.23% ±0.06%	Ni 99.90% ±2.55%
Ni 80.92% ±0.92%	



SIGNATURE


QA Manager
TITLE
04/22/2021
DATE



SIGNATURE


Document Control
TITLE



Assembly and Functional Test of NRAD Heated Instrumentation Rig

540.04
11/01/2006
Rev. 05

CERTIFICATE OF CONFORMANCE

Page 1 of 3

NOTE: Prior to completing this certification, the Supplier shall review and comply with the attached **form instructions**.

A. A. Purchase Order/Contract Data			
1. PO No.: 00248131	2. PO Rev No.: N/A	3. PO Line Item: 1	
4. Contract No.: N/A	5. Contract Amendment No.: N/A		
B. Supplier/Source Information			
6. Supplier: IDAHO LABORATORIES CORPORATION		7. Supplier Address (Street/City/State): 2101 HEMMERT AVENUE IDAHO FALLS, IDAHO 83401	
8. Source of Origin: Street: <u>2101 HEMMERT AVENUE</u> City: <u>IDAHO FALLS</u> State: <u>IDAHO</u> Country: <u>USA</u>		CAUTION: The suppliers shall take all necessary actions and precautions to assure that this Certificate of Conformance(C of C) is accurate, complete, and true, regardless of the actual source of origin.	
C. Applicable Requirements			
9. Code/Standard No.:	3 PCS 270-K/24/2NI-I600-H-GND-22"/8"	Revisions/Editions/Addendum:	N/A
10. Specification No.:	N/A	Revision/Editions:	N/A
11. Technical Drawings/Diagrams:	N/A	Revision:	N/A
12. Other:	N/A	Revisions/Editions/Addendum:	N/A
D. Approved Changes/Deviations/Waivers/Substitutions/Nonconformances:			
E. Nonconformance(s): Unless otherwise directed in writing by the Procurement Agent, Do NOT deliver/ship materials/items/equipment if there are any changes, deviations, substitutions, or nonconforming conditions that have not been previously submitted and approved utilizing Form 540.33, Information/Change Request.			
F. Certification Statement			
Idaho Laboratories Corp. (Supplier), hereby certifies that the materials/items/equipment identified in Section A above, and all required documentation, conforms in all respects to the stated Purchase Order/Contract requirements and that all exceptions, waivers, deviations, and/or nonconforming conditions are identified in Section D. Furthermore, information provided is accurate, complete, and true pursuant to 10 CFR 820.11 (see definition).			
Authorized Certifying Official (See Definitions/Instructions):			
RYAN PHILIPS Printed Name	 Signature		DOCUMENT CONTROL Title
			04/22/2021 Date

See Instructions

C of C is Limited To One Page. Attached Additional Pages On Supplier Letter Head If Required.

Assembly and Functional Test of NRAD Heated Instrumentation Rig



Certified Material Test Report

EN 10204 - 3.1

Messrs.
Deutsche Nickel America
70 Industrial Road
Cumberland, RI 02864
USA

No.: R 65052
Order-No.:
401644
Confirmation-No.:
220/80129089/002

Material: Ni 205 Specification: GE 0024-2843 Rev. 6, dt. 19 11.2003
Mat.-No.: UNS No2205 33-MN-15A
Form of delivery: wire GE Part CA 3725663
Dimension: dia. 0.0588" Condition: cold drawn, 1/4-hard
dia. 1,494 mm
Net weight: No. of pieces: Heat-No.:
230,50 kg 8 coils 81085
508,16 lbs.

MEASURED VALUES						
(melting composition of heat)						
Composition (mass-%):						
Ni	Cu	Fe	Mn	S	Si	C
99,6	0,014	0,036	0,20	0,0010	0,02	0,011
Ti	Mg					
0,034	0,038					

Tensile strength (PSI): 85900 - 89600
Yield strength at 0,2 % offset (PSI) 84500 - 87300
Elongation at 10" (%) 1,0 - 1,5

Our QM-system is certified by Lloyd's Quality Assurance in accordance to DIN EN ISO 9001, certificate no. KLN 4000313-10
Our QM system is certified by Lloyd's Quality Assurance in accordance to DIN EN ISO 14001, certificate no. KLN 4000313-14
Our EM-system is certified by Lloyd's Quality Assurance in accordance to DIN EN ISO 14001, certificate no. KLN 4001020

Schwerte, 29.11.2010

QC Manager
Bernd Jacobs



Assembly and Functional Test of NRAD Heated Instrumentation Rig

PELICAN WIRE COMPANY, INC.



(239) 597-8555 PH
(239) 597-9783 FX

WHITE LAKE CORPORATE PARK
3650 SHAW BOULEVARD
NAPLES, FLORIDA 34117-8408

Sold to:

Idaho Labs

2101 Hemmert Avenue

IDAHO FALLS, ID 83401

Ship to:

2101 Hemmert Avenue

IDAHO FALLS ID 83401

Date: 7/25/13

CERTIFICATE OF COMPLIANCE

Pelican Wire Part No: 2120N80

Customer Part No: N/A

Quantity: 43.220 LB

P.O. 25189

Folder # 64024

We hereby certify that the material supplied on the above Purchase Order is 20 AWG NICHROME 80 bare wire, composed of 80% Nickel, 20% Chromium/conforming to all requirements of ASTM B344. The 20 AWG (.032) NICHROME wire has a nominal resistance of .6293 +/- 3%. The nominal strength for annealed Nichrome 80 is 120 kpsi. This bare wire is supplied on spools in one continuous length per spool .

Very truly yours,
PELICAN WIRE CO., INC.

Edward Valykeo
Quality Manager

TECHNICAL EVALUATION

Assembly and Functional Test of NRAD Heated Instrumentation Rig

SECTION 2A - ALLOY NAME AND NOMINAL COMPOSITIONS

WEIGHT % - 1% OR GREATER

Alloy	Alloy Name	Cr	Fa	Mn	Ni*	Si	Other	Spec. Grav.	Approx. Melting Point °C
007	NiCr 60 Alloy C	16	24		59	1		8.2	1350
241	NiCr 80 Alloy A	20			79	1		8.4	1400

*Includes element plus other trace elements



GREENVILLE TUBE COMPANY LLC Material Test Report per EN 10204 3.1

501 S Montgomery St
Clarksville, AR 72830

CUSTOMER: IDAHO LABORATORIES CORP



PHONE 1-479-754-6500 FAX 1-479-754-8426

2101 HEMMERT AVE

SHIPPED TO: IDAHO LABORATORIES CORP
2101 HEMMERT AVE

ORDER NUMBER GV423584/1

PO Number 26633

IDAHO FALLS, ID 83401

DFARS

PART ID CS0375016N06600JAS01

DESCRIPTION .375 OD X .016 AW 600 SMLS Tube

IDAHO FALLS, ID 83401 UNITED ST

SPEC ASTM-B-163-19/B-167-18

FINISH Cold Drawn, Bright Annealed & Passiv CONDITION Bright Solution Annealed

DATE CERTIFIED 5/20/2020 EACH TUBE ON THIS ORDER HAS BEEN SPECTROGRAPHICALLY CHECKED FOR 600

TESTS PERFORMED

TENSILE STRENGTH	YIELD STRENGTH	ELONGATION	EDDY CURRENT	Pass
97366 PSI	56918 PSI	50%	FLARE	Pass
98199 PSI	57366 PSI	50%		

CHEMICAL ANALYSIS

HEAT NUMBER 306128 TYPE 600 SMLS

	C	Mn	P	S	Si	Ni	Cr	Mo	Ti	N	Fe	Ta	Nb(Cb)+Ta	Cu	Nb(Cb)	Al	Co
L	.02	.24		.001	.20	73.49	16.26	.05			8.81			.09			.06
P	.03	.23		.001	.22	73.30	16.49	.05			8.77			.09			.05

"I HEREBY CERTIFY THAT THE HEAT NUMBERS, ANALYSIS AND TESTS DETAILED HEREON, ARE CORRECT AS CONTAINED IN THE RECORDS OF THIS CORPORATION"

Country of Manufacture: United States of America Country of Melt: Japan

Pieces: Footage:

Assembly and Functional Test of NRAD Heated Instrumentation Rig



CSM-4

CRUSHABLE MGO INSULATORS
99.4% TATEHO OZARK GRADE CSM

CERTIFICATE OF COMPLIANCE

CUSTOMER NAME: Idaho Labs
CONTRACT NO: 26459
CUSTOMER P/N: R6H 232x037+
OUR JOB NO: 24044

(Please refer to this number for all correspondence)

Tateho Ozark Technical Ceramics, Inc. certifies that this shipment complies with the specifications of the above referenced contract with the exceptions listed below. Also listed is any additional information for reference as required.

Tateho Ozark Technical Ceramics, Inc. certifies that this product complies with the requirements of Type 1 of the current ASTM specification. Reference Chemical analysis results follow:

Chemical Analysis: Values in wt% unless specified. MgO value is by difference of emission spec impurities

*Raw Material Analysis Only

MgO	99.78%
CaO	0.19%
SiO2	0.03%
Al2O3	0.03%
Fe2O3	0.04%
C	<50 ppm
S	<5 ppm
B+Cd	<30 ppm

BATCH NO:	MOR:
5966.100	4500 psi

All products manufactured and sold by Tateho Ozark Technical Ceramics Inc. are in conformance with ROHS standards. No material supplied by Tateho Ozark Technical Ceramics are environmentally hazardous or present health hazards from routine exposure. No banned substances are used in the manufacture of our products.

By: Brandi Maggard
Brandi Maggard

REACH compliant as of 1/17/2019

Date: 2/18/2019

Please note condition of packaging materials and Shipper abuse when you observe breakage. For Quality/Quantity issues, please have your inspection information available for review and comparison. Please refer to the TOTC job number above and the Batch number in all correspondence. All Returns must be pre-approved by TOTC. Please contact this office for a Return Authorization.

Tateho Ozark Technical Ceramics Inc.
402 Ware Street Webb City, Missouri 64870 USA
(417) 673-2463 FAX: (417) 673-2464 sales@TatehoOzark.com

rev 1

End certs for heater

Assembly and Functional Test of NRAD Heated Instrumentation Rig



EAGLE STAINLESS

Tube and Fabrication, Inc

Franklin Industrial Park 10 Discovery Way Franklin, MA 02038

Telephone: (508) 528-8650 or (800) 528-8650 Fax: (508) 520-1954 or (800) 520-1954 Website: www.eagletube.com Email: info@eagletube.com

MATERIAL TEST REPORT
CERTIFICATE OF CONFORMANCE

SOLD TO: Eagle Rock Specialties LLC
ADDRESS: PO Box 51436
Idaho Falls ID 83405
DATE: 3/1/2021
PURCHASE ORDER: 247960
OUR ORDER#: 160459
PART # N/A
REVISION: N/A

HEAT #: 707880
SOURCE: 51-64688-01-21
ITEM: .250 OD X .016 WALL T316/316L SMLS
Spec: ASTM A213-19A EAW/A269-15A
Temper: BRIGHT ANNEALED
Quantity: 120 Units: FT

C: .018	Ti: -	Yield (PSI):	50,100/50,300
Si: .33	Cb: -	Tensile (PSI):	91,800/91,800
Mn: 1.16	Ta: -	Elong. (% IN 2"):	50/51%
P: .036	Fe: balance	Hardness (Rockwell):	B 66/67
S: .007	Cu: -	Flattening:	PASS
Ni: 12.22	Al: -	Flaring:	PASS
Cr: 16.80	N: -	Rev F/B:	-
Mo: 2.06	Co: -	Flange:	-
Misc Chem 1: -		Int C/E:	-
Misc Chem 2: -		Eddy Current:	PASS
Misc Chem 3: -		Hydrostatic:	-
		Grain Size:	-


Note 1: ORIGIN & MELT: JAPAN
Note 2: MFG: USA DFARS COMPLIANT
Note 3: MERCURY FREE
Comments:

Conforms to all drawing and/or specifications requirements. To the best of our knowledge the material is mercury free and compliant with Directive 2011/65/EC and 2006/122/ECOP regarding the Restriction of Hazardous Substances (RoHS), and is conflict free per Dodd-Frank section 1502. By the definitions provided in Article 3 (3) of the REACH regulation, the material(s) are considered "articles," and do not contain substances "intended to release" under normal circumstances and as such, the registration requirements of Article 7(1) do not apply. Reports governing this material are on file.

Paulette Cartier

EAGLE STAINLESS TUBE AND FABRICATION INC.
Paulette Cartier
Quality Assurance Manager

AA 3/1/2021
Int. Date



Cert for sensor guide tubes

INL RECEIVING REPORT

PO/RELEASE:	00246855 /	STATUS:	COMPLETE	RECEIPT DATE:	20210219
RECEIPT #:	00079984 : REC	FACILITY:	TRA	CARRIER:	SELF
PACKING SLIP #:	74505	MR #:	03227740	FREIGHT BILL #:	
VENDOR CODE:	0304612			BOXES:	0
VENDOR NAME:	EAGLE ROCK SPECIALTIES				
RECEIPT LINE ITEM:	1	QUALITY LEVEL:	4		
CHEMICAL ITEM:				RECEIPT USER ID:	MATHKA2
CATALOG ID:	0000233976			CONFORM TO PO:	Y
WHSE:	A			DOCK NOTES:	
WHSE PUTAWAY:				SHELF LIFE IND:	N
HOT IND:	N			OSDD #:	
MANUFACTURE CODE:	EAGLE STAINL			FINAL SHIPMENT:	Y
MODEL NUMBER:				TRACE TYPE CODE:	N
PART NUMBER:	S0188016T316SAO			UNIT OF ISSUE:	EA
DESCRIPTION:	TUBING, 3/16" OD X .016" WALL, 20 FT LONG, 316 SS, SEAMLESS, ANNEALED TEMPER			QUANTITY:	7
				UNIT PRICE:	55.760000

Receiving report for "prop tubes" above, material cert below.



EAGLE STAINLESS

Tube and Fabrication, Inc

Franklin Industrial Park 10 Discovery Way Franklin, MA 02038

Telephone: (508) 528-8650 or (800) 528-8650 Fax: (508) 520-1954 or (800) 520-1954 Website: www.eagletube.com Email: info@eagletube.com

MATERIAL TEST REPORT CERTIFICATE OF CONFORMANCE

SOLD TO:	Eagle Rock Specialties LLC	DATE:	2/10/2021
ADDRESS:	PO Box 51436	PURCHASE ORDER:	246855
	Idaho Falls ID 83405	OUR ORDER#:	160094
		PART #	N/A
		REVISION:	N/A

HEAT #: YX1510-802
SOURCE: 47-64843-02-21
ITEM: .188 OD X .016 WALL T316/316L SMLS
Spec: ASTM A213-17/A269-15a EAW
Temper: BRIGHT ANNEALED
Quantity: 140 **Units:** FT

C: .021	Ti: -	Yield (PSI):	47,000/48,000
Si: .37	Cb: -	Tensile (PSI):	89,000/90,000
Mn: .59	Ta: -	Elong. (% IN 2"):	61/62%
P: .038	Fe: balance	Hardness (Rockwell):	B 75/77
S: .004	Cu: -	Flattening:	PASS
Ni: 10.41	Al: -	Flaring:	PASS
Cr: 17.00	N: -	Rev F/B:	-
Mo: 2.04	Co: -	Flange:	-
Misc Chem 1: -		Int C/E:	PASS
Misc Chem 2: -		Eddy Current:	PASS
Misc Chem 3: -		Hydrostatic:	-
		Grain Size:	-

Note 1: MELT & MFG: CHINA
Note 2: MERCURY FREE
Note 3: NO WELD REPAIR
Comments:

Conforms to all drawing and/or specifications requirements. To the best of our knowledge the material is mercury free and compliant with Directive 2011/65/EC and 2006/122/ECOF regarding the Restriction of Hazardous Substances (RoHS), and is conflict free per Dodd-Frank section 1502. By the definitions provided in Article 3 (3) of the REACH regulation, the material(s) are considered "articles," and do not contain substances "intended to release" under normal circumstances and as such, the registration requirements of Article 7(1) do not apply. Reports governing this material are on file.

Paulette Cartier

EAGLE STAINLESS TUBE AND FABRICATION INC.
 Paulette Cartier
 Quality Assurance Manager

AA 2/10/2021
 Int. Date

INL RECEIVING REPORT

PO/RELEASE:	00252289 /	STATUS:	COMPLETE	RECEIPT DATE:	20210611
RECEIPT #:	00081537 : REC	FACILITY:	TRA	CARRIER:	SELF
PACKING SLIP #:	77843	MR #:	03291642	FREIGHT BILL #:	
VENDOR CODE:	0304612			BOXES:	0
VENDOR NAME:	EAGLE ROCK SPECIALTIES			RECEIPT USER ID:	USHEJW
RECEIPT LINE ITEM:	1	QUALITY LEVEL:		CONFORM TO PO:	Y
CHEMICAL ITEM:				DOCK NOTES:	
CATALOG ID:	0000237525			SHELF LIFE IND:	N
WHSE:	A			OSDD #:	
WHSE PUTAWAY:				FINAL SHIPMENT:	Y
HOT IND:	N			TRACE TYPE CODE:	N
MANUFACTURE CODE:	EAGLE STAINL			UNIT OF ISSUE:	EA
MODEL NUMBER:	NA			QUANTITY:	5
PART NUMBER:	H0083008T316WHO			UNIT PRICE:	42.860000
DESCRIPTION:	TUBING, STAINLESS STEEL, HYPODERMIC, GAUGE: 14SP, .083 OD X .008 WALL, 316 SS, 10 FT LENGTH,				

4

Receiving report for flux wire holder tubes above, material cert below.



EAGLE STAINLESS

Tube and Fabrication, Inc

Franklin Industrial Park 10 Discovery Way Franklin, MA 02038

Telephone: (508) 528-8650 or (800) 528-8650 Fax: (508) 520-1954 or (800) 520-1954 Website: www.eagletube.com Email: info@eagletube.com

MATERIAL TEST REPORT CERTIFICATE OF CONFORMANCE

SOLD TO:	Eagle Rock Specialties LLC	DATE:	6/2/2021
ADDRESS:	PO Box 51436	PURCHASE ORDER:	252289
		OUR ORDER#:	161840
	Idaho Falls ID 83405	PART #	N/A
		REVISION:	N/A

HEAT #: SE54994
SOURCE: 57-50802-01-15
ITEM: .0820/.0840 OD X .0650/.0690 T316/316L WLD/DRN
Spec: ASTM A249 CHEMISTRY ONLY
Temper: FULL HARD
Quantity: 60 **Units:** FT

C: .02	Ti: -	Yield (PSI):	152,582
Si: .54	Cb: -	Tensile (PSI):	170,000
Mn: 1.03	Ta: -	Elong. (% IN 2"):	13
P: .027	Fe: balance	Hardness (Rockwell):	-
S: .003	Cu: -	Flattening:	-
Ni: 10.23	Al: -	Flaring:	-
Cr: 16.42	N: -	Rev F/B:	-
Mo: 2.03	Co: -	Flange:	-
Misc Chem 1: -		Int C/E:	-
Misc Chem 2: -		Eddy Current:	-
Misc Chem 3: -		Hydrostatic:	-
		Grain Size:	-

Note 1: MELT SOURCE & MFG: SOUTH KOREA

Note 2: MERCURY FREE

INL RECEIVING REPORT

Microtherm 1000X

PO/RELEASE:	00247852 /	STATUS:	COMPLETE	RECEIPT DATE:	20210511
RECEIPT #:	00081142 : REC	FACILITY:	TRA	CARRIER:	SELF
PACKING SLIP #:	77133	MR #:	03244392	FREIGHT BILL #:	
VENDOR CODE:	0304612			BOXES:	0
VENDOR NAME:	EAGLE ROCK SPECIALTIES				
RECEIPT LINE ITEM:	1	QUALITY LEVEL:	3	RECEIPT USER ID:	USHEJW
CHEMICAL ITEM:				CONFORM TO PO:	Y
CATALOG ID:	0000234581			DOCK NOTES:	
WHSE:	A			SHELF LIFE IND:	N
WHSE PUTAWAY:				OSDD #:	
HOT IND:	N			FINAL SHIPMENT:	Y
MANUFACTURE CODE:	PROMAT			TRACE TYPE CODE:	N
MODEL NUMBER:	1000X			UNIT OF ISSUE:	PC
PART NUMBER:	257392			QUANTITY:	5
DESCRIPTION:	INSULATION, 1220MM X 610MM X 6MM, HIGH TEMP, MICROTHERM (SEMI) QUILTED,			UNIT PRICE:	72.140000

Promat

Safety Data Sheet (SDS)

Page 2

OSHA HazCom Standard 29 CFR 1910.1200(g), Rev. 2012 and GHS Rev 03.

Issued on 11-Oct-2017

Trade name: MICROTHERM® 1000X and related products

3 Composition/information on ingredients

10034-76-1	Calcium sulphate	0-25%
1343-98-2	Silica Fiber	0-12%
<ul style="list-style-type: none"> • Chemical characterization: Mixtures • Description: Mixture of the substances listed below with nonhazardous additions. • Hazardous Components: 		
112945-52-5	Amorphous Silica	50-90%
409-21-2	silicon carbide	10-50%
1344-28-1	aluminium oxide	0-25%
	◊ STOT SE 3, H335	
1344-95-2	Silica fiber	0-12%
65997-17-3	Fibrous Glass	0-12%
	◊ Skin Irrit. 2, H315; Eye Irrit. 2A, H319; STOT SE 3, H335	


• **Additional information:**

MICROTHERM 1000X insulation products contain no respirable fibers (see Section 11) and therefore fall outside the scope of European Community Directive Amendment 97/69/EC.


MICROTHERM 1000X insulation products may be supplied encapsulated in covering materials such as woven glass cloth, non-woven polyester cloth, PE foil, aluminum foil and mica sheet.

Appendix E

Dry Tube Assembly Sketches



Assembly and Functional Test of NRAD Heated Instrumentation Rig




MATERIAL: ALUMINUM ALLOY PLATE OR BAR
ASTM B221 OR B209, 6061-T6XX

ADAPTER TO CONNECT ASI DRY TUBE TO
NRAD CLUSTER FITTING (734402)

SKETCH: AJP-02-2021 - REV. 1
2/13/2021

Assembly and Functional Test of NRAD Heated Instrumentation Rig




MATERIAL: 6061-T6 AL, 0.50 INCH THICK

NRAD DRY TUBE CABLE SUPPORT PLATE

SKETCH AJP-04-2021
4/30/2021

Appendix F

Heater Power Supply



VARIAC Power Supply


RE: TTAF Immersion heater



John J. Whipple

To  Mark A. Redden

Cc  Joe J. Palmer;  Randel N. Paulsen

 You replied to this message on 7/1/2021 4:41 PM.

Mark,

Thank you for looking at the heater and taking the time to document your observations.

Joe & Randal,

Based on Mark's evaluation the heater is approved for use. You can file this e-mail in your project file for documentation.

Thank You,

John

From: Mark A. Redden <Mark.Redden@inl.gov>

Sent: Thursday, July 1, 2021 2:55 PM

To: John J. Whipple <john.whipple@inl.gov>

Cc: Joe J. Palmer <joe.palmer@inl.gov>; Randel N. Paulsen <randel.paulsen@inl.gov>

Subject: TTAF Immersion heater


John, at the request of Randal, I walked over to TTAF and looked at the immersion heater. These are the observations I made:

1. Connection at the heater is a threaded bolt threaded into one of the tubes.
2. #12 AWG stranded THHN/THWN green copper conductor with a crimped stakon ring tongue lug connector.
3. #12 AWG ground with the heater line and neutral conductors connected to a 3c. #12 SEOW cord with crimped connections and insulated with heat shrink tubing.
4. The other end of the cord has a 15 amp three prong (ground, line and neutral) 120v. male connector.
5. The circuit feeding the heater is GFCI protected.

Appendix G

NRAD Heated Test – Sensors and Cabling Summary (As-Run 8/25/2021)

Instr. No.	Sensor Description	Probe diameter (mm)	Probe length (mm)	Cable diameter (mm)	Mating connector(s) at end of soft cable	Bundle hole position
1	Thermocouple, Type K (3 points)	1.6	90	1.6	TC plugs (3 ea)	1
2	RML Dosimetry (NRAD-1)	1.0	~30	NA	NA	2
3	INL (Rh) SPND	2.5	95	2.5	2 ea BNC male	5
4	RML Dosimetry (NRAD-2)	1.0	~30	NA	NA	5
5	INL (Rh) SPND	2	95	2.0	2 ea BNC male	6



Notes:

1. Position 3 was open
2. Position 4 contained a grounding lug (no room for sensors)