



# Emergency Procedure Network entry procedure and CSFTs

November 2022

*Changing the World's Energy Future*

Robert D Chapa



*INL is a U.S. Department of Energy National Laboratory operated by Battelle Energy Alliance, LLC*

#### **DISCLAIMER**

This information was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness, of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trade mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the U.S. Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the U.S. Government or any agency thereof.

# **Emergency Procedure Network entry procedure and CSFTs**

**Robert D Chapa**

**November 2022**

**Idaho National Laboratory  
Idaho Falls, Idaho 83415**

**<http://www.inl.gov>**

**Prepared for the  
U.S. Department of Energy  
Under DOE Idaho Operations Office  
Contract DE-AC07-05ID14517**

**Idaho National Laboratory**

|                        |  |
|------------------------|--|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 <div style="text-align: right;">Page: 1 of</div> |
|------------------------|--|

|   |                             |                   |                    |
|---|-----------------------------|-------------------|--------------------|
| ATR Complex   | Emergency Procedure Network | <b>USE TYPE 2</b> | DCR Number: 696275 |
| Manual: ATR Complex – ATR Emergency Response Procedure Network Manual |                             |                   |                    |
| Document Owner: Shift Supervisor                                      |                             |                   |                    |

# TSR PROCEDURE

**NOTE:**     *This document uses the word “diesel” to refer to equipment powered from either a diesel generator or the 480 V Diesel UPS, 670-E-1576.*

## ENTRY CONDITIONS

This procedure is entered:

- On any reactor scram
- On any reactor scram where one has been called for but has not occurred
- Any time a loss of commercial, diesel, or commercial and diesel power occurs with the reactor in an outage condition
- Any time a complete loss of primary flow occurs during an outage condition.
- Any time an uncontrolled loss of primary coolant is determined to be in progress with the reactor in an outage condition
- Any time a pressurizing and gland seal pump shutoff ESF Actuation System has actuated or 2 or more high-high inlet pressure alarms have been received during reactor outage.
- At the discretion of CRS/SS, when reactor is in an outage condition.

## Idaho National Laboratory

|                 |  |
|-----------------|--|
| ENTRY PROCEDURE | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 Page: 2 of |
|-----------------|--|

## INSTRUCTIONS

| <u>STEP</u> | <u>INSTRUCTIONS</u>  | <u>RESPONSE NOT OBTAINED</u>   |
|-------------|--|--|
|             | <b>NOTE:</b> <i>A # sign indicates immediate actions.</i>                    |  |
| #1.         | <u>VERIFY</u> all active safety rods inserted:                               | 1. <u>INITIATE</u> a manual scram from any or all of the following:  |
|             | <ul style="list-style-type: none"> <li>Position indicator –</li> </ul>       | <ul style="list-style-type: none"> <li>At the reactor console</li> </ul>   |
|             | ZERO in.   |  |
|             | <ul style="list-style-type: none"> <li>Lower limit switch light –</li> </ul> | <ul style="list-style-type: none"> <li>Using the emergency backup scram pushbuttons</li> </ul>                                 |
|             | ON   |  |
|             | <ul style="list-style-type: none"> <li>Seat switch light –</li> </ul>        | <ul style="list-style-type: none"> <li>From the LOCS experiment loop panel.</li> </ul>   |
|             | ON.  | <ul style="list-style-type: none"> <li>From the RMC per OMM-7.22.2.1.1, “ATR Remote Management Capability Startup.”</li> </ul> |
|             |  | <u>AND</u>   |
|             |  | <u>INITIATE</u> a REVERSE.   |
| #2.         | <u>VERIFY</u> reactor shutdown:  | 2. <u>GO TO</u> FRP-S.1, “Uncontrolled Power Generation/ATWS.”   |
|             | <ul style="list-style-type: none"> <li>Power –</li> </ul>                    |  |
|             | LESS THAN $N_L$  |  |
|             | <ul style="list-style-type: none"> <li>Period –</li> </ul>                   |  |
|             | NEGATIVE.  |  |
| #3.         | <u>INSERT</u> all OSCCs 4 degrees.   | 3. <u>PROCEED TO</u> Step 4.   |

## Idaho National Laboratory

|                 |   |
|-----------------|---|
| ENTRY PROCEDURE | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22<br>Page: 3 of |
|-----------------|---|

|             |                     |                              |
|-------------|---------------------|------------------------------|
| <u>STEP</u> | <u>INSTRUCTIONS</u> | <u>RESPONSE NOT OBTAINED</u> |
|-------------|---------------------|------------------------------|

- #4. VERIFY Vessel  $\Delta P$  (Vessel dP) –  
LESS THAN  
133.3 psid.

**CAUTION**

**Maintain PCS flow for at least 30 minutes following Reactor scram.**  
[TSR-186, 3.3.3]  
PCS flow is required during capsule Experiment Flow Cooling Time following reactor shutdown, flow from a single ECP ensures adequate cooling. (SAR-153, 10.3.5.2.2)

CHECK at least one emergency pump is operating,

AND SECURE, as necessary, the operating PCPs.

5. CONTROL reactor inlet temperature TR-509X by one or more of the following methods:

- CONTROLLING cooling tower fans as necessary
- PLACING reactor inlet temperature controller TIC-1-10 –

IN MANUAL

- ADJUST valve TCV-1-10 using controller TIC-1-10 –

OFF MINIMUM STOP.

- |   |  |
|---|--|
| 6. <u>VERIFY</u> E-3 is energized or commercial power is available. | 5. <u>GO TO</u> ECAP-0, "Loss of All Commercial and Diesel Power." |
|---|--|

**NOTE:** *If all commercial and E-3 power is lost between Step 7 and completion of the procedure, GO TO ECAP-0.*

## Idaho National Laboratory

|                        |  |
|------------------------|--|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 <div style="text-align: right;">Page: 4 of</div> |
|------------------------|--|

| <u>STEP</u> | <u>INSTRUCTIONS</u>   | <u>RESPONSE NOT OBTAINED</u>   |
|-------------|---|--|
| 7.          | <u>VERIFY</u> a total loss of process DCS indication and control has <u>NOT</u> occurred –<br><br>At least one work station indicates active values and controls.   | 7. <u>INITIATE</u> a REVERSE<br><br><u>THEN:</u><br><br><u>PERFORM</u> AOP-0.3, “Total Loss of Process DCS Indications and Controls,” <u>AND</u> in conjunction GO TO ERP-0.5, “Total Loss of Process DCS Indications and Controls.” |
| 8.          | <u>VERIFY</u> PCS Intact:<br>a. Upper vessel level LI-514X –<br><br>GREATER THAN<br>90 in. [99 ft 6 in.]<br><br>b. Firewater injection pressure PI-534X –<br><br>GREATER THAN<br>30 psia<br><br>c. Flow balance: pressurizing flow<br>FIC-1-8A/FIC-1-8B To PCV-1-1 Flow<br>“PRI to DEGAS”<br><br>LESS THAN<br>300 gpm<br><br>OR<br>FIC-1-8A/FIC-1-8B Not over-ranged (INST HIGH-BAD). | 8. <u>INITIATE</u> a REVERSE<br><br><u>THEN:</u><br><br><u>GO TO</u> E-1, “Loss of Primary Coolant.”   |
| 9.          | <u>VERIFY</u> Adequate core cooling:<br>Emergency Flow – (FI-503X) –<br><br>GREATER THAN<br>3,800 gpm<br><br>OR<br>Vessel $\Delta P$ (Vessel dP, DP-500X) –<br><br>GREATER THAN<br>15 psid  | 9. <u>INITIATE</u> a REVERSE<br><br><u>THEN:</u><br><br><u>GO TO</u> E-2, “Loss of Primary Coolant Flow.”  |

## Idaho National Laboratory

|   |   |
|---|---|
| <p style="text-align: center;"><b>ENTRY PROCEDURE</b></p> | <p>Identifier: E-0<br/>Revision: 20<br/>Effective Date: 11/09/22</p> <p style="text-align: right;">Page: 5 of</p> |
|---|---|

| <u>STEP</u> | <u>INSTRUCTIONS</u>   | <u>RESPONSE NOT OBTAINED</u>   |
|-------------|---|--|
| 10.         | <p><u>VERIFY</u> secondary flow (DPT-2-13) greater than 1.2 psid or UCW flow (FIC-2-4) –</p> <p style="text-align: center;">GREATER THAN<br/>1,500 gpm.</p>   | <p>10. <u>ENSURE</u> breakers 22 and 23 on 670-E-1745 are SHUT</p> <p><u>AND</u></p> <p><u>RESET</u> UCW trips on DCS as necessary,</p> <p><u>THEN:</u></p> <p><u>START</u> UCW pump from DCS.</p> |
| 11.         | <p><u>BEGIN MONITORING</u> critical safety function status trees.</p>   | <p>11. <u>BEGIN MONITORING</u> critical safety function status trees.</p>  |
| 12.         | <p><u>VERIFY:</u></p> <p>a. The pressurizing and gland seal pump shutoff ESF Actuation System HAS NOT ACTUATED</p> <p><u>AND</u></p> <p>b. A high-high inlet PCS Pressure –WAS NOT REACHED.</p> <p style="text-align: center;">(385 psig on 2 or 3 channels).</p> | <p>12. <u>GO TO</u> ERP-0.2, “High PCS Pressure.”</p>  |
| 13.         | <p><u>VERIFY</u> reactor outlet temperature TRS-1-17 –</p> <p style="text-align: center;">LESS THAN<br/>180°F.</p>  | <p>13. <u>INITIATE</u> a REVERSE</p> <p><u>THEN:</u></p> <p><u>GO TO</u> FRP-C.3, “Degraded Core Cooling.”</p>   |
| 14.         | <p><u>VERIFY</u> power to all 4,160-V busses supplied by commercial power has –</p> <p style="text-align: center;">NOT BEEN<br/>INTERRUPTED.</p>  | <p>14. <u>GO TO</u> ERP-0.3, “Loss of Commercial Power.”</p>   |
| 15.         | <p><u>IF:</u> The E-3 bus was being supplied by a diesel generator,</p> <p><u>AND</u> The 480 V UPS is in bypass,</p> <p><u>THEN:</u> <u>VERIFY</u> power to the 4,160-V diesel bus has –</p> <p style="text-align: center;">NOT BEEN<br/>INTERRUPTED.</p>        | <p>15. <u>GO TO</u> ERP-0.4, “Loss of Diesel Power.”</p>   |



## Idaho National Laboratory

|                 |  |
|-----------------|--|
| ENTRY PROCEDURE | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 Page: 6 of |
|-----------------|--|

- | <u>STEP</u> | <u>INSTRUCTIONS</u>  | <u>RESPONSE NOT OBTAINED</u>   |
|-------------|--|--|
| 16.         | <u>CALCULATE</u> PCS leak rate<br>(OMM-7.3.13.1.33, "Primary Coolant<br>System Leak Rate Calculation.")<br><br>LEAKAGE<br>LESS THAN<br>50 gpm.   | 16. <u>INITIATE</u> a REVERSE <u>AND</u><br><u>IF</u> : Less than 300 gpm,<br><u>THEN</u> : <u>GO TO</u> AOP-1.3, "Increased<br>PCS Leakage."<br><u>IF NOT</u> : <u>GO TO</u> E-1, "Loss of Primary<br>Coolant." |
| 17.         | As directed by ATR Operations<br>Management<br>a. <u>GO TO</u> DOP-7.2.13, "Quick Reactor<br>Startup."<br><u>OR</u><br>b. <u>GO TO</u> DOP-7.2.7, "Reactor Outage,"<br><u>OR</u><br>c. <u>GO TO</u> any appropriate procedure. |  |
- END OF PROCEDURE**

## Idaho National Laboratory

|                        |  |
|------------------------|--|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 Page: 7 of |
|------------------------|--|

**Appendix A****Risks and Controls**

**NOTE:** *During performance of this procedure, expect to encounter these routine hazards. If any other routine hazards listed in LI-295, "Hazard Controls for General Maintenance/Operations," are encountered, the job may continue without a procedure change request, with JS concurrence.*

| Sequence of Basic Activities  | Potential Hazard | Hazard Control                      |
|---|------------------|-------------------------------------|
| 1. Operation of circuit breakers or switches >240 V up to 600 V with no live exposed parts. (Generally for performing system line-ups or electrical lockout/tagout) Per LI-728, "Operating Switches, Disconnects and Overcurrent Protection Devices." | 1. Arc flash     | 1. 1) Per LI-295.<br>2) Per LI-728. |

**Certification/Qualification/Training Required**

None.

**PPE Required**

None.

**Idaho National Laboratory**

|                        |                 |          |            |
|------------------------|-----------------|----------|------------|
| <b>ENTRY PROCEDURE</b> | Identifier:     | E-0      | Page: 8 of |
|                        | Revision:       | 20       |            |
|                        | Effective Date: | 11/09/22 |            |

**Appendix B****Review Requirements**

| PROCEDURE REVIEW REQUIREMENTS   |        |                         |        |
|---|--------|-------------------------|--------|
| DISCIPLINE  | CHANGE | DISCIPLINE              | CHANGE |
| OPERATIONS  | X      | TRAINING                | X      |
| MAINTENANCE   | N/A    | QUALITY ASSURANCE       | *      |
| EXPERIMENT ENGINEERING  | N/A    | ENVIRONMENTAL           | *      |
| ENGINEERING   | X      | RADIOLOGICAL CONTROLS   | *      |
| REACTOR ENGINEERING   | *      | INDUSTRIAL HYGIENE      | *      |
| NUCLEAR SAFETY ENGINEERING  | *      | INDUSTRIAL SAFETY       | *      |
| SORC  | X      | EMERGENCY MANAGEMENT    | *      |
| TSR REVIEW  | X      | FIRE PROTECTION         | N/A    |
| CUI REVIEW  | X      | INFRASTRUCTURE/FACILITY | N/A    |
| * SP-10.2.2.3 AND DOCUMENT OWNER WILL DETERMINE ACTUAL REVIEWS NEEDED FOR DOCUMENTS IN ORDER TO MITIGATE HAZARDS ASSOCIATED WITH THE SCOPE OF THE CHANGE. |        |                         |        |

**Revision Log**

## Idaho National Laboratory

|                        |  |
|------------------------|--|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 <div style="text-align: right;">Page: 9 of</div> |
|------------------------|--|

| Rev. | Date     | Affected Pages | Revision Description   |
|------|----------|----------------|--|
| 7    | 08/06/09 | All            | See eCR 562422. Revise.  |
| 8    | 11/30/11 | All            | See eCR 582662. Revise. 588214. Revise for Procedure Upgrade Plan. |
| 9    | 11/30/11 | 2              | See eCR 600286. Minor Change.                                      |
| 10   | 12/12/11 | 2, 4           | See eCR 600575. Revise.  |
| 11   | 09/26/13 | 3, 4           | See eCR 616300. Revise.  |
| 12   | 01/29/15 | All            | See eCRs 624040. Revise. 628171. Permanent Field Change.           |
| 13   | 02/04/15 | 2              | See eCR 628943. Minor change.                                      |
| 14   | 02/04/15 | ALL            | See eCR 633142. Revise.  |
| 15   | 04/06/16 | All            | See eCR 624676. Revise.  |
| 16   | 05/31/18 | All            | See eCR 660090. Revise.  |
| 17   | 06/09/18 | 4              | See eCR 660478. Revise.  |
| 18   | 08/15/18 | All            | See eCR 660584. ATR Complex-USQ-2014-458.                          |
| 19   | 12/11/18 | All            | See eCR 662091. Periodic Review.                                   |
| 20   | 11/09/22 | All            | See DCR 696275. Revise. BF-1-14 Implementation.                    |

**Idaho National Laboratory**

|                     |  |
|---------------------|--|
| <b>CORE COOLING</b> | Identifier: CSF-C<br>Revision: 7<br>Effective Date: 06/09/18 <div style="text-align: right;">Page: 1 of 16</div> |
|---------------------|--|

**REFERENCE PAGE**

IF this procedure is used during a reactor outage,  
THEN performance of some steps may not be appropriate based on current plant or system conditions. Steps are to be performed at the SS's discretion.

In case of instrument or indication failure. Alternate or diverse indications may be substituted with CRS/SS permission.

CSF-S

## Idaho National Laboratory


|                     |                 |          |
|---------------------|-----------------|----------|
| <b>CORE COOLING</b> | Identifier:     | CSF-C    |
|                     | Revision:       | 7        |
|                     | Effective Date: | 06/09/18 |
| Page: 2 of 16       |                 |          |

|             |                 |            |                    |
|-------------|-----------------|------------|--------------------|
| ATR Complex | Status Tree/EPN | USE TYPE 2 | eCR Number: 601257 |
|-------------|-----------------|------------|--------------------|

Manual: EPN – ATR Critical Safety Functional Status Trees

Document Owner: Shift Supervisor

## ATR EMERGENCY PROCEDURE NETWORK



## Idaho National Laboratory

|                     |  |
|---------------------|--|
| <b>CORE COOLING</b> | Identifier: CSF-C<br>Revision: 7<br>Effective Date: 06/09/18 |
|                     | Page: 3 of 16  |

## ATR EMERGENCY PROCEDURE NETWORK

| PROCEDURE REVIEW REQUIREMENTS PER SP-10.2.2.3  |        |                          |        |
|--|--------|--------------------------|--------|
| DISCIPLINE   | CHANGE | DISCIPLINE               | CHANGE |
| ATR OPERATIONS   | X      | INDUSTRIAL SAFETY        | *      |
| NUCLEAR MAINTENANCE  | N/A    | QUALITY                  | *      |
| EXPERIMENT ENGINEERING   | N/A    | ENVIRONMENTAL            | *      |
| ENGINEERING  | *      | RADCON                   | *      |
| NUCLEAR ENGINEERING  | X      | INDUSTRIAL HYGIENE       | *      |
| TRAINING   | X      | F&SS                     | N/A    |
| SORC   | X      | EMERGENCY PREPAREDNESS   | N/A    |
| TSR REVIEW   | X      | FIRE PROTECTION          | N/A    |
| CUI REVIEW   | X      | WASTE GENERATOR SERVICES | N/A    |
| * DOCUMENT OWNER SHALL DETERMINE THE NEED FOR THESE REVIEWS BASED UPON THE SCOPE OF THE CHANGE |        |                          |        |

## REVISION LOG

| Rev. | Date     | Affected Pages | Revision Description             |
|------|----------|----------------|----------------------------------|
| N/A  | 03/16/00 | All            | See DAR 65065. MCP-3562 review.  |
| 1    | 09/20/05 | All            | See DAR 123248. Periodic Review. |
| 2    | 11/13/13 | All            | See eCR 601257. Periodic Review. |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |

|             |                 |            |                    |
|-------------|-----------------|------------|--------------------|
| ATR Complex | Status Tree/EPN | USE TYPE 2 | eCR Number: 660477 |
|-------------|-----------------|------------|--------------------|


## Idaho National Laboratory

|                     |                 |               |
|---------------------|-----------------|---------------|
| <b>CORE COOLING</b> | Identifier:     | CSF-C         |
|                     | Revision:       | 7             |
|                     | Effective Date: | 06/09/18      |
|                     |                 | Page: 4 of 16 |

Manual: ATR Complex – EPN – ATR Critical Safety Functional Status Trees

Document Owner: Shift Supervisor

## ATR EMERGENCY PROCEDURE NETWORK



SK604755R2



|  |   |
|--|---|
| <p style="text-align: center;"><b>CORE COOLING</b></p> | <p>Identifier: CSF-C</p> <p>Revision: 7</p> <p>Effective Date: 06/09/18</p> <p style="text-align: right;">Page: 5 of 16</p> |
|--|---|

# TSR PROCEDURE

| PROCEDURE REVIEW REQUIREMENTS   |        |                         |        |
|---|--------|-------------------------|--------|
| DISCIPLINE  | CHANGE | DISCIPLINE              | CHANGE |
| OPERATIONS  | X      | TRAINING                | *      |
| MAINTENANCE   | N/A    | QUALITY ASSURANCE       | *      |
| EXPERIMENT ENGINEERING  | N/A    | ENVIRONMENTAL           | *      |
| ENGINEERING   | *      | RADIOLOGICAL CONTROLS   | *      |
| REACTOR ENGINEERING   | *      | INDUSTRIAL HYGIENE      | *      |
| NUCLEAR SAFETY ENGINEERING  | *      | INDUSTRIAL SAFETY       | *      |
| SORC  | X      | EMERGENCY MANAGEMENT    | N/A    |
| TSR REVIEW  | X      | FIRE PROTECTION         | N/A    |
| CUI REVIEW  | X      | INFRASTRUCTURE/FACILITY | N/A    |
| * SP-10.2.2.3 AND DOCUMENT OWNER WILL DETERMINE ACTUAL REVIEWS NEEDED FOR DOCUMENTS IN ORDER TO MITIGATE HAZARDS ASSOCIATED WITH THE SCOPE OF THE CHANGE. |        |                         |        |

## Revision Log

| Rev. | Date     | Affected Pages | Revision Description                                   |
|------|----------|----------------|--|
| 0    | 03/16/00 | All            | See DAR 65065. MCP-3562 review.                        |
| 1    | 04/07/05 | All            | See DAR 121600.  |
| 2    | 08/06/09 | All            | See eCR 561204.  |
| 3    | 11/30/11 | All            | See eCR 582700.  |
| 4    | 12/12/11 | 1              | See eCR 600577. Revise.                                |
| 5    | 06/22/15 | 1              | See eCR 620610. PUP Periodic Review. 624671. Revision. |
| 6    | 12/19/17 | 1              | See eCR 654789. Revise.                                |
| 7    | 06/09/18 | 1              | See eCR 660477. Revise.                                |
|      |          |                |  |
|      |          |                |  |

## Idaho National Laboratory


|                        |   |
|------------------------|---|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0<br>Revision: 20<br>Effective Date: 11/09/22 <div style="text-align: right;"><b>Reference Page</b></div> |
|------------------------|---|

**REFERENCE PAGE**

IF this procedure is used during a control room evacuation,  
THEN PERFORM this procedure using the following controls and indications available from TRA-680 RMC as applicable:

- SCRAM and Reverse function using TRA-680 RMC HS8, “ENABLE REMOTE SHUTDOWN PANEL” key switch
- Firewater Injection Level LI-535A, LI-535B, and LI-535C
- Firewater Injection Pressure PI-534A, PI-534B, and PI-534C
- EFIS Pressure Bypass Switch
- Upper Vessel and Bottom Head Firewater Injection Manual Actuation
- Vessel Vent Manual Actuation
- Indications available from the CDS
- Controls and Indications available from the DCS.

|   |                 |                    |
|---|-----------------|--------------------|
| ATR Complex   | Status Tree/EPN | eCR Number: 647286 |
| Manual: ATR Complex – EPN – ATR Critical Safety Functional Status Trees |                 |                    |
| Document Owner: Shift Supervisor  |                 |                    |

**ATR EMERGENCY PROCEDURE NETWORK**

## Idaho National Laboratory

|                        |                          |                       |
|------------------------|--------------------------|-----------------------|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0          | <b>Reference Page</b> |
|                        | Revision: 20             |                       |
|                        | Effective Date: 11/09/22 |                       |

**ATR EMERGENCY PROCEDURE NETWORK**

| PROCEDURE REVIEW REQUIREMENTS   |        |                         |        |
|---|--------|-------------------------|--------|
| DISCIPLINE  | CHANGE | DISCIPLINE              | CHANGE |
| OPERATIONS  | X      | TRAINING                | *      |
| MAINTENANCE   | N/A    | QUALITY ASSURANCE       | *      |
| EXPERIMENT ENGINEERING  | N/A    | ENVIRONMENTAL           | *      |
| ENGINEERING   | *      | RADIOLOGICAL CONTROLS   | N/A    |
| REACTOR ENGINEERING   | *      | INDUSTRIAL HYGIENE      | *      |
| NUCLEAR SAFETY ENGINEERING  | X      | INDUSTRIAL SAFETY       | *      |
| SORC  | X      | EMERGENCY MANAGEMENT    | N/A    |
| TSR REVIEW  | N/A    | FIRE PROTECTION         | N/A    |
| CUI REVIEW  | X      | INFRASTRUCTURE/FACILITY | N/A    |
| * SP-10.2.2.3 AND DOCUMENT OWNER WILL DETERMINE ACTUAL REVIEWS NEEDED FOR DOCUMENTS IN ORDER TO MITIGATE HAZARDS ASSOCIATED WITH THE SCOPE OF THE CHANGE. |        |                         |        |

**REVISION LOG**

| Rev. | Date     | Affected Pages | Revision Description             |
|------|----------|----------------|----------------------------------|
| NA   | 03/16/00 | All            | See DAR 65065. MCP-3562 review.  |
| 1    | 10/04/05 | All            | See DAR 123251. Periodic Review. |
| 2    | 09/03/08 | 1              | See eCR 562846. Periodic Review. |
| 3    | 09/14/17 | All            | See eCR 647286. Revision.        |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |

|             |                 |  |                    |
|-------------|-----------------|--|--------------------|
| ATR Complex | Status Tree/EPN |  | eCR Number: 647286 |
|-------------|-----------------|--|--------------------|

**Idaho National Laboratory**

|                        |                 |          |                       |
|------------------------|-----------------|----------|-----------------------|
| <b>ENTRY PROCEDURE</b> | Identifier:     | E-0      | <b>Reference Page</b> |
|                        | Revision:       | 20       |                       |
|                        | Effective Date: | 11/09/22 |                       |

Manual: ATR Complex – EPN – ATR Critical Safety Functional Status Trees  
Document Owner: Shift Supervisor

**ATR EMERGENCY PROCEDURE NETWORK**

## Idaho National Laboratory

|                        |                          |                       |
|------------------------|--------------------------|-----------------------|
| <b>ENTRY PROCEDURE</b> | Identifier: E-0          | <b>Reference Page</b> |
|                        | Revision: 20             |                       |
|                        | Effective Date: 11/09/22 |                       |

**ATR EMERGENCY PROCEDURE NETWORK**

| PROCEDURE REVIEW REQUIREMENTS   |        |                         |        |
|---|--------|-------------------------|--------|
| DISCIPLINE  | CHANGE | DISCIPLINE              | CHANGE |
| OPERATIONS  | X      | TRAINING                | *      |
| MAINTENANCE   | N/A    | QUALITY ASSURANCE       | *      |
| EXPERIMENT ENGINEERING  | N/A    | ENVIRONMENTAL           | *      |
| ENGINEERING   | *      | RADIOLOGICAL CONTROLS   | N/A    |
| REACTOR ENGINEERING   | *      | INDUSTRIAL HYGIENE      | *      |
| NUCLEAR SAFETY ENGINEERING  | X      | INDUSTRIAL SAFETY       | *      |
| SORC  | X      | EMERGENCY MANAGEMENT    | N/A    |
| TSR REVIEW  | N/A    | FIRE PROTECTION         | N/A    |
| CUI REVIEW  | X      | INFRASTRUCTURE/FACILITY | N/A    |
| * SP-10.2.2.3 AND DOCUMENT OWNER WILL DETERMINE ACTUAL REVIEWS NEEDED FOR DOCUMENTS IN ORDER TO MITIGATE HAZARDS ASSOCIATED WITH THE SCOPE OF THE CHANGE. |        |                         |        |

**REVISION LOG**

| Rev. | Date     | Affected Pages | Revision Description             |
|------|----------|----------------|----------------------------------|
| NA   | 03/16/00 | All            | See DAR 65065. MCP-3562 review.  |
| 1    | 10/04/05 | All            | See DAR 123251. Periodic Review. |
| 2    | 09/03/08 | 1              | See eCR 562846. Periodic Review. |
| 3    | 09/14/17 | All            | See eCR 647286. Revision.        |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |
|      |          |                |                                  |